




Risk Analysis Screening Tool (RAST)

RAST User's Manual



Version: 3.0

Revision Date: 12-March-2020

Document Owner: Louisa Nara, CCPS Global Technical Director

Document Technical Advisor: Bruce K. Vaughan, CCPS Lead Process Safety Subject Matter Expert

Risk Analysis Screening Tool (RAST) User's Manual

Purpose

This document provides a reference for using RAST and for RAST Users who have attended classroom training in a Risk Analysis Screening Tool (RAST) workshop. This manual is available on the RAST/CHEF website [1].

Please refer to the Chemical Hazards Engineering Fundamentals (CHEF) Manual for the conceptual methods and mathematical techniques that are used in the RAST software.

Feedback Request:

Please provide feedback or comments on the content of this document to the RAST Committee, via the CCPS RAST/CHEF website [1].

Revision History:

This manual's history is located at the end of this document.

Disclaimer

It is sincerely hoped that the information presented in this document will lead to an even better safety record for the entire industry; however, neither the American Institute of Chemical Engineers (AIChE), its consultants, Center for Chemical Process Safety (CCPS) Technical Steering Committee and Subcommittee members, their employers, their employers officers and directors, nor The Dow Chemical Company, and its employees warrant or represent, expressly or by implication, the correctness or accuracy of the content of the information presented in this document. As between (1) American Institute of Chemical Engineers (AIChE), its consultants, the Center for Chemical Process Safety (CCPS) Technical Steering Committee and Subcommittee members, their employers, their employer's officers and directors, nor The Dow Chemical Company, and its employees, and (2) the user of this document, the user accepts any legal liability or responsibility whatsoever for the consequence of its use or misuse.

Copyright © 2020

American Institute of Chemical Engineers

TABLE OF CONTENTS

TABLE OF CONTENTS.....	3
1. INTRODUCTION	4
2. GETTING STARTED.....	12
3. CHEMICAL DATA.....	41
4. REACTIVITY DATA AND EVALUATION.....	50
5. ADDITIONAL RAST INPUTS AND REPORTS	63
6. SCENARIO DEVELOPMENT	83
7. LAYERS OF PROTECTION ANALYSIS	101
8. CASE STUDY.....	123
9. REFERENCES	125
10. GLOSSARY OF TERMS	125
11. REVISION HISTORY	126

1. INTRODUCTION

Intended Audience

The intended audience for Risk Analysis Screening Tool (RAST) software is personnel performing Screening Level Hazard Evaluation or Risk Analysis (such as a Layers of Protection Analysis) for existing and future manufacturing facilities including:

- Manufacturing personnel
- Research and Development Engineers
- Process Engineers
- Other Process Safety roles

User's Manual Objectives

The overall objective for the RAST manual is to:

- Develop familiarity with the RAST tool such that Evaluation Teams with the help of Facilitators and Process Safety personnel should be able to perform *screening level* Hazard and Risk Evaluations.
- Provide an example problem so that users understand the limitations of this tool and when to utilize more advanced methods or to engage a Subject Matter Expert.

Sections

There are 9 sections included in the Risk Analysis Screening Tool User's Manual including:

1. Introduction
2. Getting Started with RAST
3. Chemical Properties
4. Evaluation of Reactivity Hazards
5. Additional Inputs and Reports
6. Scenario Development
7. Layers of Protection Analysis
8. Case Study
9. Wrap-up

Process Risk Management

Process Risk is a measure of human injury, environmental damage, or economic loss resulting from an incident in terms of both likelihood and magnitude of the loss or injury. Risk Management is the systematic application of management policies and procedures in analyzing, assessing, and controlling risk. It utilizes both *Risk Analysis* and *Risk Assessment*. Process Risk management is intended to continuously improve safety, health, and environmental performance of manufacturing plants over the long term by addressing risk to people, property, and the environment. RAST supports risk analysis in providing a consistent evaluation based on a company's specific criteria.

What is RAST?

RAST is a collection of process safety and risk analysis screening tools used to assist when performing a Hazard Identification and Risk Analysis (HIRA) study that draws upon common input information. Included are:

- Dow Fire and Explosion Index (FEI)
- Dow Chemical Exposure Index (CEI)
- Reaction Hazards Evaluation
- Identification of Common Scenarios
- Hazards and Consequence Evaluation Summary
- Relief Device Effluent Screening
- Risk Analysis (modified Layers of Protection Analysis or LOPA)

RAST is intended as a productivity tool to aid evaluation teams in performing Hazard Identification and Risk Analysis (HIRA) studies providing consistency among analysis teams while reinforcing company protocol and criteria. It utilizes simplified and often empirical methods in quantifying hazards, consequences and risk. These methods have been quality checked and reasonably correlate to complex algorithms of other commercially developed software

RAST bridges the gap between qualitative and detailed quantitative risk evaluation and allows application of greater rigor and detail for high risk scenarios (Figure 1.1). In some cases, other software or rigorous evaluation methods may be needed beyond the capability of RAST to meet a company's risk analysis requirements. For these cases, RAST accommodates the entry of results from other software or methods (including qualitative estimates) in the overall study.




Figure 1.1 Hierarchy of Risk Analysis Methods

Hazard Identification and Risk Analysis is a collective term that encompasses all activities involved in identifying hazards and evaluating risk at facilities, throughout their life cycle, to make certain that risks to employees, the public, or the environment are consistently controlled within the organization's risk tolerance [2]. RAST is based on a suggested HIRA work process (Figure 1.2) to answer basic questions involving:

- What are the Hazards?
- What can go Wrong?

- How Bad can it be?
- How Often might it happen?
- Is the Risk Tolerable?



Figure 1.2 Overall Work Process Steps for Hazard Evaluation and Risk Analysis

RAST and the accompanying Chemical Hazards Engineering Fundamentals (CHEF) materials are based on performing HIRA tasks in a specific order. The order of task execution is based on an overall work flow such that results of a specific estimate (such as a source model) being available as input for the subsequent task (such as vapor dispersion). RAST is set up to use minimal information to get started with the addition of more information over time to improve the analysis and generate additional reports.

The overall Work Process for HIRA within RAST includes:

Identify the Equipment or Activity for the analysis. RAST uses the operation of a specific equipment item containing a specific chemical or chemical mixture to define the activity. For example, the operation of a storage tank, a reactor, a piping network, etc. Inputs are chemical data, equipment design information, operating conditions, and plant layout.

Identify Chemical and Process Hazards or “inherent chemical or physical characteristics that have the potential for causing damage to people, property, or the environment”. RAST considers both Chemical and Operational related hazards. Chemical Hazards include flammability, toxicity, corrosivity, and reactivity (stored chemical energy). Operational Hazards include stored pressure-volume energy, high or low temperature (potential for thermal burns) and, to some extent, electrical conductivity (potential for static discharge). RAST contains administrative screening parameters (such as flash point for consideration of flammability hazard, ERPG-3 concentration for consideration of toxicity hazard, etc.) to aid in determining what hazards to consider,

RAST contains a data table of chemical properties (for 250 chemicals as of the date of this manual) that are used for quantifying hazards and in source models to determine leak rate. Users may enter properties for additional chemicals as needed in the HIRA study. There are several limitations relative to chemical properties, the most significant being that vapors are addressed as ideal gases and thermodynamic properties are correlated as simple linear relationship with temperature. Some source models for chemical processes operating near the critical point (critical temperature and critical pressure) will be less accurate than processes operating at or below the normal boiling point.

Each company has the ability to update the default screening parameters provided on hidden worksheets within RAST to utilize their specific criteria. CCPS does not endorse any specific criteria but provides initial values needed for the program to run and for the company to consider.

If hazard severity is considered reasonably low, then a HIRA study may not be required (in other words “screened out”), provided there is no regulatory or other requirement. In that case the RAST Hazard Summary Report may be used to document why the study team considers the hazard to be low.

Development of Scenarios involves “a detailed description of an unplanned event or incident sequence that results in a loss event and its associated impacts, including the success or failure of safeguards involved in the incident sequence”. In addition to Cause (or Initiating Event) and Consequence (or Incident Outcome), a RAST scenario contains one unique Loss Event. Details of the Loss Event help clarify the event sequence for the analysis team. In addition, the Loss Event is linked to a specific Source Term that allows RAST to perform a simple Consequence Analysis.

It should be noted that a RAST scenario contains only one Loss Event (Figure 1.3). If the overall event sequence contains more than one loss event, it is addressed as multiple RAST scenarios. For example: a spill of flammable liquid (first loss event) that ignites causing a pool fire that heats an adjacent vessel to the point of either ruptures or activates a relief device (second loss event) would be addressed as multiple RAST scenarios (the second loss event being a domino effect of the first). Each spill of flammable material which could ignite and create a pool fire impacting another vessel in the area would be addressed as separate scenarios. The heating from pool fire resulting in relief venting, rupture or damage would be addressed as an additional scenario. This is consistent with the Layer of Protection Analysis methodology.

Standardized lists of Initiating Events and Incident Outcome are also used to develop the scenario in RAST. Common parameter deviations for the type of equipment being analyzed is used to link some Loss Events with Initiating Events consistent with a Hazard and Operability Study (HAZOP) approach. RAST generates a list of suggested scenarios for consideration by the study team.

The suggested list of scenarios provided by RAST is not intended to represent all scenarios needed for an effective HIRA study, but a starting point that the evaluation team may build upon.




Figure 1.3 Scenario Development in RAST

RAST also considers operational limits to evaluate the feasibility of a scenario. For example, does the maximum system pressure exceed the design limits of the equipment or the relief device set pressure? Finally, RAST is “live” so that updates of Input information will automatically update the list of scenarios for consideration.

Consequence Analysis in RAST uses various source and effect models from CCPS and other literature sources. Loss events are categorized as related to hole size (vapor, liquid, or two-phase), material balance (such as overfill), heat balance (such as vaporization resulting from fire exposure), rupture (instantaneous release) or equipment damage. If the release is liquid or two-phase, vapor rate is estimated from simple flashing, aerosol evaporation and pool evaporation models.

A generic Event Tree (Figure 1.4) is used with RAST to determine Incident Outcome resulting from the Loss Event using criteria based on release location, release quantity and physical state, concentration at distance to the public, occupied buildings or on-site personnel location, in addition to process area congestion and other criteria. Administrative Incident Outcome criteria in RAST may be updated to reflect a company's standards on which a judgment or decision may be based. Parameter values provided in the RAST software are example criteria for the company to consider.




Figure 1.4 Generic Incident Outcome Event Tree used in RAST

RAST estimates a single “worst” Consequence Severity for each Incident Outcome.

There are three approaches that may be used to categorize consequence severity for *human harm* in RAST.

- **Simplified Quantitative Estimate of Human Harm:** This method involves the use of mathematical models to estimate the release rate, the subsequent dispersion, and toxic or blast effects. The models used in RAST are described in the Chemical Hazards Engineering Fundamentals (CHEF) manual available for download from CCPS. In addition to direct comparison with a company’s risk tolerance criteria, quantitative methods provide better consistency between different analysts.

It must be recognized that the results of real-world events have been both significantly less and significantly greater than those calculated. A set of assumptions such as weather conditions, wind direction, and release orientation are used to determine a “worst” consequence that may not represent real-world events.

- **Severity without Direct Reference to Human Harm:** This method is based on results of simple dispersion or explosion models such as a release where the distance to ERPG-2 concentration exceeds 1000 m or where the distance to 1 psi blast overpressure exceeds 500 m. Each Incident Outcome utilizes a different correlation with either a Hazard Distance or Concentration divided by a Level of Concern. Administrative parameters for relating consequence severity to dispersion and explosion model estimates may be updated to reflect a company’s specific criteria.

This approach avoids directly estimating the number of potential injuries or fatalities which may appear to imply that injuries or fatalities are tolerable. This approach also recognizes the difficulty in estimating the number of people who may be harmed and how severe the harm might be. For example, a toxic release may result in one or more fatalities or no harm at all, depending on the proximity of people to the release location and capability they have to escape.

- **Estimates of Consequence Severity other than provided by RAST:** RAST allows the User to enter a severity level as agreed upon by the study team rather than utilize the estimates provided.

Consequence severity for Environmental Damage is based on liquid release quantity to the ground or to waterways with a specific NFPA Health Hazard Rating (or GHS Hazard Classification) for Environmental Damage severity. (For example, 1000 kg material with GHS Hazard Classification of “toxic to aquatic life” or “toxic if swallowed”)

Consequence severity for Business Loss is based on User entered cost to repair damaged equipment plus cost of business interruption for Business Loss severity

Scenario Frequency in RAST is order-of-magnitude and based on independence of initiating events, enabling conditions/conditional modifiers and protective layers. Tables of initiating event frequencies, enabling condition or conditional modifier probabilities (such as probability of ignition), and probability of failure upon demand (PFD) for independent protective layers (IPL) are stored as administrative parameters. Residual failures (those leaks represented by chronic issues such as wear or fatigue rather than a process upset) are labeled Mechanical Integrity scenarios in RAST with frequency based on correlation on published leak frequency data. These tables and correlation coefficients may be updated to reflect a company’s specific frequency values for use in risk analysis. The scenario frequency is simply the product of the initiating event frequency times the enabling condition or conditional modifier probability times the failure probability for each IPL appropriate for the scenario.




Figure 1.5 Example RAST Risk Matrix for Consequence Severity times Frequency [1]

Risk Analysis within RAST involves converting the Consequence Severity and Scenario Frequency to graduated scales representing order-of-magnitude levels. The Risk Matrix (Figure 1.5) is used to summarize results with each cell in the matrix (at intersecting values of Consequence Severity and Scenario Frequency) representing a specific value of scenario risk. Tolerable Risk may also be summarized in the same tabular Risk Matrix and compared to scenario risk in determining if further risk reduction is needed. The values of tolerable frequency for the various Consequence Severity levels are administrative parameters that should be updated to reflect a specific company's risk tolerance criteria. The criteria for Human Harm in the risk matrix may also be related to Hazard Distance if a company desires to not use number of severe impacts or fatalities as the reference. The default parameters provided in RAST should be considered "examples" as CCPS does not endorse any specific risk criteria.

RAST also provides a graph of cumulative frequency versus consequence severity level as an indicator of societal risk. For human harm consequences, this graph is similar to an F-N Curve for making risk decisions.

A Layers of Protection Analysis (LOPA) workbook within RAST is used to summarize the risk associated with each scenario to be analyzed. Scenarios are selected from a list of potential scenarios for risk analysis by the analysis team. Scenarios of relatively low risk may be screened out from LOPA consideration based on a company's risk screening criteria which may be entered as administrative parameters. Those scenarios representing "worst cases" are noted (those requiring the greatest number of protective layers to meet a company's risk tolerance criteria) to aid the analysis team in selecting which scenarios to include in the analysis.

During LOPA, the study team adds additional cost effective IPLs until each scenario is at or below the tolerable risk criteria. Once approved by company leadership, these additional IPLs would be implemented and entered into the company's inspection, testing and maintenance programs to ensure that all safeguards are sustained for the life of the facility. RAST includes several reports to aid the study team in development

of a design basis for effective IPLs (such as estimation of the maximum allowable response time for a protective layer to function).

RAST Documentation

RAST maintains datasets of new chemicals, suggested scenarios, consequence analysis results, and layers of protection analysis results for each equipment item evaluated. These datasets are compatible with and may be imported into newer versions of the RAST software to effectively manage the data and documentation associated with the study. Future HIRA studies for the facility are easily updated by importing previous studies into the latest version of RAST, review and update of inputs, and generation of updated reports.

All chemical, equipment, process conditions and location inputs are stored within RAST by the equipment item or unit operation name. A User may select any equipment item within the HIRA study to review inputs or results, make appropriate changes or additions, and save the updated information. All information related to risk analysis for a specific scenario is stored within RAST by the scenario number. A User may select any scenario number to review scenario details and identified protection layers, make changes, and save the updated information. All reports and analysis results may be viewed by selecting either the equipment item or scenario number depending on the specific report desired.

RAST Training Materials

There are three related training manuals (and workshops available) for RAST.

Chemical Hazard Engineering Fundamentals (CHEF) is intended for newer engineers or as a refresher for experienced personnel. It describes methodology for performing a Hazard Identification and Risk Analysis (HIRA) study. There are many simplifying assumptions used that may not be suitable for every situation. A RAST User should be familiar with CHEF materials to recognize when a simplifying assumption may not be appropriate within a specific HIRA study.

Risk Analysis Screening Tool (RAST User) focuses on how to utilize the software in helping HIRA study teams to improve productivity, consistency, and quality of the studies. Various inputs and reports are described in detail with examples.

RAST Technical Administrator is intended to show experienced Process Safety personnel how to incorporate a company's specific risk matrix and other screening criteria into the RAST software. It is intended for those filling a RAST Technical Administrator role rather than a RAST User.

2. GETTING STARTED

RAST is a collection of process safety and risk analysis screening tools used to perform Hazard Identification and Risk Analysis (HIRA). A simple study example will be used to illustrate some of the features of the RAST tool. The example presented in this manual covers simple identification of hazards and evaluation of risk associated with a single equipment item handling a single Chemical. Information input and Analysis details for more complex situations will be covered in the *Additional RAST Inputs and Reports* section. The tool is based on a Microsoft Excel platform.

Opening the RAST Tool

Open the RAST spreadsheet. The first tab is an “Introduction” worksheet that contains notes pertaining to recent changes and other communication is the first tab in the workbook. Save this “blank” copy of the tool to the desktop then select “Go to Main Menu” in the top right corner or use the worksheet tabs at the bottom of the page to go to “Main Menu”. The Instructions worksheet can be selected with the “Go to Instructions” in the top right corner or using the worksheet tabs at the bottom of the page.

Main Menu

Equipment Identification, Equipment Type, and Location (Outdoors or Indoors) are entered on the Main Menu worksheet (Figure 2.1) On the Main Menu, one may also:

- Select the Source File for Input Information (prior LOPA or RAST workbook).
- Enter the Equipment Identification, Equipment Type and Location for analysis. (If updating a Previous Study, Equipment Identification, Equipment Type and Location is retrieved from the Equipment Table.)
- Access Workbook Notes for entering and viewing comments regarding the entire workbook and viewing selected parameters used in calculations (such as value of ambient temperature)
- Access Forms for Input Information such as Chemical Properties, Equipment Data, Operating Conditions, and Site or Facility Layout Information.
- Save all Input Information for the Equipment Identification selected
- Select the Evaluation or Report desired
- Update and Save Analysis Results for new or modified Equipment Items

Color Coding Guidance

Throughout the RAST workbook: “orange” colored cells represent the minimum required information while “yellow” colored cells represent other key information. In addition, “green” macro buttons at the top of each page are used for navigation to other worksheets, “black” for executing calculations, “red” to clear information, and “blue” for saving information.




Figure 2.1: Main Menu

An Example Study


As an example, to illustrate the RAST tool, consider a simple Hazard Evaluation and Risk Analysis for the storage tank containing acrylonitrile at 25 C (77 F) and 0.01 barg (0.2 psig) depicted in Figure 2.2:

Equipment Parameters

Tank Volume = 100 m³ (26000 gal)
Chemical = Acrylonitrile
Maximum Allowable Working Pressure = 0.2 bar (2.9 psig)
Flat Bottom Non-Anchored Tank
Bottom Outlet Nozzle = 100 mm (4 inch)
Circulating Pump = 7.5 kW (10 HP)

Operating Conditions

Operating Temperature = 25 C
Pressure = 0.01 bar (0.2 psig)
Liquid Head = 6 m (20 ft)
Feed Rate = 400 Kg/min (880 lb/min)



Acrylonitrile Reaction Data

Heat of Reaction: - 326 cal/gm
Activation Energy: 32 Kcal/gm mole
Detected Onset Temperature: 190 C
Detected Onset Rate: 0.08 C/min
Test Method: ARC with Phi Factor of 2.1




Figure 2.2: PFD for example (acrylonitrile storage tank)

Study Input Information

Let's begin by entering the minimum necessary Input Information to begin a new study.

STEP 1: In the Main Menu worksheet:

- Enter the Equipment Identification, V-101, select the Equipment Type, Vessel/Tank and Location, Outdoors from the drop-down lists.

Location is assumed Outdoors if input is blank. If updating a previous study, the Equipment Identification would be selected from the Equipment Table and displaced on the Study Menu form.

- Select Default Units as SI Units

If updating a previous study, DO NOT select Default Units as information has already been entered in previously defined units.

From the Main Menu, Select Chemical Data Input to enter Chemical information.

Chemical Information is entered on the Chemical Data worksheet (Figure 2.3). On this worksheet, one may:

- Select the Chemical (or Chemical Mixture) contained within the Equipment being analyzed.
- Access key Chemical Information from a Chemical Data Table.
- Estimate specific Chemical and Physical Properties at the Operating Temperature including the Physical State (vapor, liquid, or solid), Vapor Pressure, Vapor Composition, Liquid Density, Liquid Heat Capacity, and Heat of Vaporization. Other Chemical Information such as estimated mixture Boiling Point and Saturation Temperature (boiling point at the operating pressure) are also available.
- Enter additional Chemical Information not available or missing from the Chemical Data Table.

STEP 2: In the Chemical Data Input worksheet:

- Select the Chemical Name, Acrylonitrile, from the available list and Enter Weight Fraction Feed of 1.0.
- Enter the Operation Temperature of 25 C and Operating Pressure of 0.01 bar gauge (near atmospheric pressure).
- Select Go to Main Menu to continue with additional information input.

**Note that there are “orange” cells on the Chemical Data Input worksheet denoting minimum inputs. Once inputs are made in these cells, they are no longer “orange”. Also, on the Main Menu the “Minimum Complete” box has turned green for Chemical Data Input once all the minimum required inputs have been entered.*

[<< Go To Main Menu](#)

Chemical Data Input

[Go To Equipment Input >](#)

[Enter New Chemical](#)

[Save All Input to Equipment Table](#)

[Clear Input](#)

[Go To Process Conditions >](#)

[Go To Plant Layout >](#)

Equipment Identification:

Equipment Type:

Location:

Operating Temperature =

Operating Pressure (gauge) =

Saturation Temperature =

Physical State =

Key Chemical: Reference:

Chemical Comments:

Reg. Agency Considers Toxic?

Chemicals (the first chemical listed is the 'key' chemical)	Wt Fraction Feed	Second Liq Phase	Wt Fraction Vapor	Relative Volatility	Molecular Weight	ERPG-2 (ppm)	ERPG-3 (ppm)	LFL (vol %)
Acrylonitrile	1.000		1.000	1.0000	53.1	35	75	3.0
Sum =	1.00							

Vapor Mixture Properties:

Mixture azeotrope?

Standard Mixture (the key chemical has been defined as a mixture)	Wt Fraction Feed	Second Liq Phase

Model as a single Pseudo-Chemical?

Mixture Properties

Melting Point =

Flash Point =

Est Mixture Flash Point =

Not "Sustained Burning"?

Autoignition Temperature =

Ease of Ignition =

Fuel Reactivity =

Dermal Toxicity =

Aquatic Toxicity =

High Viscous Material (for F&E)?

Mixture NFPA Flammability =

Mixture NFPA Health =

Reactivity Category =

Mixture NFPA Reactivity =

Liquid Conductivity =

Dust Characteristics

Dust/Solids Hazard Class =

Solids Mean Particle Size =

Particle Size at 10% Fraction =

Dust Min Ignition Energy =

Dust-flammable hybrid?

Solids Bulk Density >160 g/liter (>10 lb/ft³)?

Summary of Chemical Properties

Estimated Boiling Point =	77.2	C
Vapor Pressure at Operating Temp =	0.138	atm
Liquid Density at Operating Temp =	0.80	gm/ml
Liq Heat Capacity at Op Temp =	0.50	cal/gm C
Liq Heat Capacity at Boiling Point =	0.52	
Heat of Vaporization at Op Temp =	152	cal/gm
Heat of Vaporization at Boiling Point =	140	
Boiling Point at Relief Set or MAWP =	82.8	C
Boiling Point at Burst Pressure =	85.3	C

From the above vapor composition: Estimated 1 hour LC₁ ppm Estimated 1 hour LC₅₀ ppm

Name	State	Mol Weight	ERPG-2 (ppm)	ERPG-3 (ppm)	LFL (vol %)	Flash Pt (C)
Pad Gas Properties	Vapor	29				
Heat Transfer Fluid						

[Show Chemical Details](#)

[Hide](#)

Select a chemical from the drop-down list.

Enter fraction by weight

Enter normal operating temperature and pressure.

Figure 2.3: Chemical Data Input

From the Main Menu, Select Equipment Parameter Input to enter Equipment Information.

Equipment Parameters are input on the Equipment Input worksheet (Figure 2.4). On this worksheet one may:

- Enter key Equipment Information such as Volume, Maximum Allowable Working Pressure, Pipe or Nozzle Diameter, Material of Construction, Surface Area and Elevation.
- Enter Design Information for specialized equipment such as Heat Transfer Area, Heating Media Temperature, Coolant Temperature, Pipe Length, Pump Seal Type, etc.
- Enter information regarding Design Issues such as Corrosion or Stress Cracking Potential, Susceptible to Vibration Fatigue, Piping Vulnerable to Physical Damage, Use of Conductive Dip Pipe or Bottom Fill, etc.
- Enter Relief Device design information such as Relief Set Pressure, Relief Size (diameter), Relief Type, Tail Pipe Diameter, and Discharge Elevation.

STEP 3: In the Equipment Input worksheet:

- Enter the Equipment Volume of 100 m³, Maximum Allowable Working Pressure (MAWP) of 0.2 bar gauge and Nozzle or Pipe Size of 100 mm. This represents the minimum input information
- Additional Equipment Parameters available that should be entered are Motor Power of 7.5 Kw for the circulating pump (which is a mechanical energy input to the tank). You may also enter an *Equipment Description* if desired.
- Select Go to Main Menu to continue with additional information input.

**Note that there are no longer “orange” cells on the Equipment Input worksheet denoting that minimum input requirements have been met. Also note that on the Main Menu the “Minimum Complete” box has turned green for Equipment Parameter Input.*

Equipment Input

[<< Go To Main Menu](#)
[< Go To Chemical Data](#)
[Save Input to Equipment Table](#)
[Clear Input](#)
[Go To Process Conditions Input >](#)
[Go To Plant Layout >](#)
[Go To Reaction Input >](#)

Equipment Identification: Equipment ID: V-101 Equipment Type: Vessel/Tank Location: Outdoors		Equipment Description _____	
Equipment Parameters		Piping Parameters	
Equipment Volume =	100 cu m	Pipe Length =	m
MAWP (gauge) =	0.2 bar	Piping Vulnerable to Damage?	
Full Vacuum Rated?		Apply Screwed Connection Penalty?	
Estimated High Temperature Failure =	C	Pump / Agitator Parameters	
Brittleness Temperature =	C		
Nozzle or Pipe Size =	100 mm	Pump Type =	
Number of Flanges or Nozzles =		Seal or Containment Type =	
Material of Construction		Remote Start Pump?	
Estimated Equip Mass based on C. Steel	3408 kg	Pump Automated Suction or Discharge?	
Equipment Mass =	kg		
Stress or Stress Cracking Potential?		Pump Volume (including piping to block valves), liter	Estimated 15.1
Exposure to Vibration Fatigue?		Pump Surface (including piping to block valves), m ²	0.69
Motor Power =	7.5 Kwatt		
Insulation			
Insulation Heat Reduction Factor =			
Tracing ?			
Estimated Equipment Max Wetted Area =	101 sq m		
User Equipment Max. Wetted Area =	sq m		
Equipment Elevation to Surface =	m		
Drain Valve Size	mm		
Vessel/Tank Parameters		Transportation Equipment or Piping Parameters	
Vessel/Tank Geometry?		Equipment or Piping Connection =	
Low Pressure Tank with Weak Seam Roof?			
Vessel/Tank Considered as "Storage"?			
Conductive Dip Pipe or Bottom Fill?			
Heat Transfer Parameters		Other Equipment Parameters	
Heating Transfer Area =	sq m	Replacement Cost & Business Loss	
Heating Overall U =	Kwatt/sq m C	Drum Oven Volume =	
Heating Fluid Temperature =	C	High Speed Rotating Equipment?	
Heat Transfer Fluid Pressure (gauge) =	bar	Bellows or Expansion Joint Used?	
Tube Failure Release to Atmosphere?		Sight Glass Used?	
Heat Transfer Fluid Name =			
Heat Transfer Fluid State =			
Quantity Hot Oil Handled (for F&E) =			
Tube (or Leak) Diameter =	mm		
Number of Tubes =			
Cooling Transfer Area =	sq m		
Cooling Overall U =	Kwatt/sq m C		
Coolant Temperature =	C		
		Relief Device Parameters	
		Relief Device Identification	
		Relief Type =	
		Relief Discharges to:	
		Relief Set Pressure (gauge) =	
		Relief Size (equiv. diameter) =	
		Relief Design Actual Flow Rate =	
		Release Pipe Diameter =	
		Release Elevation	
		Closest Distance From Relief to Elevated Work Area =	
		Furthest Distance from Relief to Elevated Work Area =	
		Elevation of Nearest Work Area =	
		<i>Enter Distances from Relief Location ONLY if Different from Equipment Location</i>	
		Relief Distance to Property Limit or Fence Line =	
		Relief Distance to Occupied Bldg 1 or Area =	
		Relief Distance to Center of Occ Bldg 1 =	
		Occ Bldg 2 in Same Wind Direction for Relief?	
		Relief Distance to Occupied Bldg 2 =	
		Relief Distance to Center of Occ Bldg 2 =	

Figure 2.4: Equipment Input Worksheet

From the Main Menu, Select Process Conditions Input to enter Process and Operating Conditions Information

Process and Operating Information is entered on the Process Conditions worksheet (Figure 2.5). On this worksheet, one may:

- Enter ambient temperature to be used in the analysis.
- Enter key process conditions such as the maximum fill or feed rate and the liquid head for equipment with low operating pressure.
- Enter additional feed information such as the total inventory, maximum feed pressure, and type of feed (continuous or batch).

- Enter information on use of Pad Gas such as Pad Gas Pressure, Maximum Pad Gas Flow Rate and if a Non-ignitable Atmosphere is Being Maintained in the equipment.

STEP 4: In the Process Conditions worksheet:

- Enter the Liquid Head within Equipment of 6 m and Maximum Feed or Flow Rate of 400 Kg/min. Ensure input units are correct. Note that *Liquid Head* is entered since it has a significant impact on the pressure drop available for leaks in this case. (The tank is operating at << 1 atmosphere gauge). Also note that leaving the *Total Inventory* blank implies an unlimited inventory available for overflow or leak scenarios.
- Select Go to Main Menu to continue with additional information input.

**Note that there are no longer "orange" cells on the Process Conditions worksheet denoting that minimum input requirements have been met. Also note that on the Main Menu the "Minimum Complete" box has turned green for Process Conditions Input.*

Process Conditions Input

Equipment Identification: Storage Tank
Equipment Type: Vessel/Tank
Location: Outdoors

Process Description

Process/Operating Conditions

Ambient Temperature = C
Inventory Limit (blank is unlimited) = kg
Liquid Head within Equipment, Δh = 6 m
Limiting Maximum Fill Fraction =
Limiting Minimum Fill Fraction =
Maximum Feed Press (gauge) = bar
Maximum Feed or Flow Rate = 400 Kg/min
Maximum Feed Temperature = C
Type of Feed (Batch or Continuous)
Non-Ignitable Atmosphere Maintained?
Potential for Aerosol or Mist?
Pad Gas Name =
Max Pad Gas Pressure (gauge) = bar
Maximum Pad Gas Rate = kg/min
Downstream Pressure (gauge) = bar
Maximum Back Flow Rate = kg/min
Equipment Vents to .. =

Summary for Acrylonitrile

Operating Temperature =	25	C
Operating Pressure (gauge) =	0.1	bar
Physical State =	Liquid	
Saturation Temperature =	80.2	C
Contained Mass =	63752	kg
Maximum Contained Mass =	79690	kg
Inventory for Reference =	103690	kg

Operating Procedures

Percent of Time in Operation =
Frequent Turnaround or Cleanout?
Centralized Ventilation Shut-Off Bldg 1?
Centralized Ventilation Shut-Off Bldg 2?

Review of Operating Procedures for
Selected Equipment Item by: Review Date:

Use Time-based Release for Equipment Rupture? sec

Figure 2.5: Process Conditions Worksheet

From the Main Menu, Select Plant Layout Input to enter Process and Operating Conditions Information Site and Plant Layout Information is entered on the Plant Layout worksheet (Figure 2.6). On this worksheet, one may:

- Enter key location information such as minimum Distance to Property Limit or Fence Line, Furthest Distance to Property Limit, Distance to Occupied Building and Number of Building Occupants. One may

also enter up to two offsite populated regions. If Equipment Location is "Indoors", key information includes the Enclosed Process Volume.

- Enter other location information such as: if Personnel are Routinely in the Immediate Area, Effective Egress from the Immediate Work Area, Degree of Equipment Congestion, Area of Containment Dike, Drainage to a Remote Location, and Distance from Fired Equipment.
- Enter the Number of Enclosed Area Personnel if the Equipment Location is Indoors.
- Enter Occupied Building Information including Name, Elevation of Ventilation Inlet, Ventilation Rate, and if there is Centralized Ventilation Shut-Off.

STEP 5: In the Plant Layout Input worksheet:

- Enter the Distance to Property Limit or Fence Line of 180 m, the Distance to Occupied Building or Enclosed Work Area of 70 m and Maximum Number of Building Occupants of 3. Note that if equipment Location is "Indoors", Enclosed Process Volume becomes a required input.

Select Go to Main Menu to Check Inputs, Save Inputs to the Equipment Table, or view Evaluations or Reports.

**Note that there are no longer "orange" cells on the Plant Layout worksheet denoting that minimum input requirements have been met. Also note that on the Main Menu the "Min Complete" box has turned green for Plant Layout Input.*

[<< Go To Main Menu](#)
[< Go To Chemical Data](#)
[< Go To Equipment Input](#)

Plant Layout Input
[Save Input to Equipment Table](#)

[Go To Reaction Input >](#)
[< Go To Process Conditions](#)

Equipment Identification: V-101
 Equipment Type: Vessel/Tank
 Location: Outdoors

Location Information

Distance to Property Limit or Fence Line =	180	m
Furthest Distance to Fence Line (> 180 m) =		m
Max. Onsite Outdoor Population Density		people/m ²
Personnel Routinely in Immediate Area?		
Distance to end of Offsite Zone 1		m
Offsite Population Density within Zone 1		people/m ²
Offsite Population Density Beyond Zone 1		people/m ²
Effective Egress from Work Area?		
<i>Access for Emergency Services?</i>		
Degree of Equipment Congestion in Area?		
Containment or Dike Surface Area =		sq m
Consider Dike or Bund Failure for Vessel Rupture?		
Credit Fire Heat Adsorption for Drainage/Indirect?		
Distance to Nearest Fired Equipment =		
Quantity of "Other" Flammables in Immediate Area		kg
Quantity of Flammables in Adjacent Area		kg
Adjacent Containment or Dike Surface Area =		sq m
<i>Automated EBVs to limit spill quantity?</i>		

Occupied Building Data

Occupied Building 1 Name =	
Distance to Occupied Bldg 1 or Area =	70 m
Elevation of Occ Bldg 1 Ventilation Inlet =	m
Distance to Center of Occupied Bldg 1 =	m
Occupied Bldg Type =	
Occupied Bldg Ventilation Rate =	changes/hr
Number of Building Occupants =	3
Occ Bldg 2 in Same Wind Direction?	
Occupied Building 2 Name =	
Distance to Occupied Bldg 2	m
Elevation of Occ Bldg 2 Ventilation Inlet =	m
Distance to Center of Occ Bldg2 =	m
Occupied Bldg 2 Type =	
Occupied Bldg 2 Ventilation Rate =	changes/hr
Number of Occupants Bldg 2 =	

Enclosed Process Area Data

Enclosed Process Volume =	cu m
Enclosed Process Ventilation =	changes/hr
No. Enclosed Area Personnel =	

Environmental Inputs

Spills to Soil Require Remediation?	
Potential for Water Contamination?	
High Population Downstream of Facility?	

Note that Environmental Scenarios are Excluded

Figure 2.6: Plant Layout Worksheet

From the Main Menu, Select Check Inputs (blue macro button).

Inputs are checked for missing information, missing units, or values outside of a normal range. Errors are categorized as Comment, Warning, or Critical. Critical errors must be addressed before proceeding with preliminary evaluations. Any default values used for missing input information are described as comments.

See Figure 2.7 for error message examples.

<< Go To Main Menu

Input Data Error Checking For v-101

Comments for input cells, click to link to cell with error

Error Message	Type
Equipment Data	
No Input for Maximum Allowable Working Pressure (MAWP)	Critical
No Input for Relief Device Set Pressure - No Relief Device Assumed	Comment
No Input for Relief Discharge Pipe Size	Comment
No Input for Relief Discharge Elevation	Comment
No Input for Relief Distance to Fenceline - Equipment Distance to Fenceline will be Used	Comment
No Input for Relief Distance to Occupied Building - Equipment Distance to Occupied Building will be Used	Comment
No Input for Relief Distance to Center of Occ Building - Equipment Distance to Center of Occ Building will be Used	Comment
No Input for Relief Distance to Occ Building 2 - Equipment Distance to Occ Building 2 will be Used	Comment
No Input for Relief Distance to Center of Occ Build 2 - Equipment Distance to Center of Occ Build 2 will be Used	Comment
No Input for Occ Build 2 in Same Wind Direction for Relief - Occ Build 2 in Same Wind Direction for Equipment will be Used	Comment
No Input for Vacuum Rated - Full Vacuum Capability is Assumed	Warning
No Input for Material of Construction	Warning
No Input for Feed through Dip Pipe or Bottom Fill - None Assumed	Comment
No Input for Number of Nozzles or Flanges - 2 above and below Liquid Level is Assumed	Comment
No Input for Drain Valve Size - 1/2 inch assumed	Comment
No Input for Screwed Piping - None is Assumed	Comment
No Input for Sight Glass - No Sight Glass is Assumed	Comment
No Replacement Cost including Business Loss Entered, \$50M to \$500M will be assumed	Comment
No Input for Equipment Surface - 5 times Volume ^{2/3} is Assumed	Warning
No Input for Insulation - No Insulation is Assumed	Warning
Site/Location Data	
Missing Inputs for Offsite Population Density and Distance. Default of 0.0015 people/sq m will be Used	Warning
No Input for Personnel Routinely in Immediate Area - Assumed as None	Warning
No Input for Effective Egress from Process Area - Potential Evasive Action Credit	Comment

Color coded errors.
Orange—Critical
Yellow—Warning

Figure 2.7: Error Messages from Check Inputs

Saving Input Information

From the Main Menu, or any of the Input worksheets (Equipment Input, Chemical Data, Process Conditions, Plant Layout, or Reaction Input), Select Save Inputs to Equipment Table (blue macro button). All Input Information will be stored in the Equipment Table in a single row identified by a unique Equipment Identification or Tag (Figure 2.8).

Copy of RAST for CCPS - Sept 18, 2017 - Excel

FILE HOME INSERT PAGE LAYOUT FORMULAS DATA REVIEW VIEW ADD-INS

Arial Narrow 10 A⁺ A⁻ B I U Wrap Text Merge & Center

General Conditional Formatting Table

Normal 2 Normal_Ne Good Neutral

View Summary F&EI and CEI information for entire workbook using Column Filter 1

< LOPA Menu Load Selected Update Scenarios for Equipment Loaded Update Scenarios for ALL Equipment Equipment Loaded v-101 Clear Equipment Table Go to Equipment Input > Go To Scenario Results >

To modify information, select a cell in row to be updated and hit "Load Selected" button

Equipment Identification											
Equipment Tag	Input Status	Equipment Description	Date Input Last Saved	Plant Section	P&ID Number	Equipment Type	Personnel Routinely in Immediate Area?	Elevation of Nearest Work Area	Elevation of Nearest Work Area Units	Distance to Nearest Work Area	Distance to Nearest Work Area Units
v-101			10/4/2017 10:35			Vessel/Tank		m		m	No

Retrieve Information for an Equipment Item by selecting any cell in the desired row and entering Load Selected

Figure 2.8: Example Equipment Table

Inputs for additional equipment items are stored in subsequent rows on the Equipment Table. To save time for creating inputs, information for a previously stored Equipment Identification or Tag may be retrieved, modified to reflect the desired new input and saved under another unique Equipment Identification or Tag. If Input information for a specific Equipment Tag already exists in the Equipment Table, a message will appear asking if the information is to be updated or overwritten (Figure 2.9).




Figure 2.9: Warning notice

Evaluations and Reports

Once the minimum required inputs have been entered, the user or analysis team may begin evaluations and identification of hazard scenarios. As more information is input, more thorough evaluation may be performed. In this way, a project team may begin with little initial information. Additional hazard scenarios are added for consideration as greater information is input. Selected evaluations and summaries associated with Screening Level Hazard Evaluation will be discussed in the next sections of Getting Started.

Preliminary Fire and Explosion Index

Even with limited information, the Dow Fire and Explosion Index (F&EI) or Chemical Exposure Index (CEI) may be estimated. These represent “Relative Ranking” indices which may be used by a company to screen when qualitative versus quantitative HIRA methods should be used. An example criterion for requiring a quantitative versus qualitative HIRA study might be an F&EI Index of 128 or higher.

The Fire and Explosion Index categorizes process hazard as shown in Table 1.1:

Table 1.1: Fire & Explosion Index Degree of Hazard

F&EI Range	Degree of Hazard
1 – 60	Light
61 – 96	Moderate
97 – 127	Intermediate
128 – 158	Heavy
159 and higher	Severe

Note that Preliminary F&EI from the RAST tool is based on a *single Equipment Item*. The Dow *Fire & Explosion Index Hazard Classification Guide* allows evaluation of larger “Process Units” (consisting of

multiple equipment items) within a single analysis. The Dow *F&EI Hazard Classification Guide* notes that risk will be overstated for Process Units handling less than 5000 lb. (2269 kg.)). Careful consideration should be given to Preliminary Results for equipment items handling small quantities. Also note that answers to several F&EI questions are evaluated based on available Input information which may not exactly match the question criteria. As a result, the Index and Radius of Exposure may be slightly different than attained with the DOW F&EI but is typically within 5 to 10% of the numerical value.

To view the preliminary Fire and Explosion Index, Select Fire & Explosion Index / Chemical Exposure Index from the *Study Menu* worksheet (Figure 2.10).

Reviewer and Review Date may be entered

<< Go To Main Menu
Clear Input This Worksheet

ESTIMATED FIRE & EXPLOSION INDEX

RAST Version 1.0 (Does not include Warehouse)

Prepared by: _____
 Reviewed by: _____

Date: _____
 Review Date: _____

PLANT DATA

Process Unit: Vessel/Tank; V-101

Key Chemical: Acrylonitrile

Fraction Key Chemical	1
Physical State	Liquid
Adjusted NFPA Flammability	3
Adjusted NFPA Reactivity	2
Quantity Handled, kg	63752.0

MATERIAL FACTOR (per Table 1 Criteria) 24

1. General Process Hazrds

Base Factor 1.00

A. Exothermic Chemical Reaction - 0.30 to 1.25

B. Endothermic Chemical Reaction - 0.20 to 0.40

C. Material Handling and Transfer 0.25 to 1.25

D. Enclosed or Indoor Process Unit 0.25 to 0.9

E. Access 0.20 to 0.35

F. Drainage and Spill Control 0.25 to 0.50

Dike Area = sq m

Penalty Factor Range	Penalty Factor Used
1.00	1.00
0.30 to 1.25	0.00
0.20 to 0.40	0.00
0.25 to 1.25	0.00
0.25 to 0.9	0.00
0.20 to 0.35	0.00
0.25 to 0.50	0.50

General Process Hazards Factor (F1) 1.50

2. Special Process Hazrds

Base Factor 1.00

A. Toxic Materials 0.20 to 0.80

B. Sub-Atmospheric Pressure (<500 mmHG) 0.50

C. Operation In or Near Flammable Range 0.30 to 0.80

Not Inerted
Always in Flammable Range

D. Dust Explosion 0.25 to 2.00

E. Pressure 0.00

Operating Pressure = 0.01 bar Relief Set Pressure = bar

F. Low Temperature 0.20 to 0.30

G. Quantity of Flammable/Unstable Material

Flammable or Reactive Quantity in Process: 0 kg 0.00

Flammable or Reactive Quantity in Storage: 103690 Kg 0.64

Combustable or Reactive Solids in Process or Storage: 0 kg 0.00

H. Corrosion or Erosion 0.10 to 0.75

I. Leakage - Joints and Packing 0.10 to 1.50

J. Use of Fired Equipment 0.00

K. Hot Oil Heat Exchange System - 0.15 to 1.15

L. Use of Rotating Equipment 0.50

Penalty Factor Range	Penalty Factor Used
1.00	1.00
0.20 to 0.80	0.80
0.50	0.00
0.30 to 0.80	0.80
0.25 to 2.00	0.00
0.00	0.00
0.20 to 0.30	0.00
0.00	0.00
0.00	0.00
0.00	0.00
0.00	0.00
0.00	0.00
0.00	0.00
0.00	0.00
0.00	0.00

Special Process Hazards Factor (F2) 3.24

Process Units Hazard Factor (F1 X F2 = F3) 4.87

Fire and Explosion Index (F3 X MF) 117

Radius of Exposure 30 m

For No Penalty Use 0.00

Material Factor based on Chemical Data Input

General Process Hazards based on Equipment Type, Location, Reaction Data and Plant Layout

Special Process Hazards based on Equipment Parameters and Process Conditions Inputs

Preliminary F&EI and Radius of Exposure

Figure 2.10: Fire & Explosion Index Preliminary Results

Preliminary Chemical Exposure Index

Chemical Exposure Index (CEI) may be estimated based on the ERPG-2 and ERPG-3 (Emergency Response Planning Guideline) concentrations from the Chemical Data worksheet. Calculation Units are selected as either SI or US/English based on the Input Units for Distance (meter or feet). Up to four standard cases are estimated:

Pipe or Nozzle Failure is based on the leak rate from hole size per the CEI guidance of:

- Diameter less than 2 inch (50 mm) – full bore failure
- Diameter between 2 and 4 inch (100 mm) – estimated as a 2 inch hole
- Diameter greater than 4 inch – estimated as a hole equivalent to 20% of cross-sectional area

Equipment Overfill or Overflow is based on a leak rate equivalent to the entered feed rate.

Release from Pressure Relief Device is based on an entered Design Capacity or estimated from the Relief Diameter and Set Pressure. (Results for this case are blank if Relief Device information has not been entered.)

Fire Exposure Vapor Venting is based on NFPA-30 estimates of fire heat input divided by the heat of vaporization. (Results for this case are blank if a fire potential is not feasible based on Chemical Data input and “Quantity of Other Flammables in Area” is zero or blank.)

The Chemical Exposure Index and related Hazard Distance to ERPG-2 concentration (HD-2) or Hazard Distance to ERPG-3 concentration (HD-3) are based on “ground” elevation releases lasting at least 5 minutes in duration. An example criterion for requiring a quantitative versus qualitative HIRA study might be a CEI Index of 200 or greater.

To view the preliminary Chemical Exposure Index, Select Fire & Explosion Index / Chemical Exposure Index from the *Main Menu* worksheet (Figure 2.11).

Reviewer and Review Date may be entered

Show F&EI and CEI Details

Hide F&EI and CEI Details

ESTIMATED CHEMICAL EXPOSURE INDEX

RAST Version 1.0

Prepared by:

Date:

Reviewed by:

Review Date:

PLANT DATA

Process Unit: Vessel/Tank; V-101

Key Chemical: Acrylonitrile

Fraction Key Chemical 1
Physical State Liquid
System Inventory, kg 63752
Contained Mass, kg 63752
Maximum Feedrate, kg/min 400
Containment Dike Area, sq m

CEI UNITS: SI Units

Selection of CEI Units based on User entered Distance Units (ft or m)

Summary of Chemical Properties from Chemical Data Input

EMERGENCY RESPONSE PLANNING

NFPA Health Rating 4
ERPG-2 (ppm) 35.0
ERPG-3 (ppm) 75.0

DISTANCES

Public, m 100
Nearest Occupied Building, m 20

Summary of entered Equipment and Location Input

PHYSICAL PROPERTIES

Operating Temperature, T, C 25
Operating Pressure, P (gauge), bar 0.01
Molecular Weight 53.1
Normal Boiling Point, C 77.2
Vapor Press at Operating Temp, kPa absolute 13.94
Liquid Density at Operating Temp, kg/cu m 796.90
Liquid Heat Capacity at Op Temp, kJ/km C 2.08
Heat of Vaporization at Operating Temp, kJ/km 635.5

EQUIPMENT INFORMATION

Equipment Volume, cu m 100
Ht of Liquid within Equipment, m 6
Equivalent Pipe or Nozzle Size (in) = 2
Equivalent Pipe or Nozzle Size (mm) = 50.8

CEI Calculation Results for most common cases

CEI CASE DATA - SUMMARY

Case Number

Scenario Description

Equivalent Hole Size, mm
Liquid Release Rate, kg/sec
Vapor Release Rate, kg/sec
Total Release Quantity in 15 minutes kg
Flashed Fraction
Overall Fraction Flashed+Droplet Evaporation
Airborne Rate from Flash+Droplet Evaporation, kg/sec
Pool Area, sq m
Estimated Pool Temperature, C
Pool Evaporation Rate, kg/sec
Total Airborne Rate, kg/sec

1	2	3	4
Pipe or Nozzle Failure	Overfill or Overflow	Relief Device Vapor to Atmosphere	Fire Exposure Vapor Relief to Atmosphere
50.80			
15.04	6.67		
			5.13
13540.0	6000.0		
0.000	0.000		
0.000	0.000		
0.00	0.00		
1699	753		
25.0	25.0		
2.62	1.21		
2.62	1.21		5.13

Include Pool Fire Exposure in CEI Summary?

1216	826	1702
831	564	1162
122	83	170

Estimated distance to ERPG-2 & ERPG-3 concentration based on simple CEI dispersion correlation

Chemical Exposure Index for most common cases

CHEMICAL EXPOSURE INDEX

Hazard Distance, HD-2, m

Hazard Distance, HD-3, m

CEI

Figure 2.11: Chemical Exposure Index Preliminary Results

Hazard Summary

A summary of Process Hazards is developed based on the input information is provided for “normal” and selected “upset” process conditions. Hazards associated with excessive pressure (potential for equipment rupture and/or relief device activation), chemical exposure (thermal and/or chemical burns, dermal toxicity), flammability (including pool fire potential), inhalation toxicity, and reactivity are included in this summary. If information beyond the minimum required is input, additional hazards are considered. The evaluation team should also consider any other hazards not identified in this summary.

Example Initial Hazard Screening Results are summarized as:

Flammable Hazard Sufficient for Further Consideration if:

- Flash Point less than a specified limit (such as 60 deg C) - *or*
- The maximum process temperature (under normal or upset conditions) is greater than the flash point less a specified limit (such as 5 deg C) - *or*
- The chemical is considered a combustible dust or dust-flammable liquid hybrid.

Toxicity Hazard Sufficient for Further Consideration if:

- ERPG-3 less than a specified limit (such as 1000 ppm by volume) - *or*
- Chemical is labeled as toxic in contact with skin, or toxic to the environment or considered by a regulatory agency to be toxic.

Reactivity Hazard Sufficient for Further Consideration if [3]:

- Heat of Reaction / Mass is more exothermic than specified limit (such as -50 J/gm) - *or*
- There is evidence of highly volatile or gaseous products generated - *or*
- There is evidence of a reaction with water or any other chemical which may be inadvertently added - *or*
- The chemical is considered a potential Condensed-Phase Detonable (explosive)

Hazardous Service Sufficient for Further Consideration if:

- The maximum process temperature (under normal, upset, or reaction conditions) is greater than a specified limit for thermal burns (such 60 deg C for liquids, or 100 deg C for vapors) or temperature is less than a low temperature limit (such as -20 deg C) - *or*
- The chemical handled is considered corrosive to human tissue - *or*
- The estimated maximum process pressure or vapor pressure (under normal, upset, or reaction conditions) exceeds the equipment Maximum Allowable Working Pressure or relief device set pressure.

Note that the Hazard Screening Criteria found on hidden worksheets may be changed to reflect a company's specific criteria. It is suggested that a company representative proficient in chemical process risk analysis (filling a RAST Technical Administrator role) be responsible for updating study parameters rather than RAST users or members of a specific study team. The default parameters provided in RAST should be considered “examples” as CCPS does not endorse any specific risk criteria.

Figure 2.12 (Chemical Information), Figure 2.13 (Equipment and Process Conditions), and Figure 2.14 (Reactivity and Fire Information) show the Hazard Summary for the Acrylonitrile example.

HAZARD SUMMARY		Date:
RAST Version 1.1		
Summary of Chemical Information		for Process Unit: Vessel/Tank; V-101
Physical State at Operating Conditions for Acrylonitrile = Liquid and Feed of:		
Weight Fraction Acrylonitrile	1	Hazard Screening <i>Note Chemical Information in Bold</i> Flammability Hazard Sufficient for Further Consideration Toxicity Hazard Sufficient for Further Consideration
Normal Boiling Point, C	77.2	
Flash Point, C	-5.0	
Lower Flammable Limit at Initial Composition, vol %	3.0	
Combustible Dust?	No	
ERPG-2 at Initial Composition, ppm	35.0	
ERPG-3 at Initial Composition, ppm	75.0	
Dermal Toxicity Classification (or Corrosive to Human Tissue)	Toxic	
Aquatic Toxicity Classification	Toxic	
Considered Toxic by a Regulatory Agency?	No	
Heat of Reaction, kJoule/kg		
Highly Volatile or Gaseous Products Generated?	No	
Potential for Mixing Incompatible Materials?	No	
Considered Condensed Phase Explosive?	No	

Properties for screening of Flammability, Toxicity and Reactivity hazards

Hazard Screening results

Figure 2.12. Hazard Summary Part 1 – Chemical Information

Summary of Equipment and Process Conditions		Temperature	Pressure	Pressure Exceeds Maximum Allowable Working or Relief Set Pressure?
Equipment or Vessel Volume 100 cu m		C	bar gauge	
Normal Operating Conditions		25	0.01	
Maximum Allowable Working or Relief Set Pressure		83.1	0.20	
Catastrophic Failure/Burst Pressure for Low Design Pressure		85.7	0.30	
Full Vacuum Rated? Not Entered				
Catastrophic Failure High Temperature		600.0		
Temperature where Low Temp Embrittlement may Occur? Not Entered				
Maximum Feed Pressure			Not Entered	
Maximum Gas Pad Pressure			Not Entered	
Maximum Downstream Equipment Pressure			Not Entered	
Maximum from Liquid Displacement (based on 9 X compression or feed pressure)			4.55	Yes
Estimated Maximum Headspace Deflagration Pressure			10.13	Yes
Maximum Pressure from Hydraulic Surge (Piping Only)				
Maximum Ambient Conditions		25	0.01	No
Maximum Feed Temperature				
Minimum Coolant Temperature				
Normal Boiling Point of Equipment Contents		77.2		
Maximum from Heating Media Temperature				
Estimated time to Relief Set Pressure or MAWP from Heat Transfer at Low Level, min				
Estimated time to Relief Set Pressure or MAWP from Heat Transfer at High Level, min				
Heating Media Source Pressure			0.00	No
Max from Mechanical Energy at Low Level: Non-Insulated		34.8	0.11	No
Estimated time to Relief Set or MAWP from Mechanical Energy at Low Level, min				
Max from Mechanical Energy at High Level: Non-Insulated		29.3	0.05	No
Estimated time to Relief Set or MAWP from Mechanical Energy at High Level, min				
Maximum Mechanical Energy Temperature may also exceed the Flash Point				
Maximum Temperature, C		34.8		No
Minimum Temperature, C		25		No

Summary of Normal and selected Upset Process Hazards

Figure 2.13: Hazard Summary Part 2 – Equipment and Process Conditions

Reaction Hazard Summary

Evaluation of Pool Fire Potential

Potential for Uncontrolled Reaction

Reaction Temperature of No Return is Greater than the Boiling Point at Relief Set Pressure or MAWP or non-Reactive

Exothermic Reaction Temperature of No Return

Maximum Reaction based on Adiabatic and Initial Temperature as Operating Temperature

Max Reaction Temp Exceeds High Temperature Failure?

No

Exothermic Reaction Temperature of No Return

Temperature, C	Pressure, barg
25.0	1.01

Relief Device may not be adequately sized for Uncontrolled Reaction

Potential for Pool Fire

The Flash Point is Less Than: 60 C, Ambient Temperature + 5 C, Operating Temperature + 5 C, Heating Media Temperature + 5 C, Max Mechanical Energy Temperature + 5 C

Quantity Flammable Available based on System Inventory

Maximum Pool Fire Duration based on Direct Fire

Fire Heat Input per API 2000 or NFPA 30 for Storage or Low Pressure Tank

Contents Reach Relief Conditions at Pool Fire Duration

Contents Reach Failure or Rupture Conditions at Pool Fire Duration

Yes

63752.0	kg
513.2	minutes
10222235.8	Kwatt

Relief Device may not be adequately sized for Pool Fire Exposure

Figure 2.14: Hazard Summary Part 3 – Reactivity and Fire Information

Consequence Summary

A summary of potential Consequences for a variety of Loss Events based on a single Equipment Item is provided in the Consequence Summary. The Loss Event is selected and estimation results for Airborne Quantity, Vapor Dispersion, Explosion, and Impact Assessment including *LOPA Tolerable Frequency Factor* and *Occupied Building Impacts* are displayed.

IMPORTANT: The Consequence Analysis in RAST is based on “steady state” rather than dynamic conditions at the chemical composition and flow rate entered on the Chemical Data and Process Conditions input worksheets. Several unit operations may require dynamic simulation to perform detailed hazard and risk evaluation rather than use of “average” composition or process conditions used by RAST. Units where composition changes over time or location within the equipment would be reactors or distillation columns. The liquid or vapor velocity within piping systems may also be time or location dependent. In these cases, the User needs to determine if RAST is capable of providing the accuracy and level of detail needed.

Loss Event Categories are aligned to specific discharge models including:

- Hole Size where release rate is determined by modeling the discharge from a hole of specified diameter, process pressure, and fluid density. A small hole (5 to 15 mm) may represent gasket failure or leaks from mechanical pump seals. A medium hole (25 mm) may represent significant equipment or piping leaks, while a large hole (100 mm to full bore) represents hose, pipe, or equipment nozzle failure.
- Overflow or Specified Rate where release rate is determined from the feed or other specified release rate.

- Excessive Heat where release rate is determined from the rate of heat input divided by the heat of vaporization.
- Equipment Rupture represents a sudden release of the entire contents and may apply to both energy and hazardous chemical releases.

Airborne Quantity for liquid releases involves estimation of liquid release rate, flash fraction, aerosol evaporation fraction, and evaporation from liquid pools.

Vapor Dispersion involves estimation of concentration and distance by jet mixing or atmospheric dispersion for continuous or instantaneous releases. The effects of buoyancy, momentum, elevation, and ventilation for indoor releases are also considered.

Explosions include Physical Explosion (equipment rupture), outdoor Vapor Cloud Explosion, and indoor Building (or confined space) Explosion. Hazard and damage level are related to blast overpressure with distance from the explosion epicenter.

Impact Assessment involves estimation of the number of people potentially impacted by various Incident Outcomes including Flash Fire, Vapor Cloud Explosion, Building Explosion, Physical Explosion, Toxic Release and Chemical Exposure. Impacts to personnel outdoors, within enclosed process areas, and within occupied buildings are considered. If the Study Parameter option to represent consequence severity is set as "Hazard Distance", the Impact Assessment, severity is estimated from Vapor Dispersion and Explosion estimates rather than number of people.

Figure 2.15 (Airborne Quantity Summary), Figure 2.16 (Dispersion & Explosion Summary), and Figure 2.17 (Impact Assessment Summary including LOPA Tolerable Frequency Factor) show the Consequence summary for the selected loss event in the Acrylonitrile example.

CONSEQUENCE SUMMARY

RAST Version 3

Date: 3/6/2020

Loss Event for: Vessel/Tank; V-101 Containing Acrylonitrile :

Gasket Failure

Select desired
Loss Event for
display here

Release Location

Outdoors

Prob of Exposure (proximity based)
with Personnel Not in Immediate Area

Airborne Quantity Summary:

Release Temperature, C
Release Pressure, barg
Physical State at Release Conditions
Heat Input, Kcal/min
Equivalent Hole Size, cm
Release Rate, Kg/sec
Release Duration, min
Total Release Quantity, kg
Spray Distance, m
Flash + Aerosol Evaporation Fraction
Estimated Aerosol Droplet Diameter, micron
Pool Area, sq m
Estimated Pool Temperature, C
Maximum Pool Evaporation Rate, kg/sec
Total Airborne Rate, kg/sec
Total Airborne Quantity, Kg

25.0
0.010
Liquid
1.000
0.45
60.00
5.8
0.003
1225
159.3
8.2
0.2457
0.24
447.6

Factor Probability

On-Site Toxic POE

--	--

Flash Fire POE

--	--

Chemical Exposure POE

--	--

Physical Explosion POE

--	--

Estimated
probabilities of
exposure and
suggested credit
factors

Airborne quantity
summary for selected
Loss Event

Airborne Quantity Composition:

Mole Fraction Acrylonitrile

1.000

Mole Fraction Pad Gas (at Mw = 29)

ERPG-2 for Vapor Composition, ppm by volume
ERPG-3 for Vapor Composition, ppm by volume
LC-50 Concentration, ppm by volume
One-hour ERPG-3 for Vapor Composition, ppm by volume
One-hour LC-1 Concentration, ppm by volume
LFL for Vapor Composition, % by volume

56.6
121.3
596.9
75.0
99.2
3.00

Ground or Work Area
Exceeds Multiple of
LFL or Time-Scaled
ERPG-3

Figure 2.15: Consequence Summary for Acrylonitrile example part 1 – Airborne Quantity Summary

CONSEQUENCE SUMMARY																										
<i>RAST Version 3</i>	<i>Date:</i>																									
Loss Event for: Vessel/Tank; V-101 Containing Acrylonitrile :	Gasket Failure																									
Dispersion Summary (Atmospheric Stability Class D with 3 m/sec wind except as noted): <table style="width: 100%; border-collapse: collapse;"> <tr><td>Max Distance to Time-Scaled ERPG-2, m</td><td style="text-align: center;">243.2</td></tr> <tr><td>Max Distance to Time-Scaled ERPG-3, m</td><td style="text-align: center;">165.5</td></tr> <tr><td>Max Distance to 1% Lethality for 1.5 F weather, m</td><td style="text-align: center;">339.4</td></tr> <tr><td>Max Distance to Estimated LC-50 Concentration, m</td><td style="text-align: center;">72.7</td></tr> <tr><td>Max Distance to Flash Fire Impact or 0.5 LFL, m</td><td style="text-align: center;">17.5</td></tr> <tr><td>Maximum Ground Elevation Concentration, ppm</td><td style="text-align: center;">1000000.0</td></tr> <tr><td>Concentration at Distance to Fence Line, ppm</td><td style="text-align: center;">324.4</td></tr> <tr><td>Concentration at Distance to Unrestricted Work Area, ppm</td><td style="text-align: center;">1000000.0</td></tr> <tr><td>Concentration within Occupied Bldg 1, ppm</td><td style="text-align: center;">2287.1</td></tr> <tr><td>Concentration within Occupied Bldg 2, ppm</td><td style="text-align: center;"></td></tr> <tr><td>Concentration within Enclosed Process Area, ppm</td><td style="text-align: center;"></td></tr> <tr><td>Conc within Enclosed Process Area w/Ventilation, ppm</td><td style="text-align: center;"></td></tr> </table> Potential Toxic Impact within Occupied Building (Indoor Conc > one-			Max Distance to Time-Scaled ERPG-2, m	243.2	Max Distance to Time-Scaled ERPG-3, m	165.5	Max Distance to 1% Lethality for 1.5 F weather, m	339.4	Max Distance to Estimated LC-50 Concentration, m	72.7	Max Distance to Flash Fire Impact or 0.5 LFL, m	17.5	Maximum Ground Elevation Concentration, ppm	1000000.0	Concentration at Distance to Fence Line, ppm	324.4	Concentration at Distance to Unrestricted Work Area, ppm	1000000.0	Concentration within Occupied Bldg 1, ppm	2287.1	Concentration within Occupied Bldg 2, ppm		Concentration within Enclosed Process Area, ppm		Conc within Enclosed Process Area w/Ventilation, ppm	
Max Distance to Time-Scaled ERPG-2, m	243.2																									
Max Distance to Time-Scaled ERPG-3, m	165.5																									
Max Distance to 1% Lethality for 1.5 F weather, m	339.4																									
Max Distance to Estimated LC-50 Concentration, m	72.7																									
Max Distance to Flash Fire Impact or 0.5 LFL, m	17.5																									
Maximum Ground Elevation Concentration, ppm	1000000.0																									
Concentration at Distance to Fence Line, ppm	324.4																									
Concentration at Distance to Unrestricted Work Area, ppm	1000000.0																									
Concentration within Occupied Bldg 1, ppm	2287.1																									
Concentration within Occupied Bldg 2, ppm																										
Concentration within Enclosed Process Area, ppm																										
Conc within Enclosed Process Area w/Ventilation, ppm																										
Explosion Summary: <table style="width: 100%; border-collapse: collapse;"> <tr><td>VCE or Building Explosion Energy, kcal</td><td style="text-align: center;"></td></tr> <tr><td>VCE or Building Explosion Distance to 1 psi Overpressure, m</td><td style="text-align: center;"></td></tr> <tr><td>Maximum Distance to LFL Concentration, m</td><td style="text-align: center;">10.9</td></tr> <tr><td>Blast Overpressure at Center of Occupied Building 1, psi</td><td style="text-align: center;">0.0</td></tr> <tr><td>Blast Overpressure at Center of Occupied Building 2, psi</td><td style="text-align: center;">0.0</td></tr> <tr><td>Distance to Severe Thermal Radiation Impact, m</td><td style="text-align: center;"></td></tr> <tr><td>Rupture Explosion Energy, kcal</td><td style="text-align: center;"></td></tr> <tr><td>Distance to Direct Blast Impact (10 psi), m</td><td style="text-align: center;"></td></tr> <tr><td>Maximum Fragment Range, m</td><td style="text-align: center;"></td></tr> <tr><td>Rupture Distance to 1 psi Overpressure, m</td><td style="text-align: center;"></td></tr> <tr><td>Rupture Overpressure at Center of Occupied Building 1, psi</td><td style="text-align: center;">0.0</td></tr> <tr><td>Rupture Overpressure at Center of Occupied Building 2, psi</td><td style="text-align: center;">0.0</td></tr> </table> Probability of Ignition (POI) 2 Probability of Explosion (POX) 2			VCE or Building Explosion Energy, kcal		VCE or Building Explosion Distance to 1 psi Overpressure, m		Maximum Distance to LFL Concentration, m	10.9	Blast Overpressure at Center of Occupied Building 1, psi	0.0	Blast Overpressure at Center of Occupied Building 2, psi	0.0	Distance to Severe Thermal Radiation Impact, m		Rupture Explosion Energy, kcal		Distance to Direct Blast Impact (10 psi), m		Maximum Fragment Range, m		Rupture Distance to 1 psi Overpressure, m		Rupture Overpressure at Center of Occupied Building 1, psi	0.0	Rupture Overpressure at Center of Occupied Building 2, psi	0.0
VCE or Building Explosion Energy, kcal																										
VCE or Building Explosion Distance to 1 psi Overpressure, m																										
Maximum Distance to LFL Concentration, m	10.9																									
Blast Overpressure at Center of Occupied Building 1, psi	0.0																									
Blast Overpressure at Center of Occupied Building 2, psi	0.0																									
Distance to Severe Thermal Radiation Impact, m																										
Rupture Explosion Energy, kcal																										
Distance to Direct Blast Impact (10 psi), m																										
Maximum Fragment Range, m																										
Rupture Distance to 1 psi Overpressure, m																										
Rupture Overpressure at Center of Occupied Building 1, psi	0.0																									
Rupture Overpressure at Center of Occupied Building 2, psi	0.0																									

Figure 2.16: Consequence Summary for Acrylonitrile example part 2 – Dispersion & Explosion Summary for Selected Loss Event

CONSEQUENCE SUMMARY <i>RAST Version 3</i>			Date:
Incident Outcome and Consequence Summary: Impact Assessment with Personnel routinely in the immediate area			Exceeds Threshold Criteria
Offsite Toxic Impact based on Toxic Integration Method and 100 m to Fence Line			Yes
Onsite Toxic Impact based on Distance to LC-50 Concentration of 73 m <i>Outdoor Toxic Exposure Duration 600 sec</i>			Yes
Onsite Flash Fire Impact based on Distance to 0.5 LFL Concentration of 17 m			4
Chemical Exposure based on Dermal or Thermal Hazards and Spray Distance of 6 m			3
Equipment Rupture Direct Blast Impact based on Distance to 10 psi			
Onsite Thermal Radiation Impact based on Distance from Fireball <i>Number of Potential Serious Toxic Impacts Onsite: 1.4 people</i> <i>Number of Potential Serious Flash Fire/Fireball Impacts Onsite: 0.9 people</i>			
Occupied Building Toxic Impact <i>Number of Potential Serious Impacts for Building 1: 3 people</i> <i>Number of Potential Serious Impacts for Building 2: 0 people</i>			Yes
Occupied Building Impact from Vapor Cloud Explosion <i>Number of Potential Serious Impacts for Building 1: 0 people</i> <i>Number of Potential Serious Impacts for Building 2: 0 people</i>			No
Occupied Building Physical Explosion Impact <i>Number of Potential Serious Impacts for Building 1: 0 people</i> <i>Number of Potential Serious Impacts for Building 2: 0 people</i>			No
Environmental Impact:			NA

Figure 2.17: Consequence Summary for Acrylonitrile example part 3 – Impact Assessment Summary for Selected Loss Event including LOPA Tolerable Frequency Factor for Selected Loss Event

Scenario Identification

A library of scenarios has been developed from operational experience, incident history, and historical risk analysis studies. The scenario library in RAST is based on considering the entered Equipment Item as a study “node” for which common parameters and deviations are identified – a technique used in Hazard and Operability Studies (HAZOP). For simplified Process Risk Analysis, parameter deviations are primarily focused on those which could lead to an unintended release of hazardous material or energy (a Loss Event) impacting people or the environment. Few cases involving only Equipment Damage or Business Loss have been included.

Scenarios considered in the library not meeting a “screening” criterion are shown in gray and not included on the Scenario Results worksheet. (Note that the screening criterion may be updated by the RAST Technical Administrator on hidden worksheets.) The Scenario Identification list is intended to assist the Hazard Evaluation or Risk Analysis study team identify *what could go wrong* in the operation of the equipment item. This list is interactive: adding or modifying input information will update the list. If this worksheet is accessed directly by the worksheet tabs then the “Update” command should be used to ensure the information is current. Figure 2.18 shows the Suggested Scenario screen for some selected scenarios.

Update command if accessed directly by worksheet tab Update

Scenario type with comments or descriptions

Design Intent Statement to be updated by the Evaluation Team

Estimated Consequence Severity for each Outcome expressed as Tolerable Frequency Factor

Fields to capture Existing Safeguards, Team Recommendations, and Need for Further Analysis

<< Go To Main Menu

Update List

Create User Scenario

Suggested Scenarios from the RAST Library

Evaluation Node:
Plant Section =
Equipment Type = Vessel/Tank
Equipment Tag = V-101

Node Design Intent Summary:
V-101 is a Vessel/Tank containing Acrylonitrile that operates at 25 C and 0.01 bar. The volume is 100 cu m with a maximum allowable working pressure of 0.19 bar. The maximum feed or flow rate is 400 kg/min.

Session Date: Session Participants:

Go To Scenario Results >

Update Input this worksheet

Clear Input this Worksheet

Save Input to Equipment Table

LOPA Menu Filters:

Scenario Type	Scenario Comments	Parameters and Deviation	Initiating Event (Cause)	Initiating Event Description	Loss Event	Outcome	Off-Site Toxic Release	On-Site Toxic Release	Isobar Toxic Release	Toxic Infiltration	Chemical Exposure	Flash Fire or Fireball	Vapor Cloud Explosion	Building Explosion	Equipment Explosion	Property Damage or Business Interruption	Environmental Damage	Existing Safeguards	Recommendations	Further Analysis
Drain or Vent Valve Open	Drain or Vent Valve left open following infrequent maintenance, purging or cleaning	Flow/Loss of Containment	Human Failure Action once per quarter or less	Operator leaves Drain or Vent Open following infrequent maintenance	Drain or Vent Leak	Off-Site Toxic Release, On-Site Toxic Release, Toxic Infiltration, Chemical Exposure, Flash Fire or Fireball	4	5		5	3	4						Procedure requires blank or plug on all terminal valves to the atmosphere. Procedure requires a "walk through" inspection of terminal valves before restart of process.		Yes
Excessive Heat Input - Pool Fire Exposure	Vapor Pressure exceeds Relief Set or Burst Pressure from Pool Fire Exposure	Pressure-High	IEF=3 pending more detailed evaluation	Leak of Flammable Material or Material above its Flash Point which may ignite	Vapor Relief Vent - Fire Equipment Rupture at Fire Conditions	Off-Site Toxic Release, On-Site Toxic Release, Toxic Infiltration, Flash Fire or Fireball, Vapor Cloud Explosion Off-Site Toxic Release, On-Site Toxic Release, Toxic Infiltration, Chemical Exposure, Flash Fire or Fireball, Equipment Explosion	6	6	6		5	5						Water deluge system in place which covers the AN storage tank. Check relief sizing and effluent for venting to a "safe" location		Yes
Ignitable Headspace	Chemical is Flammable or Combustible; Maximum Operating Mechanical Energy or Heating Media Temperature exceeds Flash Point less 5 C	Composition-Wrong Concentration	BPCS Instrument Loop Failure	Failure of Pressure or NonCombustible Atmosphere Control	Equipment Rupture - Deflagration	Off-Site Toxic Release, On-Site Toxic Release, Toxic Infiltration, Chemical Exposure, Flash Fire or Fireball, Equipment Explosion	4	5		5	3	5			4			Tank is maintained under an inert atmosphere.		Yes
Overfill or Overflow	Overfill or Backflow of liquid with spill rate equal to the feed rate to a maximum quantity of the available inventory minus contained mass	Level-High	BPCS Instrument Loop Failure Human Failure Action more than once per quarter	Failure of Level Indication with continued addition of material Operator opens wrong valve or initiates filling when equipment is not empty	Overfill Release	Off-Site Toxic Release, On-Site Toxic Release, Toxic Infiltration, Chemical Exposure, Flash Fire or Fireball Off-Site Toxic Release, On-Site Toxic Release, Toxic Infiltration, Chemical Exposure, Flash Fire or Fireball	5	5		5	3	4						Operator present during tank truck unloading. Potential for offsite toxic impacts. Continue with more detailed evaluation		Yes
Vacuum Damage	Vacuum Damage of Process Equipment	Pressure-Low	BPCS Instrument Loop Failure	Failure of Pressure Control	Full Bore Hole Size Leak above Liquid Level	On-Site Toxic Release		4										Tank equipment with vacuum breaker		No
Excessive Heat Input - Heat Transfer	No Heating Media Temperature was noted	Pressure-High	BPCS Instrument Loop Failure	Failure of Flow Control	Criteria for Triggering Incidents Not Met															Yes
Excessive Heat Input - Mechanical	Vapor Pressure plus pad gas Does Not exceed Maximum Allowable Working Pressure or Relief Set Pressure at Maximum Temperature from Mechanical Energy Input	Pressure-High	Human Failure Action once per quarter or less	Agitation or Pump Recirculation left running for extended time allowing slow temperature increase	Criteria for Triggering Incidents Not Met															Yes
High Temperature Failure	Maximum Feed Temperature Does Not Exceed Temperature limits of Equipment	Temperature-High	BPCS Instrument Loop Failure	Failure of Temperature Control	Criteria for Triggering Incidents Not Met															
Uncontrolled Reaction - Adiabatic	the Operating Temperature, Heating Media Temperature, or Maximum Mechanical Energy Temperature is below the Temperature of No Return or Maximum Reaction Pressure Does Not exceed the equipment Maximum Allowable Working Pressure or Relief Set Pressure. Scenario may represent a product quality issue.	Reaction-High Rate	BPCS Instrument Loop Failure	Loss of Cooling results in Uncontrolled Exothermic Reaction	Criteria for Triggering Incidents Not Met															
Uncontrolled Reaction - Fire Induced	Maximum Temperature at Relief Set Pressure is less than the Temperature of No Return or Fire Duration Not Sufficient to Reach Reaction Conditions	Reaction-High Rate	IEF=3 pending more detailed evaluation	Leak of Flammable Material or Material above its Flash Point which may ignite	Criteria for Triggering Incidents Not Met															
Uncontrolled Reaction - Thermal Initiation	Heat of Reaction Low with little or no Gas Generation. Scenario may represent a product quality issue.	Reaction-High Rate	BPCS Instrument Loop Failure	Loss of Temperature Control with Maximum Heating Media or Ambient Temperature exceeding the Temperature of No Return	Criteria for Triggering Incidents Not Met															

Figure 2.18: Portion of suggested Scenarios of Acrylonitrile example

Example Impact of Changes in Parameter Inputs

To demonstrate the impact of a Parameter Input change:

Select Scenario Identification from the Main Menu and view the Scenario List.

Return to the Main Menu and Select Equipment Parameter Input. Enter the input for Insulation? as “Yes”

Again, Select Scenario Identification from Main Menu.

Notice that a new scenario has been added (Figure 2.19):

Scenario Type	Scenario Comments	Parameters and Deviation	Initiating Event (Cause)	Initiating Event Description	Loss Event	Outcome													Existing Safeguards	Recommendations	Further Analysis
Drain or Vent Valve Open	Drain or Vent Valve left open following infrequent maintenance, purging or cleaning	Flow-Loss of Containment	Human Failure Action once per quarter or less	Operator leaves Drain or Vent Open following infrequent maintenance	Drain or Vent Leak	Off-Site Toxic Release, On-Site Toxic Release, Toxic Infiltration, Chemical Exposure, Flash Fire or Fireball	4	5		5	3	4							Procedure require blank or plug on all terminal valves to the atmosphere. Procedure requires a "walk through" inspection of terminal valves before restart of proces.		Yes
Excessive Heat Input - Mechanical	Vapor Pressure plus pad gas exceeds Maximum Allowable Working Pressure or Relief Set Pressure at Maximum Temperature from Mechanical Energy input	Pressure-High	Human Failure Action once per quarter or less	Agitation or Pump Recirculation left running for extended time allowing slow temperature increase	Vapor Relief Vent - Mechanical Energy	On-Site Toxic Release		2													
					Equipment Rupture at Saturation Temperature	Off-Site Toxic Release, On-Site Toxic Release, Toxic Infiltration, Chemical Exposure, Flash Fire or Fireball, Vapor Cloud Explosion, Equipment Explosion	6	6		5	4	5	6		4						

Figure 2.19: New Scenario Added due to Adding Insulation

If the vessel is well insulated, then the small quantity of heat from the circulation may be able to slowly raise the maximum temperature to the point where vapor pressure of acrylonitrile exceeds the design limits of the equipment.

As another example:

Select Process Conditions Input from the Main Menu.

Enter for Downstream Pressure (gauge) = a value of 0.5 bar to reflect the head of fluid downstream.

Return to the Main Menu and again select Scenario Identification.

Notice that the Overfill Scenario has been modified (Figure 2.20):

Scenario Type	Scenario Comments	Parameters and Deviation	Initiating Event (Cause)	Initiating Event Description	Loss Event	Outcome													Existing Safeguards	Recommendations	Further Analysis
Overfill or Backflow	Overfill or Backflow of liquid with spill rate equal to the feed rate to a maximum quantity of the available inventory minus contained mass	Flow-Backflow	Pump (blower, compressor, etc.) Failure	Pump Failure causing backflow	Backflow Release	Consequence Does Not Exceed Threshold Criteria for Continuing with LOPA															
					Equipment Rupture at Operating Temperature	Off-Site Toxic Release, On-Site Toxic Release, Toxic Infiltration, Chemical Exposure, Flash Fire or Fireball, Vapor Cloud Explosion	6	6		6	3	5	5								
Overfill or Overflow	Overfill or Backflow of liquid with spill rate equal to the feed rate to a maximum quantity of the available inventory minus contained mass	Level-High	BPCS Instrument Loop Failure	Failure of Level Indication with continued addition of material	Overfill Release	Off-Site Toxic Release, On-Site Toxic Release, Toxic Infiltration, Chemical Exposure, Flash Fire or Fireball	6	5		5	3	4							Operator present during tank truck unloading.	Potential for offsite toxic impacts. Continue with more detailed evaluation	Yes
			Human Failure Action more than once per quarter	Operator opens wrong valve or initiates filling when equipment is not empty		Off-Site Toxic Release, On-Site Toxic Release, Toxic Infiltration, Chemical Exposure, Flash Fire or Fireball	6	5		5	3	4									

Figure 2.20: Scenario Modification due to Adding Downstream Pressure

A second Loss Event has been added to reflect backflow as a means by which Overfill may occur. Also notice that additional Initiating Events may be added. Note that the backflow rate may also need to be entered for evaluation of Consequence. (The Outcome comments note that the Consequence Does Not Exceed Threshold Criteria for Continuing in LOPA".)

Saving Preliminary Analysis Results

From the Main Menu, Select Go to Equipment Table, select the cell containing V-101, and Select Load Selected. This will remove the changes in Insulation and Downstream Pressure inputs and return to the Main Menu. Select Update Scenarios for Equipment Loaded (black macro button). Results of the Preliminary Analysis *for all scenarios selected for further analysis on the Scenario List worksheet* will be stored on the Scenario Results worksheet in a single row identified by a unique Scenario Number. Results contain information regarding the type of equipment, scenario category, initiating event, loss event, incident outcome, consequence, a summary of release quantities and summary of hazard distance estimates.

The Scenario Results worksheet may be accessed from the LOPA Menu.

There is no “calculation” per se, but a capture of scenario information at a point in time based on the team Input information available. If Inputs are changed and Update Scenarios for Equipment Loaded is initiated at a later time, estimates are compared to the previous values for each existing Scenario. When estimates do not match the previous estimate, the cell containing the changed results turns “green” and the prior values are stored in the cell comments. This allows the user to determine the impact of changes in the Input information.

An example of the Scenario Results worksheet is located in Figure 2.21

3. CHEMICAL DATA

The chemical and physical properties of materials handled are fundamental in Hazard Evaluation and Risk Analysis. RAST contains a small chemical database and allows modification or creation of key chemical parameters for single components and mixtures.

This section contains:

- The simple correlations used for common chemical properties as a function of temperature.
- How to enter chemical properties for a new chemical.
- How to create a mixture from listed chemicals.
- How vapor composition is estimated in RAST from liquid composition assuming an “ideal” mixture.

Chemical Property Correlations in RAST

Chemical Properties are needed at several temperatures to perform screening calculations. The following are simple correlations of key chemical properties used in RAST that require only two data points at different temperatures in the region of interest.

Vapor Pressure: $\ln(P^{\text{sat}}) = a - b / (T - c)$. The “c” constant is 0 if only two data points are used with T in deg K

Liquid Density: $\rho = a - b T$

Liquid Heat Capacity: $C_s = a + b T$

Heat of Vaporization: $\lambda = a - b T - c T^2$. The “c” constant is zero if only two data points are used.

Vapor density may be estimated as an ideal gas by:

$\rho_v = 0.12 P M_w / T$ where P is pressure in kPa and T in deg K

Note that values of the coefficients in these correlations are typically positive numbers as the “sign” is part of the correlating equation.

The simple property correlations in RAST do not include an equation of state (vapor is estimated as an ideal gas). This limitation will result in less accuracy for equipment operating with liquid at elevated temperature and pressure (such as a liquefied gas operating near the critical temperature of the material). In some cases, it may be necessary to utilize more advanced software in estimation of thermodynamic properties for determination of material or energy release rate near the critical point.

Entering New Chemical Properties

A fairly comprehensive list of chemical properties is available within the RAST Chemical Data Table. However, if a chemical is not listed or the User wants to modify the available data, the Enter New Chemical option must be used. Note that to create a chemical mixture, the properties for each component must be available from the Chemical Table listing (Figure 3.1).

Chemical Data Input

<< Go To Main Menu Enter New Chemical Save All Input to Equipment Table Clear Input Go To Equipment Input > Go To Process Conditions > Go To Plant Layout >

Enter New Chemical (Callout) Equipment Identification: V-101
 Equipment Type: Vessel/Tank
 Location: Outdoors

Key Chemical: Acrylonitrile Reference:

Operating Temperature =	25	C
Operating Pressure (gauge) =	0.01	bar
Saturation Temperature =	77.5	C
Physical State =	Liquid	

Figure 3.1: Entering a New Chemical

From the Chemical Data worksheet, select Enter New Chemical. One may begin with properties from an existing chemical by selecting a Chemical Name under the column “Starting chemical that is similar” or merely enter values under the column “User Supplied Values”. Note that if any chemical property is updated by the user, then the chemical needs to be saved using a different Chemical Name to be available on the chemical listing.

Select Save Data to Chemical Table to save information as a “user” chemical for use within the current RAST file. All “user” chemicals will be included in new RAST files that are “imported” from this file. Contact a RAST administrator for addition, update, or deletion of chemical information in the globally available list within the RAST tool.

Example Entry of New Chemical Properties

As an example, data for t-butyl amine (CAS 75-64-9) is entered as a new chemical. The input information may come from a variety of sources, including various Physical Property Databases, Vendor NFPA Ratings, American Industrial Association ERPG values (or US Department of Transportation Protective Action Criteria), Material Safety Datasheets, or other literature references.

STEP 1: Enter initial data.

Molecular Weight: 73.14

Melting Point: -86.7 deg C

Boiling Point: 44.4 deg C

Select two temperatures to correlate vapor pressure, liquid density, liquid heat capacity and heat of vaporization. These temperatures should be selected to represent the region of interest (including operating temperature, ambient temperature, boiling point, etc.) and fall between the melting point to less than 0.8 of the critical temperature (if known) or roughly 1.2 times the boiling point in deg K. (*In this example, the critical temperature is listed as 211 deg C or 484 deg K such that 0.8 of the critical temperature is 387 deg K or 114 deg C.*) Temperatures of 0 deg C and 100 deg C are selected. Liquid properties values at “saturation” (pressure equals vapor pressure) are typically used.

STEP 2: Enter chemical property data at the two selected temperatures. Use data from external sources (Figure 3.2).

Property	Units	Point 1	Point 2
Temperature, 1 and 2	C	0	100
Vapor Pressure (absolute)	kPa	16.3	517.1
Liquid Density	Kg/cu m	711	607
Liquid Heat Capacity	J/gm C	2.58	2.73
Heat of Vaporization	J/gm	413	323

Figure 3.2: Chemical Properties from External Sources

STEP 3: Enter remaining available chemical data from the supplier Material Safety Data Sheet (MSDS), ERPG Database, and other sources into the center (white) column.

Flash Point: -8 deg C
 Lower Flammable Limit: 1.7 volume %
 Upper Flammable Limit: 8.9 volume %
 Autoignition Temperature: 380 deg C
 ERPG-2: 0.38 ppm
 ERPG-3: 56 ppm
 NFPA-Health Rating: 3
 NFPA-Flammability Rating: 3
 NFPA-Stability Rating: 0

STEP 4: Enter Ease of Ignition category if there is sufficient information to indicate this hazard characteristic is outside of the default category of "Normal". Categories are Low, Normal, Elevated, and High Ignition based on heat of oxidation, Minimum Ignition Energy, Auto-Ignition Temperature, Fundamental Burning Velocity, and other rating systems such as Maximum Experimental Safe Gap. These categories are described in a report titled "Assessing Probability of Ignition (POI) of Gases and Vapors with Deflagration Potential", Larry G. Britton, Neolytica Inc, March 10th, 2005. Examples of materials in the different Ignition Probability categories:

- **Low:** ammonia, methylene chloride, and trichloroethylene
- **Normal:** n-butane, propylene, acetone, methane, and methanol
- **Elevated:** hydrogen, acetylene, ethylene oxide, propylene oxide, carbon disulfide, and ethylene
- **High:** silane and various alkyl aluminum compounds (normally described as pyrophoric)

STEP 5: Enter Fuel Reactivity category if there is sufficient information to indicate this hazard characteristic is outside of the default category of "Medium". Categories are Low, Medium, and High based on Fundamental Burning Velocity of less than 45 cm/sec, between 45 and 75 cm/sec and greater than 75 cm/sec respectively.

STEP 6: Enter Conductivity category if there is sufficient information to indicate this hazard characteristic is outside of the default category of "Semi-Conductive". Categories are Non-Conductive, Semi-Conductive, and Conductive based on liquid electrical conductivity of less than 100 pico-siemen/meter (pS/m), between 100 and 10000 pS/m and greater than 10000 pS/m respectively.

STEP 7: Enter Dermal and Aquatic Toxicity category if there is sufficient information to indicate a toxicity hazard based on (United Nations) Globally Harmonized System or European Dangerous Substances Directive categories.

STEP 8: Enter Dust Hazard Classification if the material is a solid and there is sufficient information to indicate dust flammability hazard. Often this information is specific to the equipment in which the dust is handled and, therefore, not saved to the Chemical Table. In those cases, the dust classification information is entered and saved to the Equipment Table from the Chemical Data or Main Menu.

Refer to Figure 3.3 for the User Chemical Data Input screen.

The screenshot shows the 'User Chemical Data Input' screen. At the top, there are buttons: '< Go To Chemical Data', 'Clear Chemical Data Inputs', 'User Chemical Data Input', and 'Save Chemical Data to Chemical Table'. Below these is a 'Go To Chemical Table to Delete User Chemicals' button.

The main data entry area is a table with four columns: 'Existing Chemical That is Similar', 'User Supplied Values', and 'Properties of User Chemical to be Saved'. The rows include fields for Chemical Name, CAS Number, Data Source, Mol Weight, Melting Point, Boil Point, Vapor Pressure (A, B, C), Density (A, B), Liquid Capacity (A, B), Latent Heat (A, B, C), Flash Point, LFL, and various toxicity and hazard parameters like Dust Min Ignition Energy, ERPG-2, ERPG-3, NFPA Health, NFPA Flammability, NFPA Reactivity, Dermal Toxicity, Aquatic Toxicity, and Reactivity Category.

Annotations on the screen include:

- 'Start with an Existing Chemical to modify data or Enter from 'scratch'' pointing to the 'Existing Chemical That is Similar' column.
- 'Save Data to Chemical Data when Complete. Must use a 'new' Chemical Name' pointing to the 'Save Chemical Data to Chemical Table' button.
- 'Calculate Physical Property Constants from Data Points' pointing to a sub-table with properties like Temperature, Vapor Pressure, Liquid Density, Liquid Heat Capacity, and Heat of Vaporization.
- 'Estimated Boiling Point, C = ' pointing to a text input field.
- 'Enter Chemical Property Data at two temperatures.' pointing to the 'Point 1' and 'Point 2' columns in the sub-table.
- 'Normal Boiling Point is estimated from correlations based on entered data' pointing to the 'Boil Point, TB (C)' field.
- 'Dust Data applies ONLY to solids' pointing to the 'Dust Min Ignition Energy (mJ)' field.
- 'Orange denotes minimum required information' pointing to orange-shaded cells in the 'User Supplied Values' column.
- 'User values will override those of starting chemical' pointing to the 'User Supplied Values' column.

Figure 3.3: New Chemical Data Input

STEP 9: Enter the Chemical Name under “Properties of New Chemical to be saved” and select Save Chemical Data to Chemical Table.

If a Chemical Name is selected that has already been used in the Chemical Table, a dialog box appears as a reminder that the data will not be saved under the selected name. Merely enter “OK” and select another Chemical Name. See Figure 3.4.




Figure 3.4: Error if choose already existing name

If a User specified Chemical Name is selected that already exists in the Chemical Table, a dialog box appears. If merely updating data for a User specified Chemical, enter “OK”. See Figure 3.5.




Figure 3.5: Dialog box to confirm overwriting chemical data

Since Reaction Data may be saved to the Chemical Table for User specified Chemicals, a reminder that reaction information must be entered and saved from the Reaction Input worksheet appears, enter “OK”. See Figure 3.6.




Figure 3.6: Reminder to enter Reaction Data

Chemical Mixtures

Where it is necessary to consider mixtures, simple methods based on selection of one component as a Key Chemical are presented in this section. The Key Chemical is merely the first chemical entered whose name will be used in reports rather than listing all the chemicals in the mixture. These methods are generally sufficient for hazard evaluation over a narrow temperature range which should include the operating temperature, ambient temperature and the normal boiling point. The following "Mixture Rules" provide a reasonable estimate for selected chemical properties. Either mass fraction with property per unit mass or mole fraction with property per mole may be used.

Mixture Liquid Density may be estimated by additive volumes:

$1/\rho_{\text{mixture}} = \text{sum of liquid fraction divided by density of each component.}$

Example: Estimate liquid density for a mixture of 50 wt% A at 1.0 gm/cc and 50 wt% B at .0.6 gm/cc.
Mixture volume = $0.5 / 1 + 0.5 / 0.6 = 1.333 \text{ cc/gm}$, and mixture density = $1 / 1.333 = 0.75 \text{ gm/cc}$

Mixture Vapor Density may be estimated as an ideal gas as:

$$\rho_v = 0.12 P M_{w_{\text{avg}}} / T$$

where ρ_v is vapor density (kg/m³), P is pressure (kPa), T is temperature (deg K), M_w is average molecular weight of the vapor mixture.

Example: Estimate the vapor density for a mixture of 50 wt% A of molecular weight 30 and 50% wt% B of molecular weight 100 at 101.3 kPa pressure and 298 K. The average molecular weight is $1 / (0.5/30 + 0.5/100) = 46.2$. $\rho_v = 0.12 P M_{w_{\text{avg}}} / T = 0.12 (101.2) 46.2 / 298 = 1.88 \text{ kg/m}^3$.

Mixture Liquid Heat Capacity may be estimated as the sum of liquid fraction times Heat Capacity for each component.

Example: Estimate liquid heat capacity for a mixture of 50 wt% A at 1.5 joule/gm and 50 wt% B at 3 joule/gm. Mixture heat capacity = $0.5 (1.5) + 0.5 (3) = 2.25 \text{ joule/gm}$

Mixture Heat of Vaporization may be estimated as the sum of vapor fraction times Heat of Vaporization for each component.

Example: Estimate the heat of vaporization for a vapor mixture of 50 wt% A at 600 joule/gm and 50 wt% B at 400 joule/gm. Mixture heat of vaporization = $0.5 (600) + 0.5 (400) = 500 \text{ joule/gm}$

Vapor-Liquid Equilibrium in RAST

Mixture Vapor Pressure requires an estimation of the equilibrium vapor composition from a known liquid composition. For simple Risk Analysis, an ideal mixture is assumed where the partial vapor pressure of each component is equal to the pure component vapor pressure times its mole fraction in the liquid (Raoult's Law).

A further simplification is assumption of constant relative volatility and/or a constant ratio of vapor pressures over a narrow temperature range. The vapor-liquid equilibrium ratio for each component is $k_i = y_i / x_i$ where y_i is the mole fraction vapor for component i and x_i is the liquid mole fraction of component i . Relative Volatility is the ratio of k_i values which may be estimated relative to a "key chemical" as:

$$\alpha_i = k_i / k_{\text{key}} = x_{\text{key}} y_i / (x_i y_{\text{key}})$$

For an "ideal" mixture, the relative volatility is also the ratio of vapor pressures.

Note: The ratio of vapor pressure typically decreases with increasing temperature. Selection of the appropriate temperature range is important to provide a reasonable or conservative estimate of vapor composition from liquid composition.

Two liquid phases (each of which is assumed ideal) is used for mixtures of immiscible liquids. In these cases, each component is assumed to be present in either liquid phase A or liquid phase B. The mixture partial pressure is the sum of the partial pressure for each liquid phase. An activity coefficient for each component is estimated at the feed composition and assumed constant in the region of interest as:

$$\gamma_i = x'_i + x''_i / x_i$$

where: x'_i and x''_i are the liquid mole fractions of component i in liquid phase A and B respectively and x_i is the overall liquid mole fraction of component i . For a single liquid phase $\gamma_i = 1$.

The partial pressure for each component is determined as:

$$P_i = P^{\text{sat}}_i x_i \gamma_i$$

where: P^{sat}_i is the vapor pressure of component i .

The total pressure, Π , is estimated as the sum of partial pressures or:

$$\Pi = \sum P^{\text{sat}}_i x_i \gamma_i \quad \text{and} \quad \Pi = x_{\text{key}} \gamma_{\text{key}} P^{\text{sat}}_{\text{key}} / y_{\text{key}}$$

where:

x_i is the overall liquid mole fraction of component i

y_i is the vapor mole fraction of component i

γ_i is activity coefficient for component i

P^{sat}_i is the vapor pressure of component i

P_i is the partial pressure of component i

Π is the total pressure

Note that aqueous mixtures containing acids or bases are highly complex and not easily correlated by this simple model.

Example Entry of a Liquid Mixture

As an example, enter data for a mixture of 0.5 weight fraction acrylonitrile and 0.5 weight fraction water at an Operating Temperature of 25 C and Operating Pressure of 0.01 barg.

STEP 1: Enter liquid composition on the Chemical Data worksheet. Enter 0.5 as the weight fraction for Acrylonitrile. Select "Water" as a second chemical from the chemical list and enter the weight fraction of 0.5.

STEP 2: Enter which (if any) chemicals form a second liquid phase. Enter "Yes" for Second Liquid Phase for Water. Note the change in vapor composition and estimated Saturation Temperature when "Yes" is entered. There is a significant difference in these estimates for two miscible versus immiscible liquids.

STEP 3: Update mixture Flash Point, Melting Point, Autoignition Temperature, and categories for Ease of Ignition, Fuel Reactivity, Dermal Toxicity, Aquatic Toxicity, and Liquid Conductivity as appropriate. These parameters are not accurately estimated for mixtures, such that values representing the "worst" chemical in the mixture are initially selected. An estimated mixture flash point is provided based on the temperature at which the equilibrium vapor composition at atmospheric pressure equals the estimated lower flammable limit. Experimentally determined values should always be entered if available.

Observe the change in estimated boiling point between water as a second liquid phase or in solution. Observe that changing the Operating Temperature to 80 C will change the Physical State to "Vapor". See Figure 3.7.

Do Not Save this example. Clear Water inputs and change Weight Fraction Acrylonitrile in Feed to 1.0.

Chemical Data Input

Go To Main Menu | Go To Equipment Input > | Go To Process Conditions > | Go To Plant Layout >

New Chemical | Save All Input to Equipment Table | Clear Input

Equipment Identification: V-101 | Equipment Type: Vessel/Tank | Location: Outdoors

Operating Temperature = 25 C | Operating Pressure (gauge) = 0.01 bar | Saturation Temperature = 67.0 C | Physical State = Liquid

Key Chemical: Acrylonitrile | Reference: | Chemical Comments: | Reg. Agency Considers Toxic?

Chemicals (the first chemical listed is the 'key' chemical)	Wt Fraction Feed	Second Liq Phase	Wt Fraction Vapor	Relative Volatility	Molecular Weight	ERPG-2 (ppm)	ERPG-3 (ppm)	LFL (vol %)
Acrylonitrile	0.500		0.928	1.0000	53.1	35	75	3.0
Water	0.500	Yes	0.072	0.0778	18.02			
Sum =	1.00							

Vapor Mixture Properties: 46.6 | 43.0 | 92.2 | 3.7

Mixture azeotrope? Yes

Model as a single Pseudo-Chemical?

Summary of Chemical Properties

Estimated Boiling Point =	66.7	C
Boiling Point at Operating Temp =	0.170	atm
Boiling Point at Relief Set or MAWP =	0.89	gm/ml
Heat Capacity at Op Temp =	0.75	cal/gm C
Liq Heat Capacity at Boiling Point =	0.77	
Heat of Vaporization at Op Temp =	183	cal/gm
Heat of Vaporization at Boiling Point =	172	
Boiling Point at Relief Set or MAWP =	71.5	C
Boiling Point at Burst Pressure =	73.6	C

Estimated vapor composition: Estimated 1 hour LC₅₀ = 121.9 ppm | Estimated 1 hour LC₅₀ = 209.6 ppm

Name	State	Mol Weight	ERPG-2 (ppm)	ERPG-3 (ppm)	LFL (vol %)	Flash Pt (C)
Vapor	Vapor	29				

Pad Gas Properties | Heat Transfer Fluid

Show Chemical Details | Hide

Physical state at the operation temperature, pressure and saturation temperature is displayed

Enter chemical names and weight fraction in the feed. The total should equal 1

Enter Yes for all chemicals which could form a second liquid phase

Estimated vapor composition in equilibrium with liquid feed is displayed

Estimates for selected chemical properties are displayed which may be updated by entering mixture data if available

Option to model as a single 'pseudo-chemical'

Show or Hide detailed chemical data such as Correlating Coefficients, NFPA ratings, etc.

Figure 3.7: Chemical Mixture Data Input

Multi-component Flash and Evaporation in RAST

A single stage equilibrium flash is estimated in RAST assuming constant relative volatility. From a material balance:

$$F = V + L$$

$$F z_i = V y_i + L x_i$$

$$z_i = (V / F) y_i + (1 - V / F) x_i = F_V y_i + (1 - F_V) x_i$$

$$x_i = z_i / \{ F_V (y_i / x_i) + 1 - F_V \}$$

substituting $\alpha_i = k_i / k_{key} = x_{key} y_i / (x_i y_{key})$ and $\Pi = x_{key} \gamma_{key} P^{sat}_{key} / y_{key}$ yields:

$$x_i = z_i / \{ F_V (\alpha_i \gamma_{key} P^{sat}_{key} / \Pi) + 1 - F_V \}$$

A heat balance of the system yields:

$$F_V = (T_0 - T) C_S / \lambda$$

A simple Rayleigh distillation (single equilibrium stage) is used in RAST for multi-component evaporation from a liquid pool once liquid feed to the pool has stopped. The material balance correlation is:

$$x_i = z_i e^{\alpha_i \ln [(1 - F_V) x_{key} / z_{key}]} / (1 - F_V)$$

where:

F is molar flow rate of the feed stream

L is molar liquid flow rate following flash

V is molar vapor flow rate following flash

z_i is the feed mole fraction of component *i*

x_i is the liquid mole fraction of component *i* after flash or evaporation

y_i is the vapor mole fraction of component *i* after flash or evaporation

x_{key} is the liquid mole fraction of the key component after flash or evaporation

y_{key} is the vapor mole fraction of the key component after flash or evaporation

z_{key} is the overall feed mole fraction of the key component

γ_{key} is activity coefficient for the key component

P^{sat}_{key} is the vapor pressure of the key component at the final temperature

F_V is the flash fraction

Π is the total pressure after flash or evaporation

T₀ is the initial temperature

T is the final temperature after flash

C_S is the molar liquid heat capacity

λ is the molar heat of vaporization

These correlations are solved by trial-and-error for the temperature, *T*, at which both the material and energy balance is satisfied or $\sum x_i = 1$.

4. REACTIVITY DATA AND EVALUATION

Introduction

Evaluation of Reactivity Hazards is one of our most challenging activities. It often involves interpretation of Reactive Chemicals test data. RAST allows input of Reactive Chemicals testing data in addition to providing several screening analysis techniques.

This section covers:

- Reactivity Screening evaluation including: Estimation of Maximum Reaction Temperature and Pressure, Temperature of No Return (TNR), and Time to Maximum Rate (TMR).
- Check for Insulation or Packing Fire potential.
- Check for Potential Explosive
- Correlation of Reactive Chemicals test data to first-order kinetics
- Evaluation of potential process upsets on reaction rate such as: catalytic impurities, “pooling” of reactants, and mis-loading or wrong recipe.

Reaction Data and Evaluation

The Reaction Data worksheet is used both for input of Reactive Chemicals data and Screening Evaluation of Reactivity Hazards. Inputs include heat of reaction, activation energy, detected onset temperature, detected onset rate, test method, and quantity of volatile or gas generation per volume of material.

The detected onset temperature, detected onset rate, and Activation Energy represents a “best fit” of Reactive Chemicals data to a first-order kinetic model. For a test method of *Accelerating Rate Calorimetry* (ARC) or *Vent Sizing Package* (VSP), a *thermal inertia* or phi factor is also required. The phi factor represents the fraction of total reaction heat retained by the sample and is used to scale the data to large equipment. If the test method is *Differential Scanning Calorimetry* (DSC), the detected onset rate is not required as it is assumed to be the sensitivity of the instrument. For a test method of *Theoretical*, inputs are assumed to have been adjusted for large scale equipment.

Several screening evaluations are performed based on equipment, chemical, and reaction inputs. These include: Maximum Reaction Temperature and Pressure, Temperature of No Return (TNR) and Time to Maximum Rate (TMR) for up to 4 initial temperatures. A Reactivity Parameter provides an estimate for potential explosive material (Index > 20) similar to the Yoshida correlation noted in the Chemical Hazard Engineering Fundamentals (CHEF) workshop under Reactivity. Finally, the Frank-Kamenetskii critical diameter for “spontaneous reaction” of powders and solids is estimated at the operating temperature and up to 4 initial temperatures by providing a thermal conductivity input of the bulk material.

Example Reaction Data Input and Evaluation (See Figure 4.1)

As an example, enter Reactive Chemicals test data for uninhibited acrylonitrile. This data is based on Accelerating Rate Calorimetry MD-1987-000517.

STEP 1: Enter the heat of reaction. The measured heat in this experiment was -1058 J/g or -253 cal/g. This is only 80% of the theoretically reported value of -17.3 kcal/mole or -326 cal/g. Enter -326 cal/g.




Figure 4.1. Reactivity data worksheet for Acrylonitrile example

Note that for Continuous Reactions, the Heat of Reaction per Mass in RAST could include heating of the feed to the maximum reaction temperature such that the apparent Reaction heat is $\Delta H_R/2$.

STEP 2: Enter the Activation Energy. The Activation Energy should be based on a "best fit" of Reactive Chemicals Data to a first-order model. Enter 32 Kcal/gm mole.

If two temperature-rate data pair are available (two points on the “best fit” line), these may be entered under the section “Estimation of Activation Energy from ARC Data”. The two data points should be selected within the lower ½ of the temperature rise and, in a region, where there is minimal scatter in the data. Enter 0.16 C/min at 210 C and 3.1 C/min at 260 C (data points from the ARC experiment, Figure 4.2). The estimated Activation Energy is 32.2 Kcal/gm mole (Figure 4.3). (Note that the Estimated Activation Energy will change slightly with changes in the Detected Onset Temperature and Detected Onset Rate.)




Figure 4.2 ARC data for example

Estimation of Activation Energy from ARC Data		
Temperature, C	210	260
Observed Rate, C/min	0.16	3.1
Fraction Conversion	0.0640	0.2240
Activation Energy =	32.2	Kcal/gm mole

Figure 4.3 Results from Reactivity Data worksheet

STEP 3: Enter the Detected Onset Temperature and Detected Onset Rate. The Detected Onset Temperature in Figure 4.2 represents the detection limit of the test instrument. If inputs are based on a theoretical model rather than test data, a detected onset temperature corresponding to a detected onset rate of 0.01 cal/min (roughly 0.02 deg C/min) is suggested. If the test method is ARC or VSP, the thermal inertia or phi factor also needs to be input. Enter 190 C for the detected onset temperature, 0.08 C/min as a first-order “best fit” for the detected onset rate, a phi factor of 2.1 and “ARC” as the test method. This represents the “best fit” rate at the detected onset temperature of the experiment.

STEP 4: Enter the Gas Generation. From the vapor pressure versus temperature data (Figure 4.4), there is no evidence of volatile or gaseous products of reaction. Enter 0 or leave blank.




Figure 4.4 Vapor pressure vs. Temperature for example

A single pressure-temperature at the end of the experiment may be used to estimate the quantity of Gas Generation. A pressure of 1865 psia (126.9 atm) at 386 C was reported from the experiment near the end of the experiment. Enter this data point and the estimated vapor pressure + inert pad (from the Chemical Data entered) is 134 atm which is slightly higher than the observed pressure indicating zero (or blank) gaseous products formed. The typical range for gm mole gas generated per cc reaction liquid is zero to 0.01.

For vapor-phase reactions, the gas generation term represents the moles products divided by moles reactants with values in the typical range of 0.5 to 2 (Figure 4.5).

Estimation of Gas Generation		
Observed Press (atm abs) and Temp (C)	126.9	386
Estimated Vapor Pressure + Inert Pad	134.26	atm
Estimated Gas Generation, k =		gm mol/cc mix

Figure 4.5 Gas generation results for example

STEP 5: Enter the Questions: “Gas Generation precedes Exotherm?” and “Inhibited Monomer?” The answers to these questions do not impact the preliminary Reactivity Evaluation but may be important in understanding upset process conditions that could lead to runaway reaction or generation of excessive pressure.

Note that any reaction that generates volatile or gaseous products will slowly pressurize a “closed” system, even a normal operating temperature.

STEP 6: Potential for Insulation or Packing Fire. The potential for insulation or packing fires is categorized as high, medium, or low (Figure 4.6). This index is based on Britton’s method which compares

Flash Point and Autoignition Temperature. If the chemical cannot undergo an oxidation reaction, this Index should be ignored. Results do not reflect other exothermic reactions (such a polymerization) that may occur.

Potential for Insulation or Packing Fire			
Britton's Method, Z =	0.99	Potential =	LOW

Figure 4.6 Potential for Insulation or Packing Fire

STEP 7: Estimation of Frank-Kamenetskii Critical Diameter. Frank-Kamenetskii theory allows for a temperature gradient to be taken into account for a reacting system. This is particularly important where there could be a considerable resistance to convective heat transfer such as for solids or highly viscous fluids. This Critical Diameter is shape dependent and that reported in RAST is based on an “infinite slab”. The F-K Critical Diameter represents the “depth” of solid or fluid at which “hot spots” can occur which, after a long enough induction time, may lead to runaway reaction.

Enter Thermal Conductivity for Acrylonitrile of 0.15 watt / m C at the operating temperature of 25 C. The F-K Critical Diameter is estimated at 38050 cm indicating that thermal gradients within the fluid are not likely to be sufficient for runaway reaction from the normal operating temperature (Figure 4.7).

Estimation of Frank-Kamenetskii Critical Diameter (Slab)		
Material Thermal Conductivity	0.15	watt / m C
F-K Critical Diameter at 25 deg C	38050.45	cm

Figure 4.7 F-K Critical Diameter

The F-K Critical Diameter may be estimated at a several temperatures from the table at the lower left-hand side of the Reaction Input worksheet. Select F-K Critical Diameter and Enter Desired Temperatures (Figure 4.8). The Critical Diameter does not become sufficiently small to indicate a runaway hazard below the Temperature of No Return (which is based on convective heat loss assuming a *uniform temperature* within the reacting medium or Semenov theory).

Time to Maximum Rate at Specified Starting Temperatures			
Reaction Scenario Type =		F-K Critical Diameter	
Temperature (C)		Crit Diam (cm)	
25		38050.5	cm
50		5093.9	cm
100		208.1	cm
150		18.4	cm

Figure 4.8 F-K Critical Diameter vs. Temperature

STEP 8: Preliminary Reactivity Evaluation. Upon entry of the reaction inputs, a graph of heat rate versus temperature will be shown corrected to near “adiabatic” conditions (dashed black line). A yellow dashed line representing the estimated convective heat losses from the equipment (based on outer surface area and insulation inputs from the Equipment Input worksheet) is also shown. The intersection of the yellow dashed line representing heat losses and the reaction heat rate represents the Temperature of No Return – the temperature above which runaway reaction occurs based on convective heat losses.

STEP 9: Save Inputs to the Equipment Table.

If mechanical energy or heat transfer inputs have been entered in the Equipment Input, a second line is shown on the graph representing reaction heat plus these additional heat inputs (dark blue line). If the potential for pool fire exists, then a third line is shown representing reaction heat plus pool fire heat input (red line) (Figure 4.9).




Figure 4.9 Reaction Heat Gain or Cooling Loss Chart

A second graph of pressure versus temperature is also provided. The dashed black line represents the vapor pressure per the composition input from the Chemical Data worksheet. *Note that the effect of changes in composition with reaction conversion is not considered.* The total pressure (including initial gas pad and any gas generation input) for reaction heat plus additional heat inputs is shown as a dark blue line. If the potential for pool fire exists, then a third line is shown representing reaction heat plus pool fire heat input (red line). A dashed yellow line represents the Relief Device Set Pressure or Maximum Allowable Working Pressure (MAWP) if relief device information is not available. A yellow triangle is shown at the intersection of the reaction pressure and Relief Device Set Pressure (or MAWP) and represents the reaction conditions where relief device activation may occur (Figure 4.10).




Figure 4.10 Reaction Pressure versus Temperature

A table summarizing maximum reaction temperature and pressure, temperature of no return, and Reactivity Parameter for potential explosive is shown at the bottom left of the Reaction Input worksheet. The Reaction Scenario Type is selected to determine which values are presented. (Figure 4.11)




Figure 4.11 Reaction Summary

Reaction Scenario Type as "Reaction". Values shown represent no additional heat input. Try other Reaction Scenario Types to view appropriate hazard screening values.

Evaluation of Potential Process Upsets

In some cases, screening evaluation for the impact of a process upset to a reaction may be obtained by adjustment of appropriate kinetic parameters. Common process upsets of interest are:

- ☐ External heat plus reaction
- ☐ Change in heat of reaction per mass (mis-loading or scale-up)
- ☐ Introduction of a catalytic impurity
- ☐ "Pooling" of reactants

It is important to recognize the evaluation of process upsets in RAST is based on a "steady state" approach with an "average" composition entered in the Chemical Data worksheet and simple first-order reaction kinetics. A dynamic simulation for a runaway reaction may be needed to address more detailed issues such as relief design for reactive systems.

Impact of External Heat: External heat may result from a heat transfer surface, mechanical energy such as an agitator or circulating pump, or fire. The primary impact of external heat is an increase in temperature without consuming reactants. At temperatures where reaction heat rate is much less than the external heat input, reaction conversion is essentially zero and total heat rate is only attributed to the external source. RAST uses a simple first-order kinetic model to determine reaction heat rate and either a constant external heat rate (such as for fire or mechanical energy) or an external heat rate which depends on temperature difference with a heating media (such as a heat exchanges). The total heat rate is the sum of both reaction and the external heat source.

Consider the impact of external heat on our acrylonitrile storage tank example. The maximum reaction temperature, pressure, and heat rate are much higher with external heat input. The reaction heat versus temperature with external fire (red line) exhibits a peak rate at nearly 80 C higher than the adiabatic reaction (dashed black line). This results in a higher peak heat rate and higher pressure (Figure 4.12).




Figure 4.12 Example Simple Kinetic Model with 1 C/min External Heat

Change in Heat of Reaction per Mass: A change in heat of reaction per mass affects the maximum temperature, the conversion per temperature increment, and the initial heat rate. This change may be the result of scale-up since Thermal Inertia (loss of reaction heat to equipment or sample container) is less for larger scale equipment. A change in the heat of reaction per mass may also be the result of mis-loading or a change in reactant concentration. More dilute exothermic reactions generate less total heat per mass.

The temperature rise for a reaction using a simple kinetic model (Figure 4.13) is roughly 0.2 divided by 0.15 or 1.33 times higher for 20 weight % reactant versus 15 %. The corresponding maximum reaction rate is significantly (nearly one order of magnitude) higher for the more concentration reaction.




Figure 4.13 Example Simple Kinetic Model for Change in Reactant Concentration

The Reaction Input worksheet may be used to estimate the impact of changes in heat of reaction per mass. Assume that the reaction is run in 50% solvent (with a liquid heat capacity similar to the reactant) and a possible upset condition is failure to add solvent. Enter "Yes" for the question "Potential Mis-Loading of Reactants?" Enter "Multiple of Reaction Heat for Mis-Loading" of 2. This corresponds to the same heat of reaction but only 1/2 the total mass. Note that the temperature rise is essentially double the adiabatic temperature rise. This change results in an estimated peak reaction rate more than two orders of magnitude higher (Figure 4.14).




Figure 4.14 Effect of Mis-Loading of Reactants

Introduction of a Catalyst or Catalytic Impurity: Introduction of a small amount of catalytic material may significantly increase the overall self-heat rate for exothermic reactions. Chemicals normally maintained within safe operating limits may quickly progress to potential runaway conditions at the operating temperature. The reaction rate for the polymerization in Figure 4.15 is significantly higher (nearly one order of magnitude) with the addition of 500 ppm of BFO catalyst. Note that only reaction rate and not temperature rise (or heat of reaction) is affected by catalyst addition.




Figure 4.15 Example Simple Kinetic Model for Addition of Catalyst

The Reaction Input worksheet may be used to estimate the impact of a catalyst. Enter “Yes” for the question “Potential Catalyzed Reaction”. An estimate is made within RAST by increasing the first-order rate constant until reaction heat rate exceeds the cooling capability at the normal operating temperature (orange line, Figure 4.16). This is a *hypothetical* situation and may not reflect what could actually occur. It is merely to address the question “if a sufficiently effective catalyst exists for uncontrolled reaction to occur at the normal operating temperature, what might be the effect to reaction parameters?”

Should the potential impact of a catalyst significantly affect analysis results, it is highly recommended that experimental data be obtained.




Figure 4.16 Effect of Potential Catalyzed Reaction

Note that for our acrylonitrile example, polymerization does not occur at an appreciable rate unless the temperature is well above the normal boiling point of 77 C (TNR = 140 C) even for uninhibited material. Since the equipment cannot operate at a pressure corresponding to the vapor pressure of acrylonitrile at 140 C (roughly 76 psia or 5.2 bar), the equipment would likely fail and contents vaporize prior to reaching the Temperature of No Return. However, if a catalyst is inadvertently added, a potentially explosive reaction rate could occur. The "catalyst" might be a strong acid or base such that if this vessel were vented to a scrubber, a potential reactive scenario might be contamination by the scrubber fluid.

Pooling of Reactants: A common means for controlling an exothermic reaction is by slow addition of a limiting reagent such that the overall reaction heat rate is proportional to the addition rate. "Pooling" occurs if the concentration of limiting reagent is allowed to increase - typically by loss of mixing or low temperature. Following accumulation of un-reacted material, batch reaction kinetics occurs potentially leading to runaway reaction.

For a batch reaction, a limiting reaction rate is estimated as the Heat of Reaction divided by the *Addition Time*. For a continuous reaction, a limiting reaction rate is estimated as the Heat of Reaction per mass divided by the *Residence Time*. Residence Time is estimated as the total reactor mass divided by the mass feed rate.

Assume that the reaction is controlled by the addition of monomer over 60 minutes. Enter a Limiting Reaction Rate of $-326 / 60$ minutes or -5.43 cal / g-min. To estimate reaction conditions if 50% of the feed were added without reacting, enter "Yes" for "Potential for Pooling" of Reactants?" and 0.5 for Fraction of Reaction Heat for "Pooling". [Note – these lines are "greyed out" until the values are entered.] An estimate is made within RAST for this condition denoted by a purple line on the heat rate versus temperature plot (Figure 4.17).




Figure 4.17 Effect of Reactant Pooling

In some cases, two liquid phases may be present. If, for example, the reaction mixture were 25 % acrylonitrile and 75% water, the Heat of Reaction per Mass would be 0.25 (-326) or -81.5 cal/g mixture. By selecting "Yes" to "Reactants in Separate Liquid Phase", an estimate of reaction conditions is made within RAST based conservatively on no heat loss to the second liquid. Note that "pooling of reactants" does not apply to vapor-phase reactions.

Do not save the entries for Potential Mis-Loading of Reactants, Potential Catalyzed Reaction, and Potential for "Pooling" of Reactants.

5. ADDITIONAL RAST INPUTS AND REPORTS

Introduction

RAST allows input of detailed information for Equipment, Process Conditions and Plant Layout. This additional information is used to support identification of hazard scenarios and improved quantification of risk.

This section covers:

- How additional Equipment Parameter information is used to identify scenarios and evaluate hazards.
- How additional Process Conditions information is used to identify scenarios and evaluate hazards.
- How additional Plant Layout information is used to identify scenarios and evaluate hazards.

Equipment Parameters

In addition to the minimum required inputs, other information may be needed for various evaluations and reports. The more information available, the more thorough the evaluation. However, only those inputs for the specific equipment being evaluating needs to be entered. See Figure 5.1 for further examples.

General Equipment Information

General Equipment information applies to most types of equipment. The minimum required inputs are Volume and Maximum Allowable Working Pressure (MAWP). Other inputs include:

Full Vacuum Rated? – should be answered “No” if vacuum failure is *feasible*. If the MAWP is less than 1 atmosphere gauge (101 kPag or 14.7 psig), this input is highlighted “yellow” as a recommended input. If blank, the default assumption is that the equipment is vacuum rated

Estimated High Temperature Failure – is the temperature where equipment failure may be possible at the normal operating pressure due to weakened material strength.

Estimated Embrittlement Temperature – is the temperature where equipment may fail under stress of shock due to transition from ductile to brittle.

Nozzle or Pipe Diameter – represents the largest practical hole size for nozzle, pipe, or hose failure scenarios. This is a minimum input requirement for all but solids containing equipment.

Number of Flanges or Nozzles – input is used in evaluation of Mechanical Integrity scenarios for smaller hole sizes (5 mm and 25 mm) typically associated with flange or gasket failures.

Material of Construction – is a list of common construction materials. This input is used to determine if the equipment is “brittle” (likely to result in many fragments upon overpressure failure or rupture), susceptible to corrosion under insulation (external corrosion), and in determining the failure frequency for Mechanical Integrity scenarios.

Equipment Mass – is used in providing a better estimate for “time to failure” for overheating cases. If blank, the default is zero such that only the mass of equipment contents is used in the estimate. For pumps, a default estimate of equipment mass based on data from centrifugal pumps is used if this input is blank.

Internal Corrosion or Stress Cracking Potential? – should be answered “Yes” if the equipment contents represent an internal corrosion or stress cracking potential for the Material of Construction. This input is used in determining the failure frequency for Mechanical Integrity scenarios. If blank, the default assumption is that the Material of Construction is compatible with the equipment contents.

Equipment Input

[<< Go To Main Menu](#)
[< Go To Chemical Data](#)
[Save Input to Equipment Table](#)
[Clear Input](#)
[Go To Process Conditions Input >](#)
[Go To Plant Layout >](#)
[Go To Reaction Input >](#)

Equipment Identification: V-101
Equipment Type: Vessel/Tank
Location: Outdoors

Equipment Parameters

Equipment Volume =	100	cu m
MAWP (gauge) =	0.2	bar
Full Vacuum Rated?		
Estimated High Temperature Failure =		C
Estimated Embrittlement Temperature =		C
Nozzle or Pipe Size =	100	mm
Number of Flanges or Nozzles =		
Material of Construction		
Estimated Equip Mass based on C. Steel	3408	kg
Equipment Mass =		kg
Estimated Corrosive or Stress Cracking Potential?		
Susceptible to Vibration Fatigue?		
Motor Power =	7.5	Kwatt
Insulation		
Insulation Heat Reduction Factor =		
Tracing?		
Estimated Equipment Max Wetted Area =	101	sq m
Equipment Max. Wetted Area =		sq m
Equipment Elevation to Surface =		m
Drain Valve Size		mm

Vessel/Tank Parameters

Vessel/Tank Geometry?		
Low Pressure Tank with Weak Seam Roof?		
Vessel/Tank Considered as "Storage"?		
Conductive Dip Pipe or Bottom Fill?		

Heat Transfer Parameters

Heating Transfer Area =		sq m
Heating Overall U =		Kwatt / sq m C
Heating Fluid Temperature =		C
Heat Transfer Fluid Pressure (gauge) =		bar
Heat Transfer Fluid Failure Release to Atmosphere?		
Heat Transfer Fluid Name =		
Heat Transfer Fluid State =		
Quantity Hot Oil Handled (for F&E) =		
Tube (or Leak) Diameter =		mm
Number of Tubes =		
Cooling Transfer Area =		sq m
Cooling Overall U =		Kwatt / sq m C
Coolant Temperature =		C

Piping Parameters

Pipe Length =		m
Piping Vulnerable to Damage?		
Apply Screwed Connection Penalty?		

Pump / Agitator Parameters

Pump Type =		
Seal or Containment Type =		
Remote Start Pump?		
Pump Automated Suction or Discharge?		
Pump Volume (including piping to block valves), liter	15.1	
Pump Surface (including piping to block valves), m ²	0.69	

Transportation Equipment or Piping Parameters

Equipment or Piping Connection =		
----------------------------------	--	--

Other Equipment Parameters

Replacement Cost & Business Loss		
Drum Oven Volume =		cu m
High Speed Rotating Equipment?		
Bel lows or Expansion Joint Used?		
Sight Glass Used?		

Relief Device Parameters

Relief Device Identification	PVRV-101	
Relief Type =	PVRV	
Relief Discharges to:		
Relief Set Pressure (gauge) =	0.1	bar
Relief Size (equiv. diameter) =	250	mm
Relief Design Actual Flow Rate =		kg/min
Release Pipe Diameter =		mm
Release Elevation	6	m
Closest Distance From Relief to Elevated Work Area =		m
Furthest Distance from Relief to Elevated Work Area =		m
Elevation of Nearest Work Area =		m

Enter Distances from Relief Location ONLY if Different from Equipment Location

Relief Distance to Property Limit or Fence Line =		m
Relief Distance to Occupied Bldg 1 or Area =		m
Relief Distance to Center of Occ Bldg 1 =		m
Occ Bldg 2 in Same Wind Direction for Relief?		
Relief Distance to Occupied Bldg 2 =		m
Relief Distance to Center of Occ Bldg 2 =		m

Figure 5.1: Additional Equipment Input Parameters

Susceptible to Vibration Fatigue? – should be answered “Yes” if vibration fatigue could cause a small hole size leak representing a “crack” in larger piping or failure of small piping branches.

Motor Power – represents mechanical energy input for the equipment such as a vessel agitator or mixer, circulating pump, etc. It may also represent an electric heater or tracing. An overall “inefficiency” of 50% (power resulting in heat) is assumed which is conservative for pumps and agitators but optimistic for electric heaters. For pumps, with a hydraulic efficiency of 0.6 and a 0.9 efficient electric motor exactly matched to the required hydraulic power, the thermal inefficiency would be roughly $(1-0.6)(1-0.9) = 0.36$ rather than 0.5. The user may need to adjust the power input to for improved estimates of maximum mechanical energy temperature.

Insulation – is used to determine a heat loss coefficient in energy balance estimations. Choices are “Yes”, “No”, and “Fireproof”. The option, “Fireproof” will reduce the estimated heat input from external fire. If the equipment operating temperature is within the Corrosion Under Insulation temperature range, the Input will be labeled “Insulation with Potential Corrosion (CUI)”.

Insulation Heat Reduction Factor - This is a reduction factor which will be multiplied by the heat transfer coefficient to account for insulation. It will default to a value of 0.05 if not entered.

User Equipment Wetted Surface Area – is the wetted surface area of the equipment used for fire heat input or convective heat losses. If blank an estimated Wetted Surface Area will be used based on equipment volume and tank/vessel geometry

Tracing? – entered as “Yes” if equipment is heat traced.

Equipment Elevation to Surface – represents the elevation or height of a leak above a liquid pool. This input is used to determine fire heat input (fire heat is zero for greater than 30 feet or 9.1 m elevation), distance for liquid spray and duration of aerosol droplets for estimation of Airborne Quantity. A default value of 1 m is used if this input is blank.

Drain Valve Size – is the “hole size” equivalent that will be used for estimation of leak rate for a drain valve inadvertently opened scenario. A default of ½ inch is used (representing a standard ¾ inch plug valve equivalent to a ½ inch hole) if this input is blank.

Parameters Specific to Vessels or Tanks

In addition to the General Equipment Parameters, additional inputs specific to Vessels or Tanks include:

Vessel/Tank Geometry? – Geometry is noted as horizontal, vertical, flat bottom" and/or "anchored" to improve estimation of surface area and Rupture Pressure.

Low Pressure Tank with Weak Seam Roof? – Used to determine is vessel is anchored to credit a Weak Seam Roof.

Vessel/Tank Considered as "Storage"? – To determine if the tank is considered as Storage per API 521 [4]. This is an Input for F&EI and used in determining fire heat input.

Conductive Dip Pipe or Bottom Fill? – should be answered “Yes” if appropriate. A “Yes” answer will suggest this design feature as a potential Safety Related Protective System for preventing electrostatic discharge for tanks or vessels containing flammable materials.

Parameters Specific to Heat Exchangers or Vessel Jackets

In addition to the General Equipment Parameters, additional inputs specific to Heat Exchangers or Vessel Jackets include:

Heat Transfer Area – is the area, A, used in estimation of heat input rate, $q = U A \Delta T$ where ΔT is the temperature difference between the Heat Transfer Fluid Temperature and Operating Temperature.

Heating Overall U – is the heat transfer coefficient, U, used in estimation of heat input rate. If either Heat Transfer Area or Heating Overall U is blank, no estimation of heat input rate is performed.

Heat Transfer Fluid Temperature – is used to determine if the maximum operating vapor pressure exceeds design limits, if the maximum operating temperature can exceed the Reaction Temperature of No Return, and in estimation of the heat input rate.

Heat Transfer Fluid Pressure – is used to determine if tube or heat exchanger failure will leak heat transfer fluid into the process or if process fluid would leak into the heat transfer system.

Tube Failure Release to Atmosphere? - Should be answered "Yes" if tube failure will result in a release of process fluid to atmosphere.

Heat Transfer Fluid Name – is used to look up chemical properties of the heat transfer fluid for estimation of tube leak hazards. Heat Transfer Fluid State is not an input but estimated from the fluid properties, temperature and pressure.

Tube or Leak Diameter – is used to estimate the leak rate and potential consequences for tube failure.

Number of Tubes – is entered either as “< 100” or “> 100” to determine the Initiating Event factor in LOPA.

Cooling Transfer Area, Cooling Overall U, and Coolant Temperature – are inputs to estimate the Temperature of No Return with cool for reaction scenarios.

Parameters Specific to Piping

In addition to the General Equipment Parameters, additional inputs specific to Equipment or Piping include:

Pipe Length – is the length of piping associated with an entire piping loop in the same Chemical Service.

Piping Vulnerable to Damage? – is used to determine if a pipe damage scenario should be added to the list of scenarios for consideration.

Apply Screwed Connection Penalty? – this input has options for: No Penalty, Through Very Small, Through Medium, Through Very Large and Through Extremely Large. A penalty will be taken for Mechanical Integrity scenarios through the hole size noted.

Note that Piping inputs are only used if the Equipment Type is Piping, Pump, Compressor or Blower, or Turbine or Gas Expander.

Parameters Specific to Pumps

In addition to the General Equipment Parameters of Volume, Maximum Allowable Working Pressure (MAWP) and Motor Power, additional inputs specific to Pumps include:

Equipment Volume – represents the volume of the pump plus piping system. The volume of the pump cavity is estimated for a pump based on data for centrifugal pumps.

Pump Type – is used in determining the suggested type of Pump Deadhead scenario for evaluation. Options are: Centrifugal, Positive Displacement, or Diaphragm with Limited Source Pressure. The default is assumed Centrifugal if the input is blank.

Seal or Containment Type – is used to determine the Initiating Event for a Seal or Casing Leak scenario. Options are: Single Mechanical, Double Mechanical, Magnetic Drive or Canned, or Double Containment.

Remote Start Pump? – should be answered “Yes” if an “off, jog, auto” field switch is used (could not be in a manual “on” position) and the switch location is beyond the severe hazard impact zone associated with pump failure. The default is “No” if the input is blank.

Automated Suction or Discharge? – should be answered “Discharge Only” or “Both Suction and Discharge” if a failure of instrument air or Basic Process Control could result in the inadvertent closing of the discharge and/or suction valves creating a pump deadhead scenario.

Parameters Specific to Relief Devices

Relief Device information may be entered for all types of equipment. Entry of a Relief Set Pressure indicates that a Relief Device exists (or is planned) for the equipment item being evaluated. The additional Relief Device Parameters are used for evaluation of Relief Device Effluent or in estimating the release rate within Layers of Protection Analysis.

Relief Device Identification – is the identification number of the Relief Device for reference.

Relief Type – is the type of Relief Device including: Rupture Disk, Graphite Disk, Safety Valve, Pilot Operated Valve, ERV, PVRV, Pressure Relief Line, Combination PSV, and Combination Disks.

Relief Discharges to: - provides information relative to the release location and orientation. Options include: Indoors, Outdoors-Upwards, Outdoors-Horizontal, Outdoors to Ground, Pump or Compressor Suction, Vent Header to Blow-down Tank, and Scrubber or Containment.

Relief Set Press (gauge) - is the set pressure of the Relief Device. If blank, it is assumed that no Relief Device has been used for overpressure protection of the equipment being evaluated.

Relief Size (equivalent diameter) – is the orifice diameter for Safety Values or diameter for other types of devices. It is used in estimation of the Actual Flow Rate for relief device activation.

Relief Design Actual Flow Rate – is the actual flow capacity from Relief Design calculations and must be matched to the composition on the Chemical Input worksheet. If the actual flow rate is based on a relief vent design program which only compares worst case chemical within a mixture, the input should be left blank and an estimate based on the device diameter and set pressure will be used.

Relief Tail Pipe Diameter – is the diameter of the Tail Pipe and used to determine the exit velocity from the relief system. This velocity is an important parameter in determining dilution of the relief effluent by “jet mixing”. A low velocity is assumed if the input is blank.

Relief Discharge Elevation – is the elevation of the relief discharge and used in the dispersion modeling for estimation of ground level concentration versus distance. A worst case “ground” elevation release is assumed if the input is blank.

Closest Distance to Nearest Elevated Work Area – is used to determine the concentration of toxic or flammable material at the closest edge of the nearest elevated work area from the release location, most typically a relief device.

Furthest Distance to Nearest Elevated Work Area – is used to determine the concentration of toxic or flammable material at the furthest edge (for large areas) of the nearest elevated work area from the release location, most typically a relief device

Elevation of Nearest Work Area - is used to determine the concentration of toxic or flammable material within the nearest work area.

Locations Specific to Relief Device – Entered ONLY if Different from Equipment Location, includes:

Relief Distance to Property Limit or Fence Line

Relief Distance to Occupied Building 1 or Area

Relief Distance to Center of Occupied Building 1

Occupied Building 2 in Same Wind Direction for Relief?

Relief Distance to Occupied Building 2

Relief Distance to Center of Occupied Building 2

Example Relief Device Effluent Screening Evaluation

As an example, for a Relief Device Effluent Evaluation, continue with the “Getting Started” Study Example. (Note that Inputs on the Plant Layout worksheet will also impact Relief Effluent Screening.)

STEP 1: Go to the Equipment Table and select a cell in the row representing Inputs for V-101. Use the *Load Selected* command. Information for V-101 should now be “active” on the Equipment Input worksheet.

STEP 2: Go to Equipment Input and enter the Relief Device Identification as PVRV-101. Select PVRV for the Relief Type. Also enter Relief Size of 250 mm (10 inch), a Relief Set Pressure of 0.07 barg (1 psig), and Relief Discharge Elevation of 6 m (20 ft). Select *Save Input to Equipment Table*.

STEP 3: Select *Go to the Main Menu*, then Select Relief Effluent Screening Report from the Main Menu (Figure 5.2).

RAST RELIEF EFFLUENT SCREENING
RAST Version 1.1

[Save Input to Equipment Table](#) [Clear Input This Worksheet](#)

Study File: Risk Analysis Screening Tool.xlsm
Equipment Item: V-101
Relief Device Identification: PVRV-101
Reviewed By:
Prepared Date:

Do Government Permits Require Effluent Treatment?
Does Operations Support Venting to Atmosphere?

Relief Effluent Screening based on ERPG-2 Concentration Beyond the Property Limit - or:
Onsite Personnel exposed to 0.25 times LFL (flammable) vapor - or - hot, corrosive or toxic liquid
Onsite Personnel exposed to 2 times ERPG-3 vapor concentration for short duration (toxic)
Occupied Buildings exposed to 1 times ERPG-3 vapor concentration (toxic infiltration)

Type of Relief Device: PVRV
Discharge Orientation: Horizontal Assumed

Relief Orifice Diameter, cm = 25
Relief Set Pressure, barg = 0.1
Horizontal Distance To Nearest Fence Line, m = 180
Horizontal Distance To Nearest Work Area, m =
Horizontal Distance To Occupied Building, m = 70

ID of Discharge Piping (final segment), cm = 25
System Inventory, kg = 103690
Elevation of Relief Discharge above Ground, m = 6
Elevation of Nearest Work Area above Ground, m = 1.2
Ventilation Elev of Occupied Bldg above Ground, m =
Entered Relief Design Actual Flow Rate (kg/sec) =

Summary of Risk Categories:
Flammable ☒
Toxic ☒
Reactive ☐
Corrosive to Tissue ☐
Environmental ☒

LOPA Scenario ID, or Comments

Scenarios Considered:	Comments or Reviewed By:	Effluent Screening	LOPA Scenario ID, or Comments
Excessive Vent Flow - Pad Gas			
Failure			
Excessive Vent Flow - Displacement from Liquid Filling		Relief Effluent May Not Pose Significant Risk for Release to Atmosphere	
Overfill or Overflow		Effluent may be Hazardous Liquid or Two-Phase Material - see Effluent Screening Notes	
Backflow			
Heat Exchanger Tube Failure			
Excessive Heat Input - Pool Fire Exposure		Additional Risk Evaluation or Effluent Treatment is Suggested - see Effluent Screening Notes	
Excessive Heat Input - Heat Transfer			
Excessive Heat Input - Mechanical Energy		Relief Effluent May Not Pose Significant Risk for Release to Atmosphere	
Uncontrolled Reaction - Adiabatic Conditions			
Uncontrolled Reaction - with External Heat			
Uncontrolled Reaction - Fire Induced		Effluent may be Hazardous Liquid or Two-Phase Material - see Effluent Screening Notes	
Uncontrolled Reaction - Catalyst or Impurity			
Uncontrolled Reaction - Pooling of Reactants			
Uncontrolled Reaction - Mis-Loading			
User Defined Vapor Rate			
User Defined Liquid Rate			

Comments or Warnings:

Effluent Screen is summarized for up to 14 standard scenarios plus 2 user defined scenarios

Criteria not meeting Effluent Screening criteria is noted

A LOPA Scenario Number may be entered to capture scenario where Effluent Screening fails

Figure 5.2: Relief Effluent Screening Report

Relief Effluent Screening for up to 14 standard scenarios and 2 User Defined scenarios are summarized. Input for the LOPA Scenario Number that demonstrates adequate Risk Management for these cases may be entered to complete the documentation requirements. Details are summarized by selecting the specific Scenario.

STEP 4: Select Overfill or Overflow from the available listing. A report, consistent with the Relief Effluent Screening Tool, is shown with details of the specific case selected. Refer to Figure 5.3.

RAST RELIEF EFFLUENT SCREENING
RAST Version 1.1

Equipment Item: **V-101**

Relief Device Identification: **PVRV-101**

Relief Scenario: **Excessive Heat Input - Pool Fire Exposure**

Type of Relief Device: **PVRV**

Discharge Orientation: **Horizontal Assumed**

Chemical Name	Liquid Wt Fract	Vapor Wt Fract	Mol Weight	ERPG-2 (ppm)	ERPG-3 (ppm)	LFL (Vol %)
Acrylonitrile	1.0000	1.0000	53.1	35.0	75.0	3.0
Unspecified Pad Gas			29.0			

Equivalent Values for the Vapor Mixture (Ideal Gas)

	53.1	35.0	75.0	3.0
--	------	------	------	-----

Time Scale Factor: **1.000**

Potential for Liquid or 2-Phase Release	No
Quantity Released during Initial Depressurization (Rupture Disk Only)	kg

Is liquid being vaporized during this scenario?	Yes
Release Duration	1.0000 hr

Estimated Actual or Rated Flowrate	4.94	kg/sec
Estimated Sizing Flowrate	4.94	kg/sec
Temperature at Inlet of Relief Device	80.2	C
Density of Relief Stream at Exit	1.832	kg/m ³
Density of Air at Ambient Temperature (25 C)	1.185	kg/m ³
Pressure of Exiting Relief Vapor	0.0134	cP
Actual Flowrate (exit conditions)	54.8	m/sec
Actual Flowrate (Re = d v ρ / m)	1.9E+06	
Sizing Flowrate (exit conditions)	54.8	m/sec
Sizing Flowrate (Re = d v ρ / m)	1.9E+06	
Max. Time-Scaled ERPG-2 Distance	1027	m
Max. Time-Scaled ERPG-3 Distance	697.3	m
Maximum 0.5 LFL Distance	56.5	m
Maximum Outdoor Ground Level Concentration	13077.9	ppm
Maximum Outdoor Work Area Elevation Concentration	13077.9	ppm
Estimated Conc at Distance to Fence Line and Ground Elevation	27.4	times ERPG-2
Estimated Concentration at Closest Distance to Nearest Elevated Work Area	0.4	times LFL
Estimated Conc at Closest Distance to Elevated Work Area	174.4	times ERPG-3
Estimated Conc at Distance and Elev of Nearest Occupied Building	0.2	times LFL
Estimated Conc at Distance and Elev of Nearest Occupied Building	70.7	times ERPG-3

API 521 Flammability Hazard Analysis

The released vapor will be diluted below the LFL due to jet mixing if the Reynolds number, Re, meets the criterion of the following equation:

$$Re > 1,54 \cdot 10^4 \left(\frac{\rho_j}{\rho_\infty} \right) \quad \text{API 521 5th ed. Eq 22}$$

ρ_j = density of relief vapor

ρ_∞ = density air *

Re is the Reynolds number at the vent outlet.
ρ_j is the density of the gas at the vent outlet;
ρ_∞ is the density of the air.

API 521 Reynolds No Criteria, Re > 15400 (ρ _j /ρ _∞) at Actual	
API 521 Reynolds No Criteria, Re > 15400 (ρ _j /ρ _∞) at Sizing	Yes

First Pass Screen

Additional Risk Evaluation or Effluent Treatment is Suggested - see Effluent Screening Notes

Effluent Screening Notes:

Caution: Concentration at distance and elevation of Occupied Building(s) may be greater than 1 times ERPG-3. Ensure toxic infiltration is addressed.

Concentration is beyond the property limit at an elevation that could impact personnel.

Concentration may not be sufficient to reduce concentration at Unrestricted Personnel Area below 2 times ERPG-3 concentration.

Concentration may not be sufficient to reduce concentration at Unrestricted Personnel Area below 0.25 times LFL.

Figure 5.3: Example of Specific Case Relief Effluent Report

Parameters Specific to Specialized Equipment

Other Equipment Parameters include Replacement Cost & Business Loss in addition to highly specialized parameter such as:

Replacement Cost & Business Loss – Used for determining the Business Loss Consequence.

Drum Oven Volume – is the volume of an oven rather than volume of equipment being evaluated (typically a drum).

High Speed Rotation Equipment? – is used in determining the Probability of Ignition for Solids Handling Equipment. "Yes" implies a Maximum Tip Speed > 9.5 m/sec.

Bellows or Expansion Joint Used? – should be answered "Yes" if appropriate. A "Yes" answer will add the appropriate leakage penalty to the Fire and Explosion Index.

Sight Glass Used? – should be answered "Yes" if appropriate. A "Yes" answer will suggest a potential scenario involving failure of the sight glass and add the appropriate leakage penalty to the Fire and Explosion Index.

Process and Operating Conditions

In addition to the minimum required inputs of Maximum Feed or Flow Rate and Liquid Head within Equipment (for low Operating Pressure), other Process and Operating Information may be needed for various evaluations or reports. Refer to Figure 5.4.

Process Conditions Input

Navigation: << Go To Main Menu | Go To Plant Layout > | < Go To Chemical Data | Go To Reaction Input > | < Go To Equipment Input

Buttons: Save Input to Equipment Table | Clear Input

Equipment Identification:
Storage Tank
Equipment Type: Vessel/Tank
Location: Outdoors

Process Description

Process/Operating Conditions

Ambient Temperature =		C
Inventory Limit (blank is unlimited) =		kg
Liquid Head within Equipment, Δh =	6	m
Limiting Maximum Fill Fraction =		
Limiting Minimum Fill Fraction =		
Maximum Feed Press (gauge) =		bar
Maximum Feed or Flow Rate =	400	Kg/min
Maximum Feed Temperature =		C
Type of Feed (Batch or Continuous)		
Non-Ignitable Atmosphere Maintained?		
Potential for Aerosol or Mist?		
Pad Gas Name =		
Max Pad Gas Pressure (gauge) =		bar
Maximum Pad Gas Rate =		kg/min
Downstream Pressure (gauge) =		bar
Maximum Back Flow Rate =		kg/min
Equipment Vents to ... =		

Summary for Acrylonitrile

Operating Temperature =	25	C
Operating Pressure (gauge) =	0.1	bar
Physical State =	Liquid	
Saturation Temperature =	80.2	C
Contained Mass =	63752	kg
Maximum Contained Mass =	79690	kg
Inventory for Reference =	103690	kg

Operating Procedures

Percent of Time in Operation =	
Frequent Turnaround or Cleanout?	
Centralized Ventilation Shut-Off Bldg 1?	
Centralized Ventilation Shut-Off Bldg 2?	

Review of Operating Procedures for Selected Equipment Item by:

--	--

Use Time-based Release for Equipment Rupture? ☐ sec

Callouts:

- Information on normal process or conditions (points to Equipment Identification)
- Summary of chemical specific information, for reference (points to Summary for Acrylonitrile)
- Time based model may be selected for equipment rupture if appropriate (points to Use Time-based Release for Equipment Rupture?)

Figure 5.4: Additional Process Condition Parameters

Total Inventory –the total quantity of chemical in the process which may be added to the equipment being evaluated. For storage tanks, it would represent a “full” tank plus the quantity within any tank truck, railcar, etc. that could be unloaded into the tank. The difference between Total Inventory and the estimated Maximum Contained Mass is the maximum amount that can be released for an overfill scenario.

Limiting Maximum Fill Fraction –the maximum fill fraction for the equipment used for estimating heat-up time, etc. If blank is assumed 0.9 or 90%.

Limiting Minimum Fill Fraction –the minimum fill fraction for the equipment used for estimating heat-up time, etc. If blank is assumed 0.1 or 10%.

Maximum Feed Pressure (gauge) –the source pressure of material feeding the equipment being evaluated. If the maximum feed pressure is less than the relief device set pressure, an overfill or hydraulic overpressure scenario is not feasible.

Maximum Feed Temperature –the maximum temperature of material feeding the equipment being evaluated.

Type of Feed (Batch or Continuous) –used in determining the most likely Initiating Event for some scenario cases.

Non-Ignitable Atmosphere Maintained? – answer “Yes” if a scenario case for “Loss of Inert or Air Ingress” should be included in the list of potential scenario cases.

Potential for Aerosol or Mist? –the potential for aerosol or mist from splash filling or vigorous agitation/mixing which may increase the probability of ignition for internal deflagration.

Pad Gas Name - used to look up chemical properties of the pad gas. If blank, a molecular weight of 29 is assumed for the pad gas.

Maximum Pad Pressure (gauge) - the source pressure of the pad gas feeding the equipment being evaluated. If the maximum pad gas pressure is greater than the relief device set pressure, an overpressure scenario is considered.

Maximum Pad Gas Rate –the maximum rate of pad gas into the equipment being evaluated. This input is used to estimate the rate of pressure rise for pad gas system failure.

Downstream Pressure (gauge) –the maximum pressure of downstream equipment and should include pressure due to change in elevation if appropriate. If this pressure is greater than the operating pressure, a backflow scenario is considered.

Maximum Back Flow Rate –the maximum back flow rate that could occur and used to estimate release rate for back flow scenarios.

Equipment Vents to... –used in identification of scenario cases. Options include: Immediate Area, Source/Vapor Balance, Scrubber System, Fired Equip (TOX- Flare), Does Not Vent, or Floating Roof Tank.

Operating Procedures

Information relative to selected common Operating Procedures may be input for use in Layers of Protection Analysis (LOPA). Included is:

Percent Time in Operation –used to determine if a Time at Risk Enabling Factor may be used in LOPA.

Frequent Turnaround or Cleanout? – answer “Yes” if frequent cleanout of equipment is needed for batch operations.

Effective Ventilation Shut-Off Building 1? - answer “Yes” if appropriate which will suggest a potential LOPA credit for toxic infiltration scenarios.

Effective Ventilation Shut-Off Building 2? - answer “Yes” if appropriate which will suggest a potential LOPA credit for toxic infiltration scenarios.

Use Time-based Release for Equipment Rupture? - answer “Yes” if a time-based model is to be used for Equipment Rupture outcome. The release duration in seconds also needs to be entered (to a maximum of 600 seconds). If left “blank” or “No” is entered, a Rupture (or Instantaneous) Release model will be used. For very rapid events such as explosions in pressure vessels, detonations, or very rapid runaway reactions, the Rupture Release model should be used. For slower events such as the rupture of a weak seam roof or the base of a low-pressure vessel lifting from its foundations, a time-based model over an “appropriate” length of time may be more accurate.

Plant Layout Information

In addition to the minimum required inputs of Distance to Property Limit of Fence Line, Distance to Occupied Building and Number of Building Occupants, other Plant Layout Information may be needed for various evaluations or reports. Refer to Figure 5.5.

Plant Layout Input

[<< Go To Main Menu](#)
[Save Input to Equipment Table](#)
[Clear Input](#)
[Go To Reaction Input >](#)

Equipment Identification: V-101
 Equipment Type: Vessel/Tank
 Location: Outdoors

Location Information

Distance to Property Limit or Fence Line =	180	m
Furthest Distance to Fence Line (> 180 m) =		m
Max. Onsite Outdoor Population Density		people/m ²
Personnel Routinely in Immediate Area?		
Distance to end of Offsite Zone 1		m
Offsite Population Density within Zone 1		people/m ²
Offsite Population Density Beyond Zone 1		people/m ²
Effective Egress from Work Area?		
Access for Emergency Services?		
Degree of Equipment Congestion in Area?		
Containment or Dike Surface Area =		sq m
Failure for Vessel Rupture?		
Reason for Drainage/Indirect?		
Fired Equipment =		
Quantities in Immediate Area		kg
Quantity of Flammables in Adjacent Area		kg
Adjacent Containment or Dike Surface Area =		sq m
Automated EBVs to limit spill quantity?		

Enclosed Process Area Data

Enclosed Process Volume =		cu m
Enclosed Process Ventilation =		changes/hr
No. Enclosed Area Personnel =		

Layout Description

Nearest occupied building information

Occupied Building Data

Occupied Building 1 Name =		
Distance to Occupied Bldg 1 or Area =	70	m
Elevation of Occ Bldg 1 Ventilation Inlet =		
Distance to Center of Occupied Bldg 1 =		
Occupied Bldg Type =		
Occupied Bldg Ventilation Rate =		
Number of Building Occupants =	3	
Occ Bldg 2 in Same Wind Direction?		
Occupied Building 2 Name =		
Distance to Occupied Bldg 2		m
Elevation of Occ Bldg 2 Ventilation Inlet =		
Distance to Center of Occ Bldg 2 =		
Occupied Bldg 2 Type =		
Occupied Bldg 2 Ventilation Rate =		
Number of Occupants Bldg 2 =		

Information for a second occupied building, if appropriate

Information regarding environmental impacts

Environmental Inputs

Spills to Soil Require Remediation?		
Potential for Water Contamination?		
High Population Downstream of Facility?		

Note that Environmental Scenarios are Excluded

Information for the specific equipment location

Information for the enclosed process area if indoors

Figure 5.5: Additional Plant Layout Parameters

Specific Equipment Location Information

Furthest Distance to Fence Line or Effect Zone - used in estimating the maximum area of the effect zone to be used with the entered population density for outdoor toxic or flammable releases. Few people would be on-site beyond this distance.

Maximum Onsite Outdoor Population Density – represents the number of people who could be outdoors divided by the outdoor process area. A default of 0.0002 people/m² is used if this input is blank (which is an average value for many industrial facilities).

Personnel Routinely in Immediate Area? answer “Yes” if operator attendance is required, equipment location is near a walkway, etc. The default is “Yes” if the input is blank.

Distance to end of Offsite Zone 1 - two offsite population densities may be used in the analysis: beyond the Property Limit distance to the end of Zone 1 distance, and beyond Zone 1 distance.

Offsite Population Density within Zone 1 – offsite population density immediately beyond the Property Limit distance to the Zone 1 distance. If blank, the default offsite population density will be used. Typically, “Sparsely” populated is 0.0002 to 0.0005 people/m², “Moderately” populated is 0.001 to 0.002 people/m² and “Densely” populated is 0.003 to 0.005 people/m².

Offsite Population Density Beyond Zone 1 - offsite population density immediately beyond the Zone 1 distance. If blank, the default offsite population density will be used.

Effective Egress from Work Area? - answer “Yes” if personnel would not be trapped on an elevated work platform and have an unobstructed path for escape purposes.

Access for Emergency Services? – is used as an input for Fire and Explosion Index. Options include: Adequate, Inadequate, and Partially Adequate.

Degree of Equipment Congestion in Area? – is used in determination of explosion energy. Options include: Low, Medium, and High.

Containment or Dike Area - is the surface area a spill would be confined to. If this input is blank, spills are assumed as not confined.

Consider Dike or Bund Failure for Vessel Rupture? – answer “Yes” to assume a “wave” of liquid spills over the dike wall or the dike wall fails for rupture cases.

Credit Fire Heat Adsorption for Drainage/Indirect? - answer “Yes” if drainage is such that fire heat is not directly under the equipment. “Yes” will reduce the NFPA fire heat (with remote impoundment) input by 50% or use a lower correlating coefficient in API fire heat input.

Distance to Nearest Fired Equipment – is used in determining factors with the Fire and Explosion Index and probability of explosion with LOPA. Options include: No, within 10 m (33 ft), within 20 m (65 ft), within 30 m (100 ft), and greater than 30 m (100 ft).

Quantity of "Other" Flammable Liquids in Area – is the mass of flammable material in nearby equipment that provide fuel for a pool fire. This quantity does not include the contents of the equipment being evaluated.

Quantity of "Other" Flammable Liquids in Adjacent Area – is the mass of flammable material in equipment or vessels in an adjacent area that provide fuel for a pool fire.

Adjacent Containment Surface Area - is the surface area a spill would be confined to within the adjacent area.

Automated EBV to limit spill quantity? - answer “Yes” if appropriate. This input is used within the Fire and Explosion Index.

Enclosed Process Area Information

Enclosed Process Volume – is the volume of the enclosed process area in which the equipment is located. If the equipment is located in a room that is isolated from the other areas of the process building, only the room volume should be entered.

Enclosed Process Ventilation –represents the mechanical ventilation rate of the Process Area. This input is used to estimate concentration within the enclosed process area to determine if mechanical ventilation may represent a possible “credit” in LOPA. This input does not impact LOPA Consequence.

Number of Enclosed Area Personnel – represents the number of people who could be within the enclosed process area who may be impacted. A default of two people is assumed if this input is blank.

Occupied Building Information

Identical inputs for up to two Occupied Buildings may be used. If a second building is to be included in the evaluation, the question: Occupied Building 2 in Same Wind Direction? should be answered either “Yes” or “No” as appropriate. Refer to Figure 5.6 for an example.

Depiction of Occupied Buildings in the same Wind Direction




Figure 5.6: Depiction of 2 Occupied Buildings Downwind

Occupied Building Name – is a text field used for reference by the evaluation team.

Distance to Occupied Building or Area? – is a minimum required input and represents the distance to the nearest edge of the Occupied Building or Occupied Area within an Enclosed Process Building.

Elevation of Occupied Building Ventilation – is the elevation of the ventilation inlet and often corresponds to the roof elevation.

Distance to Center of Occupied Building – is used in estimation of explosion damage to the building. This value should always be greater than the Distance to Occupied Building. A default of Distance to Occupied Building is used if this input is blank.

Occupied Building Type – is used to determine explosion damage to the Occupied Building. Options include: “Low Strength” which represents a low strength portable building, or “Typical Construction” representing typical residential or industry construction. Impacts to high strength or blast resistant buildings are not considered in RAST screening evaluation.

Occupied Building Ventilation Rate – is used in estimation of indoor concentration resulting from toxic infiltration. This input does not impact LOPA Consequence.

Centralized Ventilation Shut-Off? - answer “Yes” if appropriate which will suggest a potential LOPA credit.

Number of Building Occupants – is a minimum required input and should represent a daytime maximum building occupancy

Environmental Inputs

RAST contains a very approximate table for estimating Environmental Consequences. Both spills to soil and spills to a waterway are considered.

Spills to Soil Require Remediation? – answer “Yes” if using this Environmental Consequence Table for estimating the Tolerable Frequency for spills to soil. The consequence will be based on the NFPA Health ranking in addition to the quantity spilled.

Potential for Water Contamination - answer “Yes” if using this Environmental Consequence Table for estimating the Tolerable Frequency for spills to a waterway. The consequence will be estimated based on the entered Aquatic toxicity (harmful, toxic, and very toxic) in addition to the quantity spilled.

High Population Downstream of Facility? – answer “Yes” if a city or other highly populated area is immediately downstream of the spill. “Yes” will increase the consequence category (or Tolerable Frequency) by 1 for water contamination.

Estimation of Number of People Impacted from Plant Layout Information within RAST

It must be noted that estimating the number of people impacted for a scenario is extremely inaccurate. Often consequence severity is predicted significantly higher or significantly less than actual historical incidents. It is the intent of RAST to provide estimates primarily for consistency among Hazard Identification and Risk Analysis studies and for comparison.

When using the option for *Consequence Severity without Direct Reference to Human Harm*, inherent to the correlation of hazard distance or concentration divided by Level of Concern is a population density or number of building occupants. For situations where the population density is significantly greater or less than inherent to the correlation, or where the number of building occupants is significantly greater or less than inherent to the correlation; adjustments or Conditional Modifiers may be needed in Risk Analysis.

The location references of the various RAST inputs are depicted in Figure 5.7.

The Maximum Number of On-Site Outdoor Personnel Impacted is estimated as:

- Person Routinely in the Immediate Area
- + Person at Elevated Work Location
- + Effect Zone “Footprint” Area times Maximum Population Density

Note that the area of the Effect Zone is estimated as a “pie shaped” circle segment of 0.3 times Distance². The Vapor Cloud distance to a concentration of ½ the Lower Flammable Limit (flammable cloud) OR a multiple of ERPG-3 concentration (toxic cloud) at ground elevation will be used unless limited by entering a maximum “Distance to Furthest Fence Line or On-Site Personnel”.

The number of people impacted within Occupied Buildings is estimated as the sum of “Vulnerability” (or fraction of building occupants impacted) times Maximum Number of Occupants for each building. For outdoor release scenarios, the number of outdoor on-site personnel impacted is added to those impacted within occupied building to obtain a total number of people impacted.




Figure 5.7: RAST Input Referenced Locations

For example: Consider a flammable release with an estimated distance to $\frac{1}{2}$ LFL concentration of 250 m, a maximum population density of 0.0002 people/m² within the effect zone, personnel noted as “routinely in the immediate area”, concentration at the location of the elevated work area exceeding $\frac{1}{2}$ LFL, and one building with 10 occupants within the blast wave of the resulting vapor cloud explosion such that the occupant vulnerability is 50%. The total number of people impacted for this scenario would be estimated as:

$$\begin{aligned}
 & 1 \text{ person within the immediate area} \\
 & + 1 \text{ person within the elevated work area} \\
 & + 0.3 (250 \text{ m})^2 (0.0002 \text{ people/m}^2) = 3.8 \text{ people within the effect zone} \\
 & + 10 (0.5) = 5 \text{ people within the occupied building} \\
 & = 10.8 \text{ total people impacted}
 \end{aligned}$$

Additional information for estimation of effect zones and toxic or explosion damage vulnerability of building occupants is found in the training materials for Chemical Hazard Engineering Fundamentals (CHEF).

Pool Fire Evaluation Worksheet

Excessive Heat from Pool Fire is a common scenario case for Hazard Evaluation and Pressure Relief Design. The Pool Fire Evaluation worksheet provides a summary of key pool fire information for any Equipment Item. This summary contains an estimate of the fire heat adsorption rate and the pool fire duration. In addition, the times for heating to the saturation temperature at the relief device set pressure, heating to the saturation temperature at the rupture or catastrophic failure pressure, heating to the reaction temperature of no return are estimated. Figures 5.8, 5.9 & 5.10 depict the Pool Fire Evaluation worksheet.

<< Go To Main Menu

Save Input to Equipment Table

Clear Input This Works

Reviewed by:

Review Date:

Equipment Item

Equipment Type

Vessel/Tank Considered as "Storage"?

Location

Vessel or Equipment Volume

Vessel or Equipment Maximum Wetted Mass

Maximum Allowable Working Pressure

Vessel or Equipment Orientation

Maximum Wetted Surface Area

Equipment Elevation to Surface

Credit Fireproof Insulation?

Credit Drainage to Reduce Fire Heat rate?

Containment or Dike Surface Area

Adjacent Containment or Dike Surface Area

Quantity of "Other" Flammables in Immediate Area

Quantity of Flammables in Adjacent Area

Operating Temperature

Reaction Temperature of No Return (if applicable)

Temperature at Relief Set Pressure

Temperature at Failure or Burst Pressure

Based on Catastrophic Failure at 1.5*MAWP

Potential for Two-Phase Release. Chum-Turbulent Void Fraction of 0.21

Liquid Density of Other Flammable Material

V-101

Vessel/Tank

Outdoors

100.0

0.20

100.64

1.2

25.0

176.6

80.2

85.7

m³

Kg

bar(g)

m²

m

m²

m²

kg

kg

C

C

C

C

g/cc or Sp. Gravity

Figure 5.8: Pool Fire Evaluation Worksheet Part 1

Pool Fire Evaluation Worksheet

Pool fire heat adsorption estimate based on NFPA or API methods which are based on Low Pressure, Storage or Process Vessels

Fire Heat Adsorption Summary for Storage or Low Pressure Tank

QFire = 963400 (1083 sq ft)^{0.338}
 = **1.02E+07** BTU/hr or **715.5** Kcal/sec
 per API 2000 or NFPA 30 for Storage or Low Pressure Tank

Maximum Fire Heat Adsorption (without drainage) = **715.5** Kcal/sec

Maximum Fire Duration based on Self Leak Rate and Pool Area = $2 \cdot Vol^{2/3}$:

Area of Burning Pool for Fully Engulfed = **43.15** m²
 Leak Rate for Fully Engulfed = **2.07** Kg/sec
 Maximum Contained Mass = **63752** Kg
 Maximum Fire Duration = **513.23** min

Pool fire duration based on:

- Self-leakage
- Leakage within a diked area
- Containment surface area
- Adjacent containment surface area

Maximum Fire Duration based on Leak of Other Flammables in Immediate Area and Pool Area = $2 \cdot Vol^{2/3}$:

Immediate Area Flammable Mass = **63752** Kg
 Leak Rate for Fully Engulfed = **2.08** Kg/sec
 Maximum Fire Duration = **513.23** min

Maximum Fire Duration based on Containment Surface Area:

Maximum Flammable Inventory = **63752** Kg
 Maximum Depth within Confined Area = **1.0** m
 Fire Duration = **513.23** min

Maximum Indirect Fire Duration based on Adjacent Containment Surface Area:

Maximum Depth within Confined Area = **1.0** m
 Fire Duration = **513.23** min

Figure 5.9: Pool Fire Evaluation Worksheet Part 2

Pool Fire Evaluation Worksheet

Fire Sizing Vent Rate = $Q_{Fire} / \text{Heat of Vaporization}$:

$Q_{Fire} / \Delta H_v = 5.13 \text{ Kg/sec}$

Heat-up Times for 10 % Full Vessel or Equipment =
 (with Heat Transfer Area = 0.21 times Maximum Wetted Area)

Mass of Contents at 10% Full =	7969.0	Kg	
Average Mass for Self Leakage =	39845.0	Kg	
at 0.5100 Kcal/Kg C			
Wetted Mass of Equipment at 10 % Full =		Kg	
Average Wetted Equip Mass for Self Leakage =		Kg	
at 0.1000 Kcal/Kg C			
Heat Adsorption at 10 % Full =	150.3	Kcal/sec	
Average Heat Adsorption for Self Leakage =	472.1	Kcal/sec	
Indirect Heat Adsorption at 10 % Full =		Kcal/sec	

	<u>Heat-up Times</u>	<u>Basis</u>
Time to Temperature of No Return =	min	Direct
Time to Temperature at Relief (non-reactive) =	39.01 min	Self Leakage
Time to Temperature at Failure (non-reactive) =	42.70 min	Self Leakage

Contents Reach Relief Conditions at Pool Fire Duration

Contents Reach Failure or Rupture Conditions at Pool Fire Duration

Estimated Pool Fire Thermal Radiation Distances based on dike surface area of 0 m², typical burning rate of 0.05 kg/m² s, 42000 kJ/kg heat of combustion and 0.35 fraction of combustion energy radiated.

Thermal Radiation Level,

4
12.5
37.5

kw/m²

Distance from dike wall, m

Vessel or equipment heat up time based on:

- Self-leakage
- Leakage within a diked area
- Containment surface area
- Adjacent containment

Figure 5.10: Pool Fire Evaluation Worksheet Part 3

Additional information associated with Pool Fire Evaluation is covered in the Layers of Protection Analysis section of this document under Pool Fire Frequency Evaluation.

Workbook Notes and Setting Units to be Displayed on the Scenario Results worksheet

A Workbook Notes tab is available to capture notes from the LOPA team that apply to the entire workbook. The Basis for Analysis is also summarized on the worksheet including the values for Ambient Temperature, Wind Speed, and Onsite Population Density.

Standard Units to be displayed for all scenarios in the Scenario Results worksheet may also be entered at the bottom right of this worksheet. If not entered, units will be displayed as those entered by the User for the various inputs. For example, the units for distance will be that entered by the user for "Distance to Property Limit or Fence Line" on the Plant Layout Worksheet (which may be different for each equipment entry). Entering Standard Reporting Units on the Workbook Notes worksheet will ensure that the units for *all* scenarios in the Scenario Results worksheet are the same. Refer to Figure 5.11.

<< Go To Main Menu

RAST

Risk Analysis Screening Tools (v.3)

Notes for the entire workbook
(versus notes for a specific piece of
equipment) may be entered

Workbook Reviewed by:
 Review Date:

Notes or Comments:

Basis for Analysis

Dispersion Parameters:

Ambient Temperature Default	25	C
Maximum Release Duration Limit	3600	sec
Day Wind Speed	3	m/sec
Night Wind Speed	1.5	
Day Atmospheric Stability Class	Class D	
Night Atmospheric Stability Class	Class F	
Surface Roughness	Industrial	
Fraction Night Weather for Offsite	0.2	
Indoor Wind Speed Equivalent	0.1	m/sec
Daytime Solar Radiation to Outdoor Liquid Pool	0.5	Kw/m ²
Occupied Building Ventilation Default	3	
Enclosed Process Ventilation Default	0.5	
Fraction Indoor/Outdoor Concentration Limit	0.5	
Averaging Time Correction for Flammable	2	

Note: 10 Minutes Averaging Time for Toxics

Toxicity Parameters:

Inhalation Toxic Screening Limit	1000	ppm
Default Toxic Time-Scale Exponent (1/n)	0.5	
Default LC ₅₀ /ERPG-3	2	
Default LC ₅₀ /ERPG-3	5	

Thermal Parameters:

High Temp Thermal Burns Screening - Liquid	55	C
Low Temp Thermal Burns Screening - Liquid	-23	C
High Temp Thermal Burns Screening - Vapor	80	C
Thermal Radiation Screening Limit	4	Kw/sq m

Explosion/Fire Parameters:

Fraction LFL for Flash Fire Severe Impact	0.5	
Vapor Cloud Explosion Limiting Quantity	100	Kg
Flash/Jet Fire Limiting Rate	0.2	Kg/sec
Pool Fire Limiting Quantity	100	Kg
Fraction of LFL Limit for Building Explosion	1	
Fraction Combustible Consumed in Pool Fire	0.9	
Direct Blast Impact Overpressure Screening	10	psi

Other Parameters:

Maximum Operating Fill Fraction	0.8	
Minimum Operating Fill Fraction	0.2	
Convective Heat Loss Coeff-Insulated	0.0005	Kw/sq m C
Convective Heat Loss Coeff-Uninsulated	0.01	Kw/sq m C
Hazard Distance Limit for Severe Impact	3	m

Equipment Failure Limits:

Multiple of MAWP Not-Anchored API	1.1	
Multiple of MAWP Anchored API Tank	1.5	
Multiple of MAWP Pressure for ASME Vessel	2	
Default Failure Temperature	600	C

Population Parameters:

Default Offsite Population Density	1500	people/km ²
Default Onsite Outdoor Population Density	200	people/km ²
Day Fraction Population Outdoors	0.1	
Night Fraction Population Outdoors	0.1	
Indoor Population Limit	2	people

Consequence Severity for Human Harm Based on:

Estimated Number of People Impacted

Standard Reporting Units for Scenario Results

Distance	
Hole Diameter	
Mass	
Flow	
Area	
Pressure	
Equipment Volume	

Show Possible IPLs

Hide Possible IPLs

Method selected for human harm
consequence severity. Options
are: "Estimated Number of People
Impacted" or "Hazard Distance"

Figure 5.11: Workbook Notes Worksheet

On the right-hand side of the Workbook Notes worksheet is a display of the specific Risk Matrix for use in RAST Hazard Analysis. It is suggested that a representative of the company (referred as a RAST "Technical Administrator") update the risk criteria and risk matrix to reflect the company's risk tolerance criteria. The

Technical Administrator should also update the number of severity and frequency levels for consistency of users of the RAST within the company. The human harm criteria may be expressed as number of people severely impacted (the current default) or by the characteristics of the chemical release such as distance from the release point to a hazardous concentration. The default parameters provided in RAST should be considered “examples” as CCPS does not endorse any specific risk criteria.




Figure 5.12: Workbook Notes Worksheet – Risk Matrix

6. SCENARIO DEVELOPMENT

Fortunately, the number of catastrophic incidents is small relative to the total number of incidents or near misses each year. Those incidents with extreme consequences are usually associated with a low frequency or probability.

Fortunately, not everyone personally experiences a catastrophic incident during their career. This may present a challenge in appreciating which potential scenarios are credible. This section covers:

- How Scenarios are developed
- Understanding of RAST Library of common Scenarios
- How to enter User Defined Scenarios

Scenario Definition

A Scenario represents an unplanned sequence of events leading to a loss event with undesired consequence (Figure 6.1).




Figure 6.1 Schematic of a scenario

- **Event** – An occurrence involving a process that is caused by equipment performance or human action or by an occurrence external to the process.
- **Event Sequence** – A specific, unplanned series of events composed of an initiating event and intermediate events that may lead to an incident.
- **Loss Event** – Point in time in an abnormal situation when an irreversible physical event occurs that has the potential for loss and harm impacts. Examples include release of a hazardous material, ignition of flammable vapors or ignitable dust cloud, and over-pressurization rupture of a tank or vessel. An incident might involve more than one loss event, such as a flammable liquid spill (first loss event) followed by ignition of a flash fire and pool fire (second loss event) that heats up an adjacent vessel and its contents to the point of rupture (third loss event). Generally synonymous with hazardous event.
- **Initiating Event (Initiating Cause)** – The operational error, mechanical failure, or external event or agency that is the first event in an incident sequence and marks the transition from a normal situation to an abnormal situation.
- **Incident Outcome** - The physical manifestation of the incident: for toxic materials, the incident outcome is a toxic release, while for flammable materials; the incident outcome could be a boiling liquid expanding vapor explosion (BLEVE), flash fire, vapor cloud explosion (VCE), etc. For example, the incident outcome for a leak of chlorine from a railcar is a toxic release.

- **Consequence** - The undesirable result of a loss event, usually measured in health and safety effects, environmental impacts, loss of property, and business interruption costs.
- **Enabling Condition** - A condition that is not a failure, error or a protection layer but makes it possible for an event sequence to proceed to a consequence of concern. It consists of a condition or operating phase that does not directly cause the scenario, but that must be present or active in order for the scenario to proceed to a loss event; expressed as a dimensionless probability.

Hazard Evaluation and Scenario Identification in RAST

Hazard Evaluation begins on the Scenario List worksheet. The date(s) and participants involved in the evaluation of each equipment item is captured on the Main Menu in addition to the type of equipment and location (Figure 6.2).

The screenshot shows a yellow background form with the following fields and annotations:

- Session Date:** [Text box]
- Participants:** [Text box]
- Equipment Identification =** [Text box containing "V-101"]
- Equipment Type =** [Text box containing "Vessel/Tank"]
- Equipment Location =** [Text box containing "Outdoors"]
- Data Entry Status or Notes:** [Text box]
- Plant Section or Sub-Area:** [Text box]
- P&ID Number:** [Text box]

Two callout boxes with orange borders provide additional context:

- Entry of Evaluation Date(s) and Session Participants:** This box has arrows pointing to the "Session Date" and "Participants" fields.
- Selection of Equipment Type and Location:** This box has arrows pointing to the "Equipment Type" and "Equipment Location" fields.

Figure 6.2 Location of Entries for Evaluation Team Participants and Date

Once the inputs have been completed (Chemical Data, Equipment Input, Process Conditions, Plant Layout and Reaction Input as appropriate), use the Scenario Identification macro button to go to the Scenario List (Figure 6.3). On this worksheet, the evaluation team may review suggested scenarios, add additional scenarios, and capture existing safeguards and recommendations. Note that any inputs made on this worksheet must "Update Input This Worksheet" to temporarily store this information which will ultimately be saved on the Equipment Table with the command "Save Input to Equipment Table" from any of the input worksheets.

Scenarios that the team enters "Yes" for Further Analysis may be exported as "Cause-Consequence pairs" for more detailed Risk Analysis in addition to any "User" defined scenarios (Figure 6.3). Note that scenarios that are not selected will not appear on the Scenario Results worksheet for detailed analysis using Layer of Protection Analysis.

Following “Update Input this Worksheet” use Save Input to Equipment Table to save all information from all input worksheets

Temporarily Store
Inputs from this
Worksheet

[illegible]

Figure 6.3 Location of Entries for Saving Evaluation Team Scenario Inputs

Scenario Development in RAST

Scenarios are developed within RAST based on common process upsets (or deviations of a process parameter from the design intent) for a specific *Type of Equipment* and *Chemical* service. Scenario Cases contain an Initiating Event, a single Loss Event and an Incident Outcome. A Scenario Type may also be used to provide a key phrase to describe the overall event sequence.

Initiating Event + Loss Event + Incident Outcome

For example, Equipment Rupture (Loss Event) caused by a Process Control Failure (Initiating Event) resulting in a potential Off-Site Toxic Release (Incident Outcome) represents a Scenario that might occur if the maximum pressure exceeds the design limits of the equipment. *This event sequence or Scenario Type can be described as Pressure Damage, as well, to indicate a deviation of pressure from the design intent.*

Equipment Types in RAST

The general Equipment Types include:

Chemical Processing Equipment

- Absorber/Scrubber
- Compressor or Blower
- Distillation
- Drum/IBC Handling
- Extraction
- Filter/Centrifuge
- Heat Exchanger
- Piping
- Pump
- Stirred Reactor/Crystallizer
- Tank Truck/Rail Car/Tote
- Turbine or Gas Expander
- Vessel/Tank

Fired Equipment (shown in green text)

- Fired Equipment - Combustion Unit
- Fired Equipment - Fire Tube Combustion Unit
- Fired Equipment - Incinerator or TTU
- Fired Equipment – Flare
- Fired Equipment - Vapor Quench
- Fired Equipment - Process Heater

Solids Handling Equipment (shown in red text)

- Bag/Pak Dumping (Solids)
- Blender/Mixer (Solids)
- Conveyor-Mechanical (Solids)
- Conveyor-Pneumatic (Solids)
- Dryer-Mechanical (Solids)
- Dryer-Spray or Fluid Bed (Solids)
- Dust Filter or Bag house (Solids)
- Hopper Storage (Solids)
- Mill/Grinder (Solids)
- Screener or Sieve (Solids)

Specialized Equipment

- Drum Oven
- USER DEFINED - EQUIPMENT

Initiating Events in RAST

Initially, the most likely Initiating Events are identified at a very high level. These will be defined in more detail ("how could this happen in my plant") after completing the Consequence Analysis. These are broadly categorized as: Control System Failures, Human Error, or Mechanical Failures. These broad categories are broken into greater detail for *Initiating Events* listed in RAST as:

Control System Failures

- BPCS Instrument Loop Failure

Human Error

- Human Failure Action more than once per quarter
- Human Failure Action once per quarter or less
- 3rd Party Intervention

Mechanical Failures

- Mechanical Failure (e.g. leading to spark or hot spot within equipment)
- Heat Exchanger Tube Leak < 100 tubes
- Heat Exchanger Tube Leak > 100 tubes
- Unloading/Loading Hose Failure
- Mechanical Loading Arm Failure
- Sight Glass Failure
- Pump (blower, compressor, etc.) Failure Loss of Flow
- Regulator Failure
- Single Mechanical Seal Failure
- Double Mechanical Seal Failure
- Canned/Magnetic Drive Pump Failure
- General Utility Failure
- Natural Disaster (Storm, Earthquake, etc.)

Other Initiating Events categorized by Failure Frequency Factors (Initialing Event Factors (IEF))

- IEF=0 (1/year) as determined by Fault Tree or Detailed Analysis
- IEF=1 (1/10 or 10^{-1} /year) as determined by Fault Tree or Detailed Analysis
- IEF=2 (1/100 or 10^{-2} /year) as determined by Fault Tree or Detailed Analysis
- IEF=3 (1/1,000 or 10^{-3} /year) as determined by Fault Tree or Detailed Analysis
- IEF=4 (1/10,000 or 10^{-4} /year) as determined by Fault Tree or Detailed Analysis
- IEF=5 4 (1/100,000 or 10^{-5} /year) as determined by Fault Tree or Detailed Analysis

Loss Event Categories in RAST

Loss Events are typically associated with “unintended release of a hazardous material or energy”. *Loss Event* in RAST are categorized by the type of estimate used to determine release rate.

☐ Hole Size release.

Standardized hole sizes simplify the screening analysis, for example:

- 5 to 15 mm to represent gasket failure.

- 100 mm to full bore diameter to represent pipe or equipment nozzle failure.

☐ Overflow or other Material Balance released such that rate estimated from feed or fill rate.

☐ Excessive Heat such that vapor release rate estimated from rate of heat input divided by heat of vaporization.

☐ Equipment Rupture as a sudden release of entire equipment contents and reaction or pressure-volume energy.

☐ Equipment Damage represents a loss event requiring repair or replacement of equipment without loss of containment.

These broad categories are broken into greater detail for *Loss Events* listed in RAST as:

Hole Size Categories

- Very Small Hole Size leak represents a 5 mm (3/16 inch) hole leak which may be typical for a valve stem packing small gasket failure.
- Small Hole Size leak represents a standard size which can be used in process upset scenarios. The default setting is ½ inch hole (12.7 mm).
- Mechanical Seal Hole Size leak represents a maximum hole size for pump seal failure. The default setting is ½ inch hole (12.7 mm).
- Gasket Hole Size leak represents a typical hole size for gasket failure. The default setting is a ½ inch hole (12.7 mm).
- Gasket Hole Size Leak (top) represents a gasket leak from the vapor space of a liquid filled vessel by depressurization of the pad gas saturated with the liquid contents
- Medium Hole Size leak is used for Mechanical Integrity scenarios. The default setting is a 25 mm (1 inch) hole.
- Medium Hole Size Leak (top) represents a leak from the vapor space of a liquid filled vessel by depressurization of the pad gas saturated with the liquid contents.
- Full Bore Hole Size leak represents a full-bore pipe or nozzle hole which is common for nozzle failure and pipe rupture.
- Large Hole Size Leak (top) represents a leak from the vapor space of a liquid filled vessel by depressurization of the pad gas saturated with the liquid contents
- Very Large and Extremely Large Hole Size is used for Mechanical Integrity scenarios. The default setting is a 100 mm (4 inch) or 250 mm (10 inch) hole respectively and.
- Very Large and Extremely Large Hole Size (top) represents a leak from the vapor space of a liquid filled vessel by depressurization of the pad gas saturated with the liquid contents.
- Drain or Vent Hole Size represents a hole size entered by the User representing an open drain or vent valve.

- Drain or Vent Hole Size (top) represents a leak from the vapor space of a liquid filled vessel by depressurization of the pad gas saturated with the liquid contents
- Tube Hole Size (Process) represents a hole size entered by the User representing a “full bore” failure of a heat exchanger tube.
- Tube Hole Size (Heat Transfer Fluid) represents a leak of heat transfer fluid for a “full bore” heat exchanger tube failure.
- User Hole Size represents a hole size entered by the User.
- User Hole Size (top) represents a leak from the vapor space of a liquid filled vessel by depressurization of the pad gas saturated with the liquid contents

Overflow and other Material Balance Related Loss Events

- Vent Release is based on a User entered feed rate primarily used for scenarios associated with vent treatment systems such as a scrubber, flare, or thermal oxidizer.
- Pad Gas Release represents a release rate equivalent to the maximum pad gas feed rate.
- Overfill Release represents a release rate equal to the input feed rate, pad gas, or back flow rate. The release is assumed to flow out the relief system if the input feed pressure is greater than the relief set pressure.
- Vapor Displacement from Liquid Filling represents a vapor release rate equal to displacement of the entered liquid feed rate.
- Solids Spill represents a spill of solids equal to the feed rate. The release is assumed to occur from failed nozzle or flexible connection.
- User Defined Release is a release rate entered by the User.

Excessive Heat or other Heat Balance Loss Events

- Vapor Relief Vent - Fire represents a release rate estimated from fire exposure heat rate divided by the heat of vaporization released through the Relief System.
- Vapor Relief Vent – Heat Transfer represents all vapor venting and the rate is calculated as $U A \Delta T$ divided by the heat of vaporization which depends on the temperature difference between the heating media and saturation at relief pressure.
- Vapor Relief Vent – Mechanical Energy represents all vapor venting and the rate is calculated as the heat from mechanical energy divided by the heat of vaporization.
- Vapor Relief Vent - Reaction represents all vapor venting and is the reaction heat rate at relief temperature divided by the heat of vaporization. A check for two-phase flow is used for Reaction cases and vapor created from flash or evaporation of ejected liquid is added to the vapor generated from reaction heat. Venting is assumed to be through the Relief System if the maximum Reaction Pressure exceeds the Relief Set Pressure. Vapor Relief Vent may occur for any of the five primary reaction types: *Adiabatic, External Heat, Fire, Catalytic, Pooling of Reactants, or Mis-Loading of Reactants*.

Equipment Rupture Loss Events

- Equipment Rupture at Operation Temperature represents a release of energy at the burst pressure and normal operating temperature. In addition to the blast wave from the sudden release of pressure, the entire contents of the equipment are assumed to be released “instantaneously” at normal process temperature.

- **Equipment Rupture at Peak Pressure** represents a release of energy at the burst pressure and temperature corresponding to the sum of vapor pressure plus thermal expansion of pad gas. In addition to the blast wave from the sudden release of pressure, the entire contents of the equipment are assumed to be released “instantaneously” at burst pressure saturation temperature.
- **Equipment Rupture at Saturation Temperature** represents a release of energy at the burst pressure and saturation temperature (boiling point at burst pressure). In addition to the blast wave from the sudden release of pressure, the entire contents of the equipment are assumed to be released “instantaneously” at burst pressure saturation temperature.
- **Equipment Rupture at Fire Conditions** represents a release of energy at the burst pressure and saturation temperature. In addition to the blast wave from the sudden release of pressure, the entire contents of the equipment are assumed to be released “instantaneously” at the fire burst pressure saturation temperature.
- **Equipment Rupture – Internal Deflagration** represents a release of energy at a deflagration pressure of roughly 10 atmospheres. In addition to the blast wave from the sudden release of pressure, the entire contents of the equipment are assumed to be released “instantaneously” at normal process temperature.
- **Equipment Rupture – Detonation/Deflagration** represents a release of energy with fragmentation assuming a condensed phase explosive material. In addition to the blast wave from the sudden release of pressure, the entire contents of the equipment are assumed to be released “instantaneously” at burst pressure saturation temperature.

Other Loss Events

- **Equipment Damage** represents an overpressure or high temperature event exceeding the design limits that does not lead to rupture. Equipment Damage may be associated with economic loss or loss of business scenario.
- **Equipment Failure above Design Temperature** represents failure of equipment due to high temperature rather than overpressure. It is analyzed similar to a full-bore hole size leak.
- **Secondary Dust Release** represents the release of dust that could accumulate on beams, rafters, or other surfaces and be later displaced to form a combustible or flammable dust cloud.
- **Flaming Liquid Release** represents a special case used for scenarios associated with Fired Equipment.

Incident Outcome in RAST

Incident Outcome in RAST is based on a generalized Event Tree (Figure 6.4). A single loss event may have several potential outcomes including:

Flammable Outcome:

- ☐ Flash Fire or Fireball
- ☐ Vapor Cloud Explosion
- ☐ Building or Confined Space Explosion

Toxic Outcome:

- ☐ Off-site toxic exposure
- ☐ On-site toxic exposure

- ☐ Toxic infiltration of occupied buildings
- ☐ Chemical Exposure

Other Outcome:

- ☐ Physical Explosion
- ☐ Environmental Incident
- ☐ Equipment Damage or Business Loss




Figure 6.4 Generalized Event Tree for RAST

Example criteria for screening of various Incident Outcome is covered in Chemical Hazards Engineering Fundamentals training. In summary:

- ☐ Flash (or Jet) Fire
Personnel exposure to flammable cloud of a multiple of LFL concentration
- ☐ Vapor Cloud Explosion
1000 Kg flammable (100 Kg for high flame speed) released within 5 minutes
- ☐ Building Explosion
Indoor average concentration exceeds LFL
- ☐ Physical Explosion
1 psi overpressure (0.3 psi for fragmentation) distance exceed a threshold distance
- ☐ Toxic Vapor Release (Indoor, Outdoor)

- Off-site exposure to > ERPG-2 concentration (60 min. basis)
- On-site exposure to > LC-50 concentration for short duration outdoors (5-10 minutes)
- On-site exposure to > ERPG-3 concentration based on 60 min. exposure within an occupied building.

These criteria are managed by the RAST Technical Administrator within hidden worksheets of the RAST spreadsheet.

Development of a Scenario Library

A library of Scenario Cases is available within the RAST tool. The intent of the Library is to provide analysis teams with initial ideas to build upon and not a substitute for performing Hazard Evaluation. Please refer to the CHEF Manual for the PHA Team's approach using the Hazard Evaluation methodology [1, pp. CHEF, Section 6]. Development of scenarios is roughly based on deviations of key process parameters similar to that used for Hazard and Operability Studies (HAZOP) (Figure 6.5).

Guidewords ⇒ Parameter ↓	More	Less	None	Reverse	Part Of	As Well As	Other Than
Flow	High flow	Low flow	No flow	Back flow			Loss of containment
Pressure	High pressure	Low pressure	Vacuum		Partial pressure		
Temperature	High temperature	Low temperature				Cryogenic	
Level	High level	Low level	No level				Loss of containment
Composition State	Additional phase	Loss of phase		Change of state	Wrong concentration	Contaminants	Wrong material
Reaction	High reaction rate	Low reaction rate	No reaction	Reverse action	Incomplete reaction	Side reaction	Wrong reaction

Figure 6.5 Example HAZOP Deviations

Beware of changing inputs such as the Chemical composition or properties, Equipment Type, Maximum Allowable Working Pressure, etc. as the suggested Scenario Type and Scenario Feasibility are dependent on Chemical Data, Equipment and Process Conditions inputs.

Also recognize that the Scenario Library in RAST only identifies the MOST LIKELY Initiating Events. In Layers of Protection Analysis, it is important for the Analysis Team to determine if other Initiating Events are feasible and either Modify the suggested Initiating Event as appropriate or Create additional scenario cases for analysis based on their knowledge of the process.

Scenario Types

Scenario types are used to categorize common parameter deviations and are often related to a specific Type of Equipment. The common parameter deviations help to define the most common Initiating Events for the scenario. Examples are depicted in Figure 6.6.

<u>Example RAST Scenario Type</u>	<u>HAZOP Parameters with Deviation</u>
Accumulation of Untreated Vent or Waste	Composition-Wrong Concentration Flow-High
Blocked-In with Thermal Expansion	Temperature-High Flow-No
Excessive Heat Input - Heat Transfer	Energy-High Pressure-High Temperature-High
Pad Gas or Vapor Flow	Flow-High
Ignitable Headspace	Composition-Wrong Concentration
Overfill, Overflow, or Backflow	Level-High Flow-Backflow
Pressure Damage	Pressure-High
Vacuum Damage	Pressure-Low
Pump Deadhead	Pressure-High Flow-No Temperature-High
Hose or Loading Arm Damage from Movement	Flow-Loss of Containment
Drain or Vent Valve Open	Flow-Loss of Containment
Seal Leak	Flow-Loss of Containment

Figure 6.6 Example HAZOP Initiating Events

In addition, a “feasibility” check of process conditions which allow the event sequences to occur, is also used. Those Scenario Cases where the likelihood of the event sequence is extremely low based on process limitations are not included in the suggested list within RAST (Figure 6.7).


Flammability Flash Point Lower Flammability Limit Minimum Ignition Energy		Fire and Explosion Process Temperature > Flash Point Max Concentration > Lower Flammable Limit Ignition Source > Minimum Ignition Energy
Toxicity Inhalation Toxicity Dermal Toxicity Aquatic Toxicity		Toxicity Max Vapor Concentration > ER Value Potential For Dermal Exposure Potential for Environmental Damage
Reactivity Heat of Reaction Detected Onset Temperature Gas Generation		Reactivity Max Pressure > MAWP or Relief Set Max Process or Heating Temp > Temp of No Return

Figure 6.7 Example HAZOP Initiating Events

RAST Scenario Group and Scenario

A RAST Scenario Group is also similar to a “Bow Tie Diagram”. It represents a single Loss Event with the related Initiating Events and Incident Outcomes. Figure 6.8 represent the generic Bow-Tie utilized in RAST. RAST evaluates essentially all Incident Outcome of interest but initially includes only the most common one or two Initiating Events. If needed, the study team would add additional scenarios representing other Initiating Events of interest prior to selecting scenarios for Layers of Protection Analysis.




Figure 6.8 Generic Bow Tie diagram used in RAST

RAST Scenario Types

The *Scenario Type* is also used to “link” Loss Event for a specific Equipment Type and Chemical Service in the Scenario Library. A *Scenario* in RAST represents a specific combination of Equipment Type, Chemical Handled and Loss Event with one of several possible Initiating Events and one of several possible Incident Outcome. Examples of Scenario Type include:

Accumulation of Untreated Vent or Waste is used for Fired Equipment - Incinerator or TTU to represent scenarios where vents are not adequately destroyed with a *Vent Release* to the atmosphere. The most likely Initiating Event is *Basic Process Control System (BPCS) Failure*.

Blocked-In with Thermal Expansion may occur within piping or equipment handling refrigerated liquids, high melting point material that would require tracing, or very long un-insulated pipelines (>100 m) that could be heated by solar radiation. It is assumed that pressure build-up causes a gasket failure of a liquid full system which is not discovered until the subsequent transfer of material through this piping or equipment.

Casing or Containment Failure represents failure of a canned or magnetic drive pump casing caused by an upset, wear, or fatigue.

Connection Failure represents failure of a flexible connection to solids handling equipment resulting in a *Solids Spill*. The typical Initiating Event is *General Mechanical Failure*.

Drain or Vent Valve Open may occur following maintenance activities or during connection or disconnection of transportation equipment (drums, totes, tank trucks, rail cars, etc.). It is assumed that a *Drain Size leak* is most commonly initiated by *Operator Action Failure*.

Excessive Heat Input causes an overpressure event due to high vapor pressure at elevated temperature. It is assumed that this pressure may result in all vapor venting *Release thru Relief System* (if the relief device is adequately sized) or *Equipment Rupture at Saturation* conditions (if the maximum pressure exceeds the burst pressure). Excluding reactive scenarios, there are three specific types that match to a specific Vapor Relief Loss Event:

Excessive Heat Input – Heat Transfer is triggered if vapor pressure at the maximum heating media temperature exceeds the relief set pressure.

Excessive Heat Input – Mechanical Energy is triggered if vapor pressure at a maximum temperature evaluated by a simple equipment heat balance exceeds the relief set pressure.

Excessive Heat Input – Fire is triggered if the chemical handled is flammable or there are other flammable materials in the area. It is assumed that the fire will persist long enough for relief set and equipment burst pressures to be achieved.

Excessive Pad Gas Flow represents a scenario where the release rate equals the feed rate of pad gas or air saturated with process chemicals. It is assumed that a *Release thru Relief System* occurs if the Maximum Inert Pressure exceeds the Relief Set Pressure.

Exhaustion of Scrubbing Media represents a scenario where the scrubbing media become depleted resulting in a Vent Release normally caused by Loss of Composition Control (BPCS Failure).

Flash Back of High Energy Feed is used for Fired Equipment – Incinerator, Thermal Oxidizer or Flare to represent propagation of combustion to upstream equipment resulting in *Equipment Damage*. It is assumed that the most likely Initiating Event is *Basic Process Control System* (BPCS) Failure.

Fuel Accumulation during Light Off is used for Fired Equipment representing a process upset during start-up of the unit resulting in Equipment Damage or Equipment Rupture - Deflagration. It is assumed that the most likely Initiating Event is *Basic Process Control System* (BPCS) Failure.

Fuel Accumulation during Operation is used for Fired Equipment representing a process upset during operation resulting in Equipment Damage or Equipment Rupture - Deflagration. It is assumed that the most likely Initiating Event is *Basic Process Control System* (BPCS) Failure.

Fuel Accumulation while Down is used for Fired Equipment representing leakage of fuel when not in operation resulting in Equipment Damage or Equipment Rupture - Deflagration. It is assumed that the most likely Initiating Event is *Basic Process Control System* (BPCS) Failure.

High Fuel Flow or Energy Content is used for Fired Equipment representing a process upset during normal operation resulting in Equipment Damage or Equipment Rupture - Deflagration. It is assumed that the most likely Initiating Event is *Basic Process Control System* (BPCS) Failure.

High Temperature Failure is used the maximum Feed Temperature exceeds the Design Temperature of the equipment resulting in Equipment Failure above Design Temperature. It is assumed that the most likely Initiating Event is loss of temperature or flow control (BSCS Failure).

Hose or Loading Arm Connection failure may occur during connection or disconnection of transportation equipment (totes, tank trucks, rail cars, etc.). It is assumed that a *Small Hole Size Leak* (gasket failure) is most commonly initiated by Operator Action Failure.

Hose or Loading Arm Damage from Movement represents leakage from piping caused by movement of a transport vehicle while connected. The potential for a Large Hole Size Leak is assumed to be most commonly initiated by Third Party Intervention.

Hydraulic Surge may occur due to the sudden change in fluid momentum in long pipelines if valves are closed too quickly (or during start-up of a pump).

Ignitable Headspace may potentially result in an internal deflagration and *Equipment Rupture – Deflagration* if the chemical handled is greater than 5 °C above the flash point. It is assumed that the peak deflagration pressure reaches 10 atmospheres which in turn assumes ignition at atmospheric pressure and may exceed the burst pressure for some equipment.

Liquid in Vapor Feed represents a process upset associated with the feed to a Flare resulting in Flaming Liquid hazards or Equipment Damage. It is assumed that the most likely Initiating Event is *Basic Process Control System (BPCS) Failure*.

Loss of Flow – Absorber or Scrubber represents a scenario where vapor feed is not treated but assumed a *Release thru Vent System* at the feed rate. It is triggered if the physical state of the feed stream is “vapor” for *Equipment* that is Absorber or Scrubber. It is assumed that the most likely Initiating Event is *Basic Process Control System (BPCS) Failure*.

Loss of Flow or Level - Fired Equipment represents a process upset where quench equipment or a process heater may see excessively high temperature with Equipment Damage or Rupture at Saturation Conditions. It is assumed that the most likely Initiating Events include *Pump Failure* or *Basic Process Control System (BPCS) Failure*.

Loss of Pilot or Ignition is used for Fired Equipment – Flare to represent loss of flame during operation with *Release through Vent System* of untreated material.

Loss of Vacuum - Thermal Oxidizer used for Fired Equipment – Incinerator or TTU to represent loss of vacuum during operation with *Release through Vent System* of untreated material.

Low Temperature Embrittlement represents the potential for material of construction to become brittle at low temperature resulting in fracture upon stress or thermal shock. It is assumed that the most likely Initiating Event is Human Error allowing evaporative cooling of low boiling chemicals in preparation for maintenance with subsequent full-bore pipe or equipment nozzle failure (Large Hole Size Leak).

Mechanical Integrity Failure represents a piping or equipment leak caused by corrosion, wear or fatigue. Hole sizes include *Very Small, Medium, Very Large* and *Extremely Large* with failure frequency dependent on the length of piping.

Movement of Flammable Liquid or Mist represents the potential for electrostatic build-up during movement of flammable liquids such as transport or mixing resulting in *Equipment Rupture – Deflagration*. It is assumed that the peak deflagration pressure reaches 10 atmospheres which assumes ignition at atmospheric pressure and may exceed the burst pressure for some equipment.

Overflow or Overfill, and *Overflow or Backflow* represents a release equal to the feed rate (or back flow rate) of process chemical if sufficient Inventory is available. It is assumed a *Release thru Relief System* if the peak pressure exceeds the relief set pressure.

Overflow - Foam or Entrainment is a type of Overflow or Backflow scenario for equipment handling vapor/liquid mixtures such as Distillation.

Overflow - Plugging or Freezing is a type of Overflow or Backflow scenario for equipment containing material that may easily plug or freeze.

Physical Damage or Puncture represents leakage from piping caused by impact from lifts or vehicle collisions. The potential for a Large Hole Size Leak is assumed to be most commonly initiated by Third Party Intervention.

Piping or Equipment Leak - Small is a general scenario type for leaks of mechanical loading arm, sight glass or other small equipment. A Small Hole size is used as the Loss Event.

Piping or Equipment LOPC – Large is a *Full-Bore Hole Size Leak* loss event resulting from a *Hose Failure, Sight Glass Failure or Mechanical Failure due to vibration*.

Plugged or Frozen Vent Line is used for Fired Equipment – Flare resulting in *Equipment Damage*. The most likely Initiating Event is assumed to be *Loss of Utilities*.

Pressure Damage is a broad category of scenario for solids handling equipment that assumes a *Solids Spill* if the peak pressure exceeds MAWP. If the peak pressure exceeds the burst pressure, *Rupture at Operating Temperature* is the loss event selected.

Propagation of Flame or Burning Ember is used in Solids Handling scenarios to represent an upset in an upstream equipment item that could ignite dust downstream.

Pump Deadhead is an event where one or both of the suction and discharge valves are closed while the pump or compressor is running. It is assumed that heat and pressure build-up result in *Equipment Rupture at Saturation* conditions or may result in an *Uncontrolled Reaction – Thermal Initiation*.

Relief Device Failure is failure of a rupture disk at the normal operating pressure due to pressure cycling or fatigue.

Rotating Equipment Damage is a failure or *Rupture at Operating Temperature* due primarily High Speed (Turbines) or Vibration (other Rotating Equipment).

Seal Leak is a leak of a mechanical pump or other rotating equipment seal caused by an upset, wear, or fatigue. The frequency of failure is determined by the type of seal arrangement – *Single Mechanical Seal, Double Mechanical Seal, Magnetic Drive, or Canned Pump*.

Tube Failure LOPC is associated with a Heat Exchanger. If the Process source pressure is higher than the Heat Transfer Fluid pressure and the Relief Set Pressure, the leak is assumed to be Process Fluid. If the Heat Transfer Fluid source pressure is higher than the Relief Set Pressure and Operating Pressure, the leak is assumed to be Heat Transfer Fluid.

Uncontrolled Reaction is a group of overpressure scenarios resulting from gas generation or high vapor pressure at elevated temperature. This pressure may result in vapor venting as a *Release thru Relief System* (if the relief device is adequately sized), *Equipment Rupture at Saturation* conditions if the maximum pressure exceeds the burst pressure, or *Equipment Rupture – Detonation* for highly reactive systems. Types of Reaction include:

Uncontrolled Reaction – Thermal Initiation is used if the process, maximum heating media, or mechanical energy temperature exceeds the Temperature of No Return

Uncontrolled Reaction - Fire Induced assumes that the fire will proceed long enough for the system to exceed the Temperature of No Return.

Uncontrolled Reaction – Catalyst or Impurity denotes a reaction that may initiated by catalysts or impurities at normal operating temperature.

Uncontrolled Reaction – Pooling of Reactants denotes a reaction that is typically limited by feed rate but may build up reactants which then react like a batch reaction.

Uncontrolled Reaction - Mis-Loading denotes greater than normal reactant or less than normal solvent such that the heat of reaction per mass of mixture increases.

Uncontrolled Reaction – Incompatible Material is triggered by the user or if the NFPA reactivity rating is 2 or greater.

Vacuum Damage represents the potential for *Equipment Damage* or a *Nozzle Failure – top of Vessel* for equipment that is not full vacuum rated.

User Defined Scenarios

The User may enter additional Scenario Cases by selecting a Scenario Type, Initiating Event, Loss Event and Incident Outcome for the equipment item being evaluated. If one of the standard Scenario Types does not adequately describe the process upset, a User Defined Scenario Type may be selected and details entered under the Initiating Event description.

A Loss Event may be selected from the standard *List of Loss Events* which will allow estimation of Consequences by calculation methods within the RAST tool. Selecting User Defined Loss Event allows input of various Hazard Parameters such as Release Rate, Total Release Quantity, Distance to ERPG-3 Concentration, etc. from other software tools.

Consequences are estimated by Impact Analysis using the RAST estimates for various Hazard Parameters. If User Defined Loss Event is selected, Hazard Parameters evaluated in other software tools may be input to continue with Impact Analysis. Alternately, a Tolerable Frequency Factor may be selected without using a quantitative estimate.

Example User Defined Scenario Case

To enter a User Scenario: (Refer to Figure 6.9 for Steps 2-5)

STEP 1: Select Create User Scenario from either the Scenario List or Scenario Results worksheets.

STEP 2: Select the Scenario Type or User Defined Scenario Type from the listing. The Scenario Type is only used in the Scenario Description or to relate Loss Events with Initiating Events and Outcome in the Scenario Library. Select *Pressure Damage* from the listing.

STEP 3: Select the Initiating Event from the listing or based on the Initiating Event Factor. Enter a Description of the Initiating Event that will be used in scenario documentation. The Initiating Event Description may be also be entered or updated from the LOPA workbook. Select *Regulator Failure* from the listing. Enter a description of the failure such as “Pad Gas Pressure Regulator failure”.

STEP 4: Select the Loss Event or User Defined Loss Event. A summary of RAST estimations for various Hazard Parameters will be displayed. If User Defined Loss Event is selected, an additional column appears for input of Hazard Parameters if desired. Select *Equipment Rupture at Operating Temperature* from the listing.

STEP 5: Select an Outcome from the listed options.

- A Table of Consequences or Tolerable Frequency Factors for each Outcome is displayed based on the Impact Analysis performed within RAST to aide in selection.
- If User Defined Loss Event was selected, a Tolerable Frequency Factor may be entered directly under User Defined Consequence using a standard LOPA Tolerable Frequency Description list.

- The numerical values for Tolerable Frequency Factor, Initiating Event Factor, Probability of Ignition (based on estimated cloud volume and flammable mass), Probability of Exposure (where sufficient input information is available), and Number of Protective Layers needed are displayed.

Select *Off-Site Toxic Release* from the listing (Figure 6.9)

STEP 6: Select Save Scenario to add this User Scenario to the Scenario Listing and Scenario Results. Select Cancel and Go Back to return to other RAST worksheets without saving the User Scenario. Select Clear Inputs to start over with entry of a User Scenario.

Selection of the Scenario Type

Selection of the Initiating Event

Description of the Initiating Event

Column for entry of Consequence Analysis Parameters from other software

Scenario Definition		Results for Loss Event		Calculated	User	Units
Plant Section or Sub-Area		Consequence Analysis Reference	RAST			
Equipment Tag	V-101	Equipment Volume	100			cu m
Equipment Type	Vessel/Tank	Equivalent Hole Diameter				mm
Key Chemical	Acrylonitrile	Release location	Outdoors			
Scenario Type	Pressure Damage	Total Release Quantity	87800			kg
Initiating Event	Regulator Failure	Feed Composition	Liquid: 1 Acrylonitrile			
Initiating Event Description	Pad Gas Regulator Fails resulting in Overpressure and Rupture of V-101	Release Temperature (deg C)	25			C
Loss Event	Equipment Rupture at Operating Temperature	Release Pressure	0.3			bar
Outcome	Off-Site Toxic Release	Maximum Release Rate				kg/min
Outcome Descriptors	at a Distance to ERPG-2 Concentration (HD2) of 2240 m which exceeds Distance to the Fence Line of 180 m - Modeled as Instantaneous Release	Duration at Max Release Rate (min)	0			min
Consequence	Severity Level-6	Total Release Duration (min)	60			min
User Defined Outcome Descriptors		Liquid Pool Area	11900			sq m
User Defined Consequences		Fraction Key Chemical in Airborne Vapor	1.000			
		Time-Scaled ERPG-2 (ppm)	58			ppm
		Time-Scaled ERPG-3 (ppm)	125			ppm
		Estimated 1 hour LC-1 Concentration (ppm)	99			ppm
		Estimated 1 hour LC-50 Concentration (ppm)	171			ppm
		Estimated Time-Scaled LC-1 Concentration (ppm)	165			ppm
		Lower Flammable Limit (vol %)	3.000			vol %
		Total Airborne Quantity	68300			kg
		Max Airborne Rate (blank if Instantaneous)	2290			kg/min
		Distance to ERPG-2 Concentration (HD2)	2240			m
		Distance to ERPG-3 Concentration (HD3)	1530			m
		Distance to Severe Toxic Impact (LC-50 Concentration)	699			m
		Distance to Time-Scaled LC-1 Concentration - D Weather	1330			m
		Distance to Time-Scaled LC-1 Concentration - F Weather	5610			m
		Name of Building 1				
		Name of Building 2				
		Occ Bldgs 1 and 2 in Same Wind Direction?				
		Concentration within Occupied Building 1 (ppm)	15900			ppm
		Concentration within Occupied Building 2 (ppm)	0			ppm
		Time to LC-1 for Occupied Building 1 (sec)	3			sec
		Time to LC-1 for Occupied Building 2 (sec)				sec
		Enclosed Process Area Concentration w/o Ventilation (ppm)	0			ppm
		Enclosed Process Area Concentration w Ventilation (ppm)	0			ppm
		Time to Reach LC-1 Enclosed Process Area w/o Ventilation (sec)				sec
		Time to Reach LC-1 Enclosed Process Area w Ventilation (sec)				sec
		Distance to Lower Flammable Limit (LFL) Concentration	132			m
		Distance to Severe Flammable Impact (0.5 LFL, BLEVE, or Dust Fireball)	192			m
		Rupture Distance to Direct Blast Impact (Overpressure or Fragments)	31			m
		Rupture Distance to 1 psi Overpressure	5			m
		Maximum Fragment Range	31			m
		Rupture Overpressure at Typical Construction Occupied Bldg 1	0.1			psi
		Rupture Overpressure at Typical Construction Occupied Bldg 2	0			psi
		Flammable Vapor Rate	2360			kg/min
		Explosion Distance to 1 psi Overpressure	308			m
		Explosion Overpressure at Typical Construction Occupied Bldg 1 (psi)	6.6			psi
		Explosion Overpressure at Typical Construction Occupied Bldg 2 (psi)	0			psi
		Time to Relief Set Pressure or Burst				sec

Selection of Incident Outcome

Save Scenario

Summary of the RAST Consequence Analysis Results for the Loss Event

Tolerable Frequency Factor	6
Initiating Event Factor	1
Probability of Ignition	
Probability of Exposure	
Time at Risk	
Layers of Protection Required	5

Clear Inputs

Save Scenario

Cancel and Go Back

Figure 6.9 User Defined Scenario Example

7. LAYERS OF PROTECTION ANALYSIS

Layers of Protection Analysis (LOPA) is a method for evaluating the effectiveness of Independent Protection Layers (IPLs) in reducing the likelihood or severity of an undesirable event. LOPA builds on information and Scenarios developed during Hazard Screening and Evaluation. The analysis uses a simplified “order of magnitude” approach for analysis of Process Risk.

This section covers:

- How Layers of Protection Analysis is addressed in RAST
- How to enter and update LOPA Unmitigated Risk information (such as Tolerable Frequency Factor, Initiating Event, and Enabling Conditions).
- How to enter Protective Layer information
- How to use worksheets that provide supporting evaluations for LOPA Analysis.

LOPA Menu

On the LOPA Menu worksheet (Figure 7.1); the Equipment Identification, Equipment Type, and Location (Outdoors or Indoors) are displayed. With the LOPA Menu, one may:

- Return to the Main Menu
- Update Scenario Analysis for cases associated with the Equipment Item being analyzed.
- Update Scenario Analysis for cases associated with all Equipment Items within the Equipment Table.
- Set controls for the cases that will be created in Scenario Analysis
- Access the Scenario Results worksheet for Selection of LOPA Scenario Cases.
- Set filter criteria for Scenario Results worksheet upon return from the LOPA Worksheet
- Access special LOPA worksheets including Pool Fire Evaluation, Protective Layer (IPL) Summary, Estimation of Maximum Allowable Response Time (MART) and Estimation of Maximum Allowable Leak Rate (MALR).
- View a Risk Summary

Update Scenario Analysis

This command updates the Scenario Results worksheet with the current estimations. Upon completion of the update, the Scenario Results worksheet will be displayed.

All calculations within the RAST Excel workbook are “live” or current with the input values displayed on the various Input worksheets. *Update Scenario Analysis* allows a “snapshot” of the current evaluation results to be saved as potential LOPA scenario cases. A comparison is made to the previous values in the Scenario Results worksheet allowing the User to track changes to the previous evaluation.

Update All Scenario Cases performs the *Update Scenario Analysis* for all Equipment Items in the Equipment Table. Note that for a large file this update may require more than one hour for completion.

(Additional information may be found under the *Scenario Results* workbook section.)




Figure 7.1: LOPA Menu

Scenario Results Worksheet

The Scenario Results worksheet (Figure 7.2) contains a summary of the evaluation for all Scenario Cases that have been identified either from the Scenario Library or User entered. The summary for each Scenario Cases is stored under a unique Scenario Number which is assigned by the RAST tool. A “filter” button at the top left of this worksheet allows excluding the Protective Layer details from this view.

From the Scenario Results Worksheet one may access the LOPA Worksheet.

View results summary without Protective Layer details using Column Filter 1

Each Scenario is stored in a single row identified by a unique Scenario Number

Each Scenario contains an Equipment Type, Scenario Type, Initiating Event, Loss Event, Incident Outcome, Consequence (LOPA Tolerable Frequency) and Key Chemical Involved.

Comparison to previous analysis results

LOPA GAP ANALYSIS

Scenario	Cross Ref	Equipment Tag	Scenario Type	Initiating Event General Description	Loss Event	Outcome	Key Chemical	Consequence	Tolerable Frequency Factor	Uninitiated Frequency Factor	Uninitiated Frequency Factor Used	Initiating Event Factor	Probability of Ignition	Probability of Ignition Used	Probability of Exposure	Probability of Exposure Used	Probability of Other	Probability of Other Used	Worst Case Scenario for Further Analysis	Analyze via LOPA?	Source	Tool Version Used for Last Calc	Date of Last Calc	Comparison with Last Run
6.01		V-101	Drain or Vent Valve Open	Human Failure Action on Drain or Vent Valve	Drain or Vent Valve Leak	Chemical Exposure	Acrylonitrile	Severity Level-2	3	3	2				0	0	0	1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
4.01		V-101	Drain or Vent Valve Open	Human Failure Action on Drain or Vent Valve	Drain or Vent Valve Leak	Off-Site Toxic Release	Acrylonitrile	Severity Level-4	6	6	2				0	0	0	3	3	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
5.01		V-101	Drain or Vent Valve Open	Human Failure Action on Drain or Vent Valve	Drain or Vent Valve Leak	On-Site Toxic Release	Acrylonitrile	Severity Level-3	4	4	2				0	0	0	2	2	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
7.01		V-101	Drain or Vent Valve Open	Human Failure Action on Drain or Vent Valve	Drain or Vent Valve Leak	Toxic Infiltration	Acrylonitrile	Severity Level-3	4	4	2				0	0	0	2	2	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
19.01		V-101	Excessive Heat Input - Pool Fire Exposure	EF=3 as determined by R	Equipment Rupture at Fire Con	Chemical Exposure	Acrylonitrile	Severity Level-3	4	4	3				0	0	0	1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
20.01		V-101	Excessive Heat Input - Pool Fire Exposure	EF=3 as determined by R	Equipment Rupture at Fire Con	Flash Fire or Fireball	Acrylonitrile	Severity Level-3	4	4	3				0	0	0	1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
18.01		V-101	Excessive Heat Input - Pool Fire Exposure	EF=3 as determined by R	Equipment Rupture at Fire Con	Off-Site Toxic Release	Acrylonitrile	Severity Level-5	6	6	3				0	0	0	3	3	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
10.01		V-101	Excessive Heat Input - Pool Fire Exposure	EF=3 as determined by R	Equipment Rupture at Fire Con	On-Site Toxic Release	Acrylonitrile	Severity Level-4	5	5	3				0	0	0	2	2	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
11.01		V-101	Excessive Heat Input - Pool Fire Exposure	EF=3 as determined by R	Equipment Rupture at Fire Con	Toxic Infiltration	Acrylonitrile	Severity Level-4	5	5	3				0	0	0	2	2	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
12.01		V-101	Excessive Heat Input - Pool Fire Exposure	EF=3 as determined by R	Vapor Retel Vent - Fire	On-Site Toxic Release	Acrylonitrile	Severity Level-5	6	6	3				0	0	0	3	3	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
13.01		V-101	Excessive Heat Input - Pool Fire Exposure	EF=3 as determined by R	Vapor Retel Vent - Fire	On-Site Toxic Release	Acrylonitrile	Severity Level-4	5	5	3				0	0	0	2	2	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
14.01		V-101	Excessive Heat Input - Pool Fire Exposure	EF=3 as determined by R	Vapor Retel Vent - Fire	Toxic Infiltration	Acrylonitrile	Severity Level-4	5	5	3				0	0	0	2	2	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
15.01		V-101	Ignitable Headspace	BPCS Instrument Loop F	Equipment Rupture - Deflagrat	Chemical Exposure	Acrylonitrile	Severity Level-2	3	3	1	1	1	1	0	0	0	1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
16.01		V-101	Ignitable Headspace	BPCS Instrument Loop F	Equipment Rupture - Deflagrat	Equipment Explosion	Acrylonitrile	Severity Level-2	3	3	1	1	1	1	0	0	0	1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
17.01		V-101	Ignitable Headspace	BPCS Instrument Loop F	Equipment Rupture - Deflagrat	Flash Fire or Fireball	Acrylonitrile	Severity Level-3	4	4	1	1	1	1	0	0	0	2	2	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
18.01		V-101	Ignitable Headspace	BPCS Instrument Loop F	Equipment Rupture - Deflagrat	Off-Site Toxic Release	Acrylonitrile	Severity Level-5	6	6	1	1	1	1				4	4	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
19.01		V-101	Ignitable Headspace	BPCS Instrument Loop F	Equipment Rupture - Deflagrat	On-Site Toxic Release	Acrylonitrile	Severity Level-4	5	5	1	1	1	1	0	0	0	3	3	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
20.01		V-101	Ignitable Headspace	BPCS Instrument Loop F	Equipment Rupture - Deflagrat	On-Site Toxic Release	Acrylonitrile	Severity Level-4	5	5	1	1	1	1				3	3	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
21.01		V-101	Mechanical Integrity Failure - Extremely	EF=4 as determined by R	Extremely L				6	6	4							2	2	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
22.01		V-101	Mechanical Integrity Failure - Extremely	EF=4 as determined by R	Extremely L				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
23.01		V-101	Mechanical Integrity Failure - Extremely	EF=4 as determined by R	Extremely L				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
24.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							2	2	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
25.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
26.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
27.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							2	2	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
28.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
29.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
30.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
31.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
32.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
33.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
34.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
35.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
36.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
37.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
38.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
39.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
40.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
41.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
42.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
43.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
44.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
45.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
46.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
47.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
48.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
49.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
50.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
51.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
52.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
53.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
54.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
55.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
56.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
57.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
58.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
59.01		V-101	Mechanical Integrity Failure - Medium	EF=4 as determined by R	Medium Hol				5	5	4							1	1	High TF & IPL	Yes	Tool 2	3/3/2019 13.24	New
60.01		V-101	Mechanical Integrity Failure - Medium	EF																				

Description of Scenario Results Worksheet

Columns at the left side of this worksheet identify the Equipment Item, Equipment Type, Scenario Type, Initiating Event, Initiating Event Description, Loss Event, Incident Outcome, and Key Chemical for the Scenario Case. These columns are denoted by “yellow” headings.

The next column is to notify the user of *Flash Convergence Errors* (column K with a pink header). When displaying entries in this column, note the following options:

- A. If the convergence is a scenario that will not be part of the risk analysis – merely ignore.
- B. If the failure is the condensation routine such that routine returns zero condensed, that is likely OK since very few chemicals or mixture will condense following release. (Note that only low vapor pressure material released at a very high temperature, i.e. > 200 C, will become supersaturated in ambient air and condense.)
- C. If a diked or bunded area exists and has not been entered, that may correct the issue. (A very large pool area is difficult to converge to a good average pool temperature.)
- D. Adjust the composition slightly. The biggest issue appears to be a small quantity of dissolved gas in the liquid. In these cases, a very small fraction evaporated causes a significant change in the pool vapor pressure.
- E. Select “pseudo” single chemical for the mixture which will generally be a more conservative result but less likely to fail to converge as there is no composition portion to the trial and error calculations (only flash fraction or temperature as being trialed).

The next series of columns represent a ***Summary of Evaluation Results***. These columns are denoted by “orange” headings. Included are:

Total Release Quantity

Maximum Release Rate

Total Airborne Quantity

Maximum Airborne Rate

Maximum Distance to Time-Scaled ERPG-2

Maximum Distance to Time Scaled ERPG-3

Distance to Severe Toxic Impact (LC-50 Concentration)

Concentration within Occupied Building

Enclosed Process Area Concentration

Distance to Severe Flammable Impact (Multiple of LFL, BLEVE, or Dust Fireball)

Rupture Distance to Direct Blast Impact (Overpressure or Fragments)

Rupture Distance to 1 psi Overpressure

Rupture Overpressure at Distance to Occupied Bldg.

Basis for Probability of Ignition (Airborne Rate or LFL Distance)

Explosion Distance to 1 psi Overpressure

Explosion Overpressure at Distance to Occupied Bldg.

Time to Relief Set Pressure or Burst Pressure

The next series of Columns represent a ***Summary of Unmitigated Risk*** for each Scenario Cases. The summary is based on analysis within the RAST workbook unless the User selects an alternate analysis. Included are:

Outcome Description

Consequence Description – based on RAST analysis of the Scenario Case

LOPA Tolerable Frequency Factor

Alternate Tolerable Frequency Factor – may be entered if other than RAST analysis is used

Initiating Event Factor

Probability of Ignition

Alternate POI – may be entered if other than RAST analysis is used

Probability of Exposure

Alternate POE – may be entered if other than RAST analysis is used

Time at Risk or Other Condition

Layers of Protection Required

Gap in Layers of Protection

The next columns capture information specific to ***Selection and Review of LOPA Scenario Cases***. Included are:

Worst Case Scenario for Further Analysis – provides guidance for selection of “worst” Scenario Cases. The Scenario Case (or cases) with the Highest *Tolerable Frequency Factor* (denoted *High TF*), Largest Number of Protective Layers Required (denoted *High IPL*), or both (denoted *High TF & IPL*) are noted for each Scenario group. Scenario Group are those scenarios with the same *Equipment Item*, *Chemical service*, *Scenario Type*, and *Loss Event* but with a different *Initiating Event* or *Incident Outcome*.

Analysis of “worst case” scenarios represents the starting point.

- *If only “Preventive” Protective Layers are used (stops the Event Sequence such as a shutting off the feed pump upon high level or shutting off the heating media supply upon high temperature), then all other cases will be adequately managed (no additional scenario cases will need analysis).*
- *If more than one “Mitigating” Protective Layer is used (reduces the magnitude of the consequence such as a sprinkler system for pool fire scenarios, than additional scenario cases representing other than the “worst case” Outcome may need to be analyzed.*
- *If more than one “Pre-Initiating” Protective Layer is used (reduces the likelihood of the Initiating Event such as a checklist to prevent leaving drain valves open), than additional scenario cases representing other than the “worst case” Initiating Event may need to be analyzed.*

Analyze via LOPA? – “Yes” is entered to select the Scenario Case for LOPA analysis. Only Scenario Cases denoted “Yes” are transferred to the LOPA worksheet for further analysis.

Source Tool Version Used for Last Calculation – captures the Version Number of RAST used for the Results currently captured in the Scenario Results worksheet.

Source – indicates which Scenario Cases were entered from the RAST Library (“Tool” or “User” entered).

Comparison with Last Run – denotes each Scenario Case as:

- *Same* – no difference in any of the captured results
- *Revised* – differences were found in one or more stored values
- *New* – a new case was added that did not previously exist
- *Eliminated* – the case no longer meets screening criteria. (Note that if the LOPA Team wants to retain an Eliminated Scenario Case, the Source column may be changed from “Tool” to “User” and the Modify User Scenario command used to update scenario information. Results are not updated for “Eliminated” Cases upon execution of the Update Scenario command.)
- *Orphaned* – the equipment item for which the scenario was created no longer exists in the Equipment Table.

Notes – may be used to capture scenario details not related to a specific LOPA factor.

“Comments /Issues to Resolve”- may be used to capture action items

Manufacturing Name, Manufacturing Date – used to capture the Manufacturing approval of the LOPA Scenario Cases analysis.

Process Safety Name, Process Safety Date - used to capture the Process Safety approval of the LOPA Scenario Cases analysis.

Process Control Name, Process Control Date- used to capture the Process Control approval of the LOPA Scenario Cases analysis.

The remaining columns of the Scenario Results worksheet are used to store all ***Protective Layer*** information from the LOPA analysis including descriptions, factors, Instrument Identification numbers, etc. As discussed under RAST – Getting Started, changes are tracked from the previous saved results as any cell that contains a value which has changed turns “green” and the prior values stored in the cell comments.

Existing Scenario Cases on the Scenario Results Worksheet may be modified by:

A scenario case may be *duplicated* by selecting any cell within the row representing the scenario may be copied and using the **Duplicate Scenario** command. A unique scenario number will be assigned by the tool.

A User Scenario may be *modified* by selecting any cell within the user scenario row and using the **Modify User Scenario** command which opens the User Scenario worksheet for editing.

The LOPA Worksheet

When activating the LOPA Worksheet from the Scenario Results worksheet, only Scenario Cases that are “filtered” on the Scenario Results worksheet will be viewed in the LOPA Workbook (Figure 7.3). For example, if the Equipment Tag (or Equipment Identification) is filtered to only one Equipment Item, only Scenario Cases for the specific Equipment Item where “Yes” has been entered under “Analyze by LOPA?” will be shown. This allows specific sections of the LOPA Worksheet to be active rather than the entire worksheet.

The screenshot displays the 'LOPA Worksheet' interface. At the top, there are buttons for 'Equipment Loaded', '< Go To LOPA', 'Export to DowGEP', and '> Go To LOPA'. Below these are buttons for 'Sort', 'Create User Scenario', 'Modify User Scenario', 'Clear Results', and 'Risk Summary'. A large orange arrow points from the 'Risk Summary' button to the 'Scenario Definition' table.

A callout box on the left contains the text: 'Transfer Scenario Information a separate LOPA worksheet by using the LOPA Worksheet command on the Scenario Results worksheet.' An orange arrow points from this box to the 'Transfer Scenario' button in the 'Scenario Results' table.

The 'Scenario Definition' table is a large table with the following columns: 'Initiating Event', 'Probability of Ignition', 'Probability of Explosive Pressure/Failure', 'Time at Risk or Other Excluding Factor', 'BPCS Control or Relief Response to Alarm', 'BPCS Control or Relief Response to Alarm', 'SIS Function A', 'SIS Function B', 'Process Relief Device', and 'EOP's 1'. The table contains several rows of data, including 'Initiating Event: Human Error', 'Probability of Ignition: 1E-05', 'Probability of Explosive Pressure/Failure: 1E-05', 'Time at Risk or Other Excluding Factor: 1E-05', 'BPCS Control or Relief Response to Alarm: 1E-05', 'BPCS Control or Relief Response to Alarm: 1E-05', 'SIS Function A: 1E-05', 'SIS Function B: 1E-05', 'Process Relief Device: 1E-05', and 'EOP's 1: 1E-05'.

Figure 7.3: Accessing the LOPA Worksheet

Unmitigated Risk – “Left” Side of LOPA Workbook

The “Left” Side of the LOPA Worksheet represents Unmitigated Risk and includes inputs for Tolerable Frequency Factor (or TFF), Initiating Event, Probability of Ignition (or Alternate POI), Probability of Exposure (or Alternate POE), Time at Risk or Other Enabling Factors.

Results from the RAST Consequence Analysis and Frequency Evaluation may be used or an Alternate method provided by the User. Additional Details for the Initiating Event (such as Sensor and Final Element Identification for Basic Process Control Failure, Procedure Reliability for Human Error, etc.) needs to be entered by the User.

Description of the Undesired Consequences

The description provided in RAST includes the Scenario Type, Type of Equipment, Chemical involved, Loss Event, Release Quantity, Airborne Rate and (if available) an estimate of the Process Safety Time. For User Defined scenarios, the Quantities reported are those entered by the User. See Figure 7.4.




Figure 7.4: Description of Consequence

Tolerable Frequency Factor Description

The Tolerable Frequency Factor description explains how the Tolerable Frequency was determined by the RAST tool. Included in the description is the selected Incident Outcome, a Hazard Distance (such as Distance to ERPG-2 Concentration), personnel location reference (such as distance to the Fence Line), and specifics on the Consequence Analysis method. A User may select an **Alternate Tolerable Frequency Factor** method by using the “+” macro button within the Tolerable Frequency Factor Description and a blank column will be available to enter a User Description and Select the Tolerable Frequency Factor from a “pull down” list. Refer to Figure 7.5.




Figure 7.5: Tolerable Frequency Factor Description

Initiating Event Factor (IEF)

The IEF is determined initially within RAST based on a most common Initiating Event but may be changed by the User from the available “pull down” list. The initial description (in blue text) should also be updated by the User to better reflect “how this could happen in my plant”. *The Initial Description is only available until it is updated. RAST will not return to the initial description once it has been updated.*

If the Initiating Event is Human Error, the reliability of the procedure and frequency of execution may be entered by selecting the “Human Error” macro button to cross check the Initiating Event Factor. If the Initiating Event is Basic Process Control System Failure, Sensor and Final Element Information may be entered by selecting the “+” macro button. Refer to Figure 7.6.




Figure 7.6 Initiating Event

Probability of Ignition (POI)

The POI for an outdoor release is determined in RAST using results of simple dispersion modeling. If needed, an *Alternate Probability of Ignition* method may be entered by selecting the “+” macro button. A blank column will be available to enter a User Description and Select the Probability of Ignition from a “pull-down” list. Refer to Figure 7.7.




Figure 7.7: Probability of Ignition

Probability of Exposure (Presence Factor)

The Presence factor is estimated in the RAST tool based on an Impact Area from simple dispersion or explosion models (similar to a release “footprint” from PHAST modeling) and Population Density of site personnel. An *Alternate Probability of Exposure* method may be entered by selecting the “+” macro button. A blank column will be available to enter a User Description and Select the Probability of Exposure from a “pull down” list. Refer to Figure 7.8.




Figure 7.8 Probability of Exposure

An additional column is available within the RAST version of the LOPA workbook to capture Time at Risk or Other Enabling Factors. There is no evaluation for Time at Risk within RAST and values are entered from a “pull down” list.

Protective Layers – “Right” Side of LOPA Workbook

The “Right” Side of the LOPA Worksheet (Figure 7.9) represents Protective Layers and includes inputs for Basic Process Control Action, Operator Response to Alarm, SIS (Safety Instrumented System) Functions, Pressure Relief Device, and Safety Related Protective Systems (SRPS). Suggested Protective Layers for Common Scenario Cases are provided the first time Update Scenario is executed. These suggestions may be revised or updated by the Analysis Team. A “pull-down” list for each Protective Layer is used to determine the appropriate LOPA Factor. The status for each Protective Layer may also be captured to aid in prioritization of work. Options include: *Fully Implemented, In Progress and Proposed*.

An IPL is considered Independent if it is not adversely affected by the initiating event or any other protection layer associated within the scenario. In some cases, however, the same IPLs may be used to manage related scenarios such that the PFD should be adjusted. If there are two scenarios with the same loss event and incident outcome but different initiating events, the PFD may need to be adjusted. For example: if there are two means for overfill of a tank, one a BPCS level control failure (at a frequency of 0.1 per year) and the other a human error, such as unloading into the wrong tank (at a frequency of 0.1 per year); then total demand on IPLs shared between these scenarios is 0.2 per year. At least one of the shared IPLs should be considered a PFD of 0.2 rather than 0.1 (or 0.02 rather than 0.01, etc.). This “correction” is typically ignored when using only order of magnitude assuming there is sufficient conservatism in the analysis. If, for example, the shared IPL is a SIS loop, then one could specify a PFD of 0.05 rather than 0.1 for a SIL-1 to accommodate.

Initial Description of common protection layers based on scenario type. To be updated by LOPA team

BPCS Control or Human Response to Alarm	BPCS Control or Human Response to Alarm	SIS Function A	SIS Function B	Pressure Relief Device	SRPS 1	SRPS 2	SRPS 3
High Level closes Feed Valve or Shuts Off Feed Pump				Pressure Relief Device Sized for Scenario and verified by qualified Relief Designer			
Protective layer status							
Credit or Probability of Failure on Demand Factor							

Protective layer categories

Protective layer pull-down list which LOPA team enters

Figure 7.9: The ‘Right Side’ of the LOPA Worksheet-IPLs

A list of Possible IPLs may be displayed using the “> Possible IPLs” macro button. A partial listing which may be updated by the Plant or Analysis Team is displayed. Refer to Figure 7.10.

> Possible IPLs		Displays a listing of possible IPLs based on type of scenario
Description of Undesired Consequence < Possible IPLs	Possible IPLs for Type of Scenario	LOPA Tolerable Frequency Factor (chemicals, quantity involved, and basis for calculations)
Vessel/Tank, V-101, is involved in an Excessive Heat Input - Pool Fire Exposure event resulting in a Vapor Relief Vent - Fire with subsequent 17800 kg airborne release of Acrylonitrile at an airborne release rate of 296 kg/min. Estimated time to relief set pressure is 31 min.	☐ Sprinkler, Deluge or Foam system that effectively extinguishes a fire that may overheat chemicals contained in process or storage equipment. ☐ Dike or Bund with Drainage to Remote Impoundment with sufficient Distance to Eliminate Fire heat adsorption	This incident could result in a Flash Fire or Fireball with operating personnel in close proximity and a Distance to Severe Flammable Impact (0.5 LFL, BLEVE, or Dust Fireball) of 56 m with the potential for Severity Level-3
IPL Status? ->		
		Tolerable Frequency Factor 4 4

Figure 7.10 Possible IPLs Displayed

Additional Information for Automated Protective Layers may be entered by selecting the “+” macro button. An additional column will appear with fields for input of key Instrument Information. Refer to Figure 7.11.

Detailed description of the IPL by the LOPA team-instrument identification in this field or within Detailed Instrumentation fields	BPCS Control or Human Response to Alarm	BPCS Control or Human Response to Alarm Instrument Details	Macro button to open Detailed Instrumentation Fields
Status may be: Proposed, In-progress, or Fully implemented	High Level closes Feed Valve or Shuts Off Feed Pump	Control Loop/ Alarm ID: Sensor #1: Sensor #2: Sensor #3: FCE #1: FCE #2: Set Point: MART: MALR: Comments:	Detailed Instrumentation Fields
Pull-down list for selection of appropriate IPL factor		Logic Solver:	

Figure 7.11: Additional IPL Details Displayed

A listing for Safety Related Protection System (SRPS) and associated credits are based on literature examples. Credits may also be “manually” entered representing values agreed upon by Process Safety Subject Matter Experts.

Use Back to Scenario Results (Figure 7.12) to Save Information that has been input on the LOPA worksheet. LOPA Information for Each Scenario Case is stored, along with the scenario information, in a single row identified by a unique Scenario number. Manually save the Entire Workbook in the appropriate location.

Scenario Definition						
Protection Gap	Scenario / Cross Ref	Description of Undesired Consequence > Possible IPLs	LOPA Tolerable Frequency Factor (chemicals, quantity involved, and basis for calculations)	Revised LOPA Tolerable Frequency Factor	Initiating Event > Human Error	Probability of Ignition
Revised	24.01	Vessel/Tank, V-101, is involved in an Overflow, or Backflow event resulting in an Overflow Release with subsequent 1550 kg airborne release of Acrylonitrile at an airborne release rate of 25.9 kg/min. Estimated time to relief set pressure is 8 min.	This incident could result in a Flash Fire or Fireball with operating personnel in close proximity and a Distance to Severe Flammable Impact (0.5 LFL, BLEVE, or Dust Fireball) of 21 m with the potential for Severity Level-3		Failure of Level Indication with continued addition of material	Outdoor release of 26.7 kg/min Flammable Material with Distance to LFL of 14 m
Instrumented Protection Credits Taken		IPL Status? →				
3		Safety	Tolerable Frequency Factor 4		BPCS Instrument Loop Failure	
Same			4		1	0
Instrumented Protection Credits Taken		IPL Status? →				
5		Safety Analysis	Tolerable Frequency Factor 6		BPCS Instrument Loop Failure	
			6		1	0

Back to Scenario Results saves any inputs made while in the LOPA worksheet to the Scenario Results worksheet

Figure 7.12 Back to Scenario Results

Example Scenario Selection and LOPA Analysis within RAST

As an example, the scenarios associated with the Acrylonitrile Storage Tank, V-101, are selected.

STEP 1: Ensure V-101 Information is “Active” within RAST.

From the Main Menu or LOPA Menu, view Equipment Identification. Refer to Figure 7.13.

Equipment Identification =	V-101
Equipment Type =	Vessel/Tank
Equipment Location =	Outdoors

Figure 7.13: Equipment Identification on Main Menu

If the Equipment Identification is not V-101, use Load Selected from the Equipment Table.

STEP 2: Ensure Analysis is Current. If the Equipment Item has not yet been analyzed or if inputs have changed since the last analysis, Select *Update Scenario for Equipment Loaded* which will go to the Scenario Results worksheet when completed.

STEP 3: Select Scenario Cases for LOPA Analysis on the Scenario Results worksheet (Figure 7.14). There are many cases listed so focus on those identified as “worst cases” as the case within a broad scenario category having the Highest Tolerable Frequency Factor (“High TF”), Greater Number of IPLs Needed (“High IPL”) or both (“High TF & IPL”).

STEP 4: Select LOPA Worksheet. Information from the RAST evaluation will be captured in the LOPA Worksheet for additional inputs and evaluation by the LOPA Team. Refer to Figure 7.16.

Equipment Load
V-101

<< Go To LOPA Export to DowGEP **LOPA Worksheet >** Clear Results Risk Summary >

Ensure LOPA team understands each scenario and its consequence. Use Notes Column for clarity as appropriate

LOPA Team should update the initiating event description and ensure the appropriate factor is used

LOPA Team should complete the detailed protective layer description and select IPL from the pull-down list

Protection Map	Scenario / Cause Ref	Description of Undesired Consequence	LOPA Tolerable Frequency Factor	Initiating Event	Probability of Ignition	Probability of Exposure	Time at Risk or Other Enabling Factor	SPCB Control or Human Response	SPCB Control or Human Response	BB Function A	BB Function B	Pressure Relief Device	SOPS
Same	3.01	Vessel/Tank, V-101, is involved in a Drain or Vent Valve Open event resulting in a Drain or Vent Leak with subsequent 440 kg airborne release of Acrylonitrile at an airborne release rate of 14.4 kg/min.	1E-05	This incident could result in an OR-500 Leak Release at a Distance to BPPD-2 Concentration (H2C) of 100 in which exceeds Distance to the Permit Line of 100 in-Mile as Intermittent Release with the potential for Severity Level 5.	1E-05	1E-05	1E-05	Operator Failure Action more than once per quarter or less	None				
Revised	10.01	Vessel/Tank, V-101, is involved in an Excessive Heat Input - Post-Fire Exposure event resulting in an Equipment Failure of the Conduits with subsequent 10000 kg airborne release of Acrylonitrile. Estimated time to rupture is 2000 sec.	1E-05	This incident could result in an OR-500 Leak Release at a Distance to BPPD-2 Concentration (H2C) of 100 in which exceeds Distance to the Permit Line of 100 in-Mile as Intermittent Release with the potential for Severity Level 5.	1E-05	1E-05	1E-05	Loss of Flammable Material on Material above the Heat Input which may ignite				Pressure Relief Device Signal for Excessive and venting to be added to Relief Design	
Revised	10.01	Vessel/Tank, V-101, is involved in an Excessive Heat Input - Post-Fire Exposure event resulting in a Relief Valve Failure - Fire with subsequent 17000 kg airborne release of Acrylonitrile at an airborne release rate of 285 kg/min. Estimated time to relief pressure is 31 min.	1E-05	This incident could result in an OR-500 Leak Release at a Distance to BPPD-2 Concentration (H2C) of 100 in which exceeds Distance to the Permit Line of 100 in-Mile as Intermittent Release with the potential for Severity Level 5.	1E-05	1E-05	1E-05	Loss of Flammable Material on Material above the Relief Valve which may ignite					
Revised	7.01	Vessel/Tank, V-101, is involved in an Ignitable Nonexplosive event resulting in an Equipment Failure - Delugation with subsequent 2000 kg airborne release of Acrylonitrile.	1E-05	This incident could result in an OR-500 Leak Release at a Distance to BPPD-2 Concentration (H2C) of 100 in which exceeds Distance to the Permit Line of 100 in-Mile as Intermittent Release with the potential for Severity Level 5.	1E-05	1E-05	1E-05	Failure of Pressure or Non-Conductive Atmospheric Control	Heat Source Ignition of Conductive Flammable Material				

Figure 7.16: LOPA Worksheet

STEP 5: Review the Description of Undesired Consequences and LOPA Tolerable Frequency Factor provided by RAST. This Description and Tolerable Frequency Factor are based on a specific RAST analysis and may not be changed. Consider entering User Scenario Cases where these descriptions do not represent a Process Risk associated with the equipment being analyzed. If a more detailed analysis of the Consequence is available which results in a different LOPA Tolerable Frequency Factor, an alternate Tolerable Frequency Factor and Description may be entered and the RAST analysis will not be used.

STEP 6: Review the Initiating Event Description and Update as appropriate. The documentation should be clearly understood by LOPA Team members. *Determine if the correct Initiating Event Factor has been used and Update if needed.*

Starting with the Open Drain Valve, update the Initiating Description to better reflect how this might occur. Consider how frequently the drain valve might be operated – such as opened less than once per year to prepare the pump or piping for maintenance or opened with each transfer to drain the unloading hose. Change the Initiating Event Factor by using the “pull down” Menu to “Operator Failure Action more than once per quarter” if appropriate.

STEP 7: Review the Enabling Factors and Update as appropriate.

STEP 8: Determine the Most Effective Protective Layers for managing the Process Risk. Protective Layer information is entered on the “Right” Side of the LOPA Workbook. Some common Protective Layers are suggested by RAST which the LOPA Team updates the description and enters the appropriate “Credit” from “pull down” Menu selections for each.

In this Scenario Case, a flammable leak detector with alarm would be documented under “Operator Response to Alarm” if there were sufficient time for Operator Response to stop the leak and significantly reduce the Consequence. This would represent a “Mitigating” Protective Layers and it does not prevent the Loss Event (leak from an open drain valve) from occurring.

STEP 9: Complete the LOPA Analysis by entering any Notes to help explain the Scenario Case. Another column is provided in the RAST version of the LOPA Workbook for capturing Issues and Action Items. In addition, columns are provided for entry of Process Safety, Manufacturing, and Process Control reviewers and Review Date.

STEP 10: Save the LOPA Inputs to the Scenario Results Worksheet. Select Back to Scenario Results to save inputs made on the LOPA Worksheet. Once the LOPA Workbook has “closed”, the entire RAST spreadsheet should be saved.

Mechanical Integrity Scenarios in RAST

Mechanical Integrity (MI) failures represent nearly 50% of Process Safety Events. These are difficult to analyze within LOPA as a “cause” is not identified other than corrosion or fatigue. Without an identified “cause” only frequent inspection and Mitigating Protective Layers can be used. Fortunately, Mechanical Integrity failures of piping and equipment are not frequent and, in many cases, Protective Layers will not be required.

RAST screens for Mechanical Integrity failures based on “order of magnitude” industry frequency data. This feature is disabled on the LOPA Menu by entering “Yes” to the question “Exclude Mechanical Integrity Scenarios”. MI scenarios appear in the Scenario Result workbook as “Piping or Equipment LOPC – xxx” where xxx represent a specific hole size. Screening is performed using four hole sizes: 5 mm, 25 mm, 100 mm, and 250 mm (or other hole sizes entered under the Administrative Parameters).

Pool Fire Evaluation

A “general” Initiating Event Factor representing a leak with ignition is used by RAST for initial screening of Pool Fire cases. Estimation of pool fire frequency, however, is complex and requires an evaluation of all potential leak sources of fuel. A Pool Fire Frequency section of this worksheet is available to perform a very simple Fault Tree based on LOPA Scenario information to obtain a more reasonable estimate of the Initiating Event Factor.

STEP 1: *Select Estimate Pool Fire Evaluation* from the either the Main Menu or LOPA Menu. *Since the Pool Fire Evaluation Summary is commonly used to determine which equipment may require more detailed evaluation of Pool Fire Frequency, access is located on both the Main Menu and LOPA Menu.*

STEP 2: *Identify Scenario Cases* (on Scenario Results worksheet) which contribute to a flammable leak near the physical location of the equipment being analyzed (cases with flammable outcome that are not pool fire related). Refer to Figure 7.17. A pool fire scenario impacting V-101 could be caused by spills from V-101, pump P-101, or other tanks within the same dike or containment area.

To determine scenario cases with flammable outcome not related to pool fire, one may *filter* scenario cases with Outcome of either “Flash, Jet or Pool Fire” or “Vapor Cloud Explosion” or “Building Explosion” and *filter* Scenario Type to exclude “Excessive Heat Input – Pool Fire”.

To reduce the number of contributing cases (to less than 10), those with highest frequency should be selected (or those with the smallest sum of Initiating Event plus Probability of Ignition plus non-mitigating Protective Layer factors). The summation of frequencies for the contributing scenarios will not be significantly impacted by excluding the very low frequency cases.

Maximum Allowable Response Time

An estimate of the Maximum Allowable Response Time (MART) is required for each Safety Instrumented System identified within a LOPA analysis. The MART provides key information for specification of the instrumentation. The RAST tool provides a worksheet to assist in MART estimation for common scenarios. The MART-MALT Estimation worksheet is accessed from the LOPA Menu. Refer to Figure 7.19.

Overflow and Backflow – this section of the MART worksheet estimates the MART from an entered High-Level Alarm Set Point to “hydraulically full” based on the entered Maximum Feed Rate or Maximum Backflow Rate inputs from the Process Conditions worksheet. A value for the Sensor Time Constant may also be entered which will incorporate a first-order time delay into the MART estimate.

Pad Gas Overpressure – this section of the MART worksheet estimates the MART from an entered High-Pressure Alarm Set Point to the lower of MAWP or Relief Device Set Pressure based on the entered Maximum Pad Gas Rate input from the Process Conditions worksheet. A value for the Sensor Time Constant may also be entered which will incorporate a first-order time delay into the MART estimate.

Overheating – this section of the MART worksheet estimates the MART from an entered High Temperature Alarm Set Point to the Saturation Temperature at the lower of MAWP or Relief Device Set Pressure based on heat inputs from Heat Transfer, Mechanical Energy, or Fire. A value for the Sensor Time Constant may also be entered which will incorporate a first-order time delay into the MART estimate.

Reaction – this section of the MART worksheet estimates the MART from an entered desired High Temperature Alarm Set Point to the Saturation Temperature at the lower of MAWP or Relief Device Set Pressure based on heat inputs from various Reaction cases. A value for the Sensor Time Constant may also be entered which will incorporate a first-order time delay into the MART estimate. As reaction heat rate may be very high, an actual High Temperature Alarm Set Point meeting the desired value is returned based on the entered Sensor Time Constant.

Note that the estimates from the MART-MALR worksheet are not saved. Results may be entered in the SIS Instrumentation details of the LOPA workbook.

[<< Go To LOPA Menu](#)**Maximum Allowable Response Time (MART)**[Clear Input This Worksheet](#)*This Worksheet for Calculation Only - Results are Not Saved. Print this page if a copy is needed.*

Equipment Identification:
Equipment Type:
MAWP or Relief Set Pressure:

Estimated as the time between the alarm activation and the undesired consequence (typically activation of a relief device or equipment rupture). Estimated as 0.5 times Process Safety Time to allow for Sensor Response, Decision Time, and Action Time. *Note that Heat Losses are Not Included in the Estimated Times. MART for Pumps is found on the Pump Deadhead Report.*

Liquid Overfilling Scenario:

	<u>Overflow</u>	<u>Backflow</u>	
Level Alarm Set Point:			Fraction Full
Sensor Time Constant:			min
Maximum Contained Mass:	79690		Kg
Maximum Source Pressure:	0.001	2.000	bar gauge
Liquid Feedrate:	400.00	0.00	Kg/min
Sensor Lag:	0.0000	0.0000	Fraction Full
Max Allowable Response Time:	199.23		min

Source Pressure less than Relief Set or MAWP - Overflow May Not Occur

Alarm set point and Sensor time constant may be entered for liquid overfill cases

Pad Gas or Vapor Overpressure:

Pressure Alarm Set Point:		bar gauge
Sensor Time Constant:		min
Normal Operating Pressure:	0.01	bar gauge
Maximum Pad Gas Flowrate:	0.000	Kg/min
Maximum Pad Gas Pressure:	0.001	bar gauge
Equipment Volume:	100000.0	liter
Initial Liquid Fill Fraction:	0.8	
Sensor Lag:	0.0000	atm gauge
Max Allowable Response Time:		min

Source Pressure less than Relief Set or MAWP - Overpressure May Not Occur

Alarm set point and Sensor time constant may be entered for excessive pressure cases

Overheating Scenario:

	<u>Heat Transfer</u>	<u>Mechanical Energy</u>	<u>Fire</u>	
Temperature Alarm Set Point:				
Sensor Time Constant:				
Normal Operating Temperature:	25			C
Boiling Point at MAWP or Relief Set	79.4			C
Heating Media Temperature:	0.0			C
Max Mechanical Energy Temperature at High Level:	25.0			C
Max Mechanical Energy Temperature at Low Level:	25.0			C
Heat Transfer Area:	0			
Heat Transfer Coefficient:	0			
Heat Capacity:	2.135			
Equipment Contained Mass at High Level:	63752.00			Kg
Equipment Contained Mass at Low Level:	7969.00			Kg
Overall Heat or Mechanical Energy Input:	0.00	0.00	2995.98	Kwatt
Sensor Lag:	0.00	0.00	0.00	C
Max Allowable Response Time at High Level:			60.11	min
Sensor Lag:	0.00	0.00	0.00	C
Max Allowable Response Time at Low Level:			25.05	min

*Heating Media Temperature less than Boiling Point at Relief Set or MAWP - Overpressure May Not Occur**Maximum Mechanical Energy Temperature at High Level less than Boiling Point at Relief Set or MAWP - Overpressure May Not Occur**Maximum Mechanical Energy Temperature at Low Level less than Boiling Point at Relief Set or MAWP - Overpressure May Not Occur*

Alarm set point and Sensor time constant may be entered for overheating or reactive cases

Estimated Response Times are displayed

Reaction Scenario based on Normal Operation Liquid Level:*(Excludes Gas Generation)*

	<u>Adiabatic Reaction</u>	<u>Reaction + Ext Heat</u>	<u>Reaction + Fire</u>	<u>Reaction + Catalyst</u>	<u>Reaction + Pooling</u>	<u>Reaction + Misloading</u>	
Temperature Alarm Set Point	0						C
Sensor Time Constant	0						min
Temperature of No Return:	138.8						C
Boiling Pt at MAWP or Relief Set	79.4						C
Required Alarm Set Point	0.0	0.0	0.0				C
Rx Heat Rate at Alarm Point	0.0000	0.0022	1.3557				C/min
Sensor Lag:	0.0000	0.0000	0.0000				C
Time to Relief Set or MAWP:	#####	36792.94	63.97				min

Figure 7.19 Maximum Allowable Response Time

Maximum Allowable Leak Rate

An estimate of the Maximum Allowable Leak Rate is also required for each Safety Instrumented System identified within a LOPA analysis. This provides key information in the specification of instrumentation. The RAST tool provides a worksheet to assist in this estimation. The MART-MALT Estimation worksheet is accessed from the LOPA Menu. Refer to Figure 7.20.

The Maximum Allowable Leak Rate is either based on *Limiting* the incident outcome to prevent a potentially serious human impact OR based on *Stopping or Delaying* the Event Sequence. For example:

LIMIT the release rate to Prevent a Potentially Serious Human Impact would be reducing the release rate such that a multiple of ERPG-3 or $\frac{1}{2}$ LFL distance is less than 3 m (10 ft) or O₂ concentration within a confined work area is greater than 19.5 volume %.

STOP the Event Sequence from reaching Process Conditions that could lead to a Release. This may involve limiting the maximum pressure within the Equipment Item to below the MAWP or the Relief Set Pressure. For example, limit the flow rate of heat transfer fluid such that the maximum temperature is below that where the vapor pressure exceeds the MAWP or Relief Set Pressure resulting in no release.

DELAY the Event Sequence from reaching potential Release conditions for a Sufficiently Long Period of Time – which is commonly accepted as 24 hours. For example, limit the feed rate to a vessel such that the volume from alarm activation to overfill takes longer than 24 hours.

Allowable Release Rate of Hazardous Material - this section of the MALR worksheet estimates the MALR for a hazardous release such that a multiple of ERPG-3 or $\frac{1}{2}$ LFL distance is less than 3 m (10 ft). The leak location (“Indoors” or “Outdoors”) must be entered or the “default” of “Outdoors” is used. If the location is indoors, the Release Rate corresponding to O₂ concentration greater than 19.5 volume % is also reported.

Allowable Addition Rate for Preventing Loss Event - this section of the MALR worksheet estimates the MALR is based on an overall heat balance. The first estimate is the Maximum Allowable Heating Media Flow to limit the maximum temperature from increasing above the entered Temperature Alarm Set Point. The second estimate is the Maximum Allowable Reagent Flow Rate that limits the reaction temperature from increasing above the entered Temperature Alarm Set Point based on an entered Fraction of Limiting Reagent within the total equipment contents.

Addition Rate to Delay Loss Event for 24 Hours - this section of the MALR worksheet estimates the MALR based on an overall material and energy balance. The first estimate is the Maximum Allowable Heating Media Flow to limit the maximum temperature to less than the boiling point at the lower of MAWP or Relief Device Set Pressure over 24 hours. The second estimate is the Maximum Allowable Reagent Flow Rate that limits the reaction temperature to less than the boiling point at the lower of MAWP or Relief Device Set Pressure based on a Fraction of Limiting Reagent within the total equipment contents over 24 hours. The third estimate is the Feed Rate or Pad Gas Flow Rate that limits Maximum Pressure to the lower of MAWP or Relief Device Set Pressure from the High-Pressure Alarm Set Point over 24 hours. (Note that Maximum Pressure from Liquid Feed Rate is based on “compression” of the vapor head space in this estimate.)

Note that the estimates from the MART-MALR worksheet are not saved. Results may be entered in the SIS Instrumentation details of the LOPA workbook.

Maximum Allowable Leak Rate (MALR)

This Worksheet for Calculation Only - Results are Not Saved. Print this page if a copy is needed.

Equipment Identification:
Equipment Type:

Maximum Allowable Leak Rate is the maximum flow that can leak by a valve used as the final element in a LOPA scenario without exceeding a threshold consequence criteria.

There are generally three cases to consider:

- LIMIT the release rate of hazardous material such that the consequence has been essentially eliminated (this is typically based on distance to multiple of ERPG-3 or 1/2 LFL is less than 3 m).
- STOP the scenario propagation by limiting the continued addition of material or energy to less than natural ability of the system to remove (such as the flow rate of heat transfer fluid that prevents further heating of the system).
- DELAY the potential for catastrophic failure for a sufficiently long period of time (such as the flow rate which delays hydraulic overpressure for at least 24 hours) by limiting the continued addition of material or energy.

LIMIT - Allowable Release Rate of Hazardous Material:

Leak Location:
Indoor Process Volume: m³
ERPG-3 at Initial Vapor Composition: ppm
Lower Flammable Limit at Initial Vapor Composition: vol %
Approximate Flash + Pool Evaporation Fractions:
Maximum Allowable Leak Rate for multiple of ERPG-3 < 3 m: Kg/min
Maximum Allowable Leak Rate for 0.5 LFL < 3 m: Kg/min

Enter leak location

MALR based on flammable or toxic personnel exposure

STOP - Allowable Addition Rate for Preventing Incident

Equipment Surface Area: m²
Heat Loss Coefficient (with Insulation): Kwatt/m² C
Alarm Temperature: C
Heat Loss Rate at Temperature Alarm: Kwatt
Heat Transfer:
Heat Transfer Fluid: C
Heat Transfer Fluid Temperature: C
Heat Capacity: Kjoule/Kg C
Maximum Allowable Heating Media Leak Rate: Kg/min

MALR to stop the event sequence based on heat rate of reaction

Reaction:
Fraction Limiting Reagent within Reaction Mixture:
Heat of Reaction: Kjoule/Kg Reaction Mixture
Reaction Temperature of No Return: C
Heat Loss Rate at Temperature Alarm: Kwatt
Maximum Allowable Reagent Addition Rate: Kg/min

Alarm Temperature is less than Ambient Temperature

DELAY - Addition Rate to Delay Incident for 24 Hours

Contained Mass: Kg
Process Heat Capacity: Kjoule/Kg C - Liquid
Total 24 hour Heat Input: Kjoule
Maximum Allowable Heating Media Leak Rate: Kg/min
Total 24 hour Reaction Heat Input: Kjoule
Maximum Allowable Reagent Addition Rate: Kg/min

Displays 24-hour MALR based on heat rate

Equipment Volume: m³
Initial Liquid Fill Fraction:
Maximum Allowable Pad Gas Leak Rate: Kg/min
Maximum Allowable Liquid Fill Rate: Kg/min

Displays 24-hour MALR based on liquid or vapor feed rate

Figure 7.20: Maximum Allowable Leak Time

Protection Layer Summary

A listing of each unique Protective Layer associated with a specific Equipment Item is displayed on the IPL Summary worksheet. This worksheet is accessed from the LOPA Menu. The Refresh macro (top center of the worksheet) should be used to update the information shown. Refer to Figure 7.21.

Control Loop ID or Alarm ID or SF	IPL Type	IPL Color	Scenario No	Equipment Tag	Credit Factor	General Description	Detail Description	IPL Status
Alarm 101D	2 - OPR	1	3.01	V-101	1	Human Response to Abnormal Condition	Flammable leak detection with alarm and Operator Response	Proposed
Alarm 101D	2 - OPR	1	13.01	V-101	1	Human Response to Abnormal Condition	Flammable leak detection with alarm and Operator Response	Proposed
Alarm 101D	2 - OPR	1	16.01	V-101	1	Human Response to Abnormal Condition	Flammable leak detection with alarm and Operator Response	Proposed
Alarm 101D	2 - OPR	1	21.01	V-101	1	Human Response to Abnormal Condition	Flammable leak detection with alarm and Operator Response	Proposed
SIF-101A	3 - SIS	3	21.01	V-101	2	SIS - SIL 2	High Level Interlock with feed pump to vary quickly stop the	Fully Implemented
SIF-101B	3 - SIS	3	7.01	V-101	2	SIS - SIL 2	Low pressure interlock with discharge pump to prevent tri	Fully Implemented
n/a	4 - Relief	5	7.01	V-101	2	Explosion Panels meeting NFPA 68 or eq	Weak seam roof which would relief deflagration pressure	In Progress
n/a	4 - Relief	5	16.01	V-101	2	Fully Meets Relief Design Criteria (No ev	Pressure Relief Device Sized for Scenario and verified by	Fully Implemented
n/a	5 - SRPS	6	3.01	V-101	1	1 - Other Safety related protection system	Procedure to pressure check all equipment and piping fol	Fully Implemented
n/a	5 - SRPS	6	13.01	V-101	1	Effluent Treatment System (Scrubber, Fl	The ERV is piping to a flare system	Proposed
n/a	5 - SRPS	7	13.01	V-101	1	Mitigation System (Deluge, Foam, etc.) th	The tank farm area is equipped with a sprinkler-deluge sy	Fully Implemented
n/a	5 - SRPS	6	16.01	V-101	1	Mitigation System (Deluge, Foam, etc.) th	The tank farm area is equipped with a sprinkler-deluge sy	Fully Implemented
n/a	5 - SRPS	6	21.01	V-101	1	1 - Other Safety related protection system	Procedure to check tank level to ensure instruments and v	Fully Implemented
Alarm 101D	FG-101				25 ppm		Flammable leak detection with response per procedure P-101 A	
Alarm 101D	FG-101				25 ppm		Flammable leak detection with response per procedure P-101 A	
Alarm 101D	FG-101				25 ppm		Flammable leak detection with response per procedure P-101 A	
Alarm 101D	FG-101				25 ppm		Flammable leak detection with response per procedure P-101 A	
SIF-101A	LT-101A	LT-101B		Pump P-101	0.95			
SIF-101B	PT-101			Pump P-101	10 mB			
n/a								
n/a								
n/a								
n/a								
n/a								
n/a								

Figure 7.21: Independent Protection Layer Summary

Risk Summary

The status for Protective Layers may be entered for each Scenario in the LOPA Workbook. A table of LOPA Consequence (as Tolerable Frequency Factor) versus LOPA Frequency is developed for all "Analyzed" Scenarios with and without fully implemented Protective Layers. This Risk Graph Summary is provided to assist in prioritization of Risk Reduction capital spending. The Risk Summary may be viewed for ALL Equipment Items within the Equipment Table or "filtered" to only the specific Equipment Items selected on the left side of this worksheet. The *Risk Summary* is accessed through the LOPA Menu. Refer to Figure 7.22.




Figure 7.22: Risk Summary Worksheet

8. CASE STUDY

To gain familiarity with the RAST spreadsheet tool, the Example Problem described in the Getting Started section is used for this Case Study.

A Case Study – Input Information (Figure 8.1)

Under Getting Started, the following example is used:




Figure 8.1: Input Information for the Case Study

In addition to the Storage Tank, perform analysis for the Tank Truck and Pump with 200 m transfer piping.

Additional input information includes:

Storage Tank, V-101

- Flat Bottom Non-Anchored Tank within a 200 m^2 diked or bunded area and 70000 Kg of other flammables in the area.
- Relief Device PVRV-101 is a 250 mm (10 inch) diameter PVRV set at 0.07 barg (1 psig). The Relief Discharge Elevation is 6 m (20 ft) with Horizontal discharge.
- V-101 is maintained with a non-ignitable atmosphere. The maximum pad gas source pressure is regulated to 1 barg (14.5 psig) with a maximum flow of 100 standard m^3/hour (3500 $\text{ft}^3/\text{hr.}$)
- V-101 is “vapor balanced” with the Tank Truck during unloading.
- The maximum liquid level is 6 meters and the tank is not rated for full vacuum.

Acrylonitrile Tank Truck

- The truck volume is 21 m^3 (5500 gal) with a maximum allowable working pressure of 1 barg (14.5 psig) and not rated for full vacuum.
- The maximum liquid level is 2 meters.

- A 75 mm (3 inch) diameter hose is used for unloading at a flow rate of 400 Kg/min (880 lb./min).
- An operator is present during the unloading operation.

Pump, P-101 with Associated Piping

- The Pump is a 75 mm (3 inch) suction Centrifugal with a Double Mechanical Seal located within the 200 m² diked area.
- The maximum pump discharge pressure is 3 barg (43.5 psig) and maximum allowable working pressure is 10 barg (145 psig).
- The associated process piping is roughly 200 m length with 20 flanges.

Acrylonitrile Reaction Data

- Heat of Reaction: - 326 cal/g
- Activation Energy: 32 Kcal/g mole
- Detected Onset Temperature: 190 C
- Detected Onset Rate: 0.08 C/min
- Test Method: ARC with Phi Factor of 2.1

A Case Study –
Screening
Evaluations

For each Equipment Item:

- ☐ Complete the necessary Inputs
- ☐ Determine the F&EI and CEI
- ☐ Review the Hazards and Potential Loss Event Consequences and note which hazards will likely need to be analyzed
- ☐ Review the Scenario List (on the Scenario Identification worksheet) and note any scenarios or Tolerable Frequency Factors that may not seem reasonable
- ☐ Review the Relief Effluent Screening for PVRV-101

A Case Study –
Preliminary Risk
Analysis

For each Equipment Item:

- ☐ Review the List of Scenarios and add additional scenarios that should be considered.
- ☐ Update Scenarios and Select those appropriate for LOPA Analysis.
- ☐ Complete LOPA Analysis for at least 2 Scenarios for each Equipment Item.
- ☐ Estimate the Maximum Allowable Response Time and Maximum Allowable Leak Rate for at least one Scenario

9. REFERENCES

Please refer to the CHEF Manual for the complete listing of references used to develop the RAST Software.

- [1] CCPS, "Risk Analysis Screening Tool (RAST) and Chemical Hazard Engineering Fundamentals (CHEF)," 2019. [Online]. Available: <https://www.aiche.org/ccps/resources/tools/risk-analysis-screening-tool-rast-and-chemical-hazard-engineering-fundamentals-chef>. [Accessed 2019].
- [2] CCPS, "CCPS Process Safety Glossary," Center for Chemical Process Safety, 2020. [Online]. Available: <https://www.aiche.org/ccps/resources/glossary>.
- [3] CCPS, "Chemical Reactivity Worksheet (Version 4.0)," 2019. [Online]. Available: <https://www.aiche.org/ccps/resources/chemical-reactivity-worksheet>. [Accessed 2019].
- [4] API, "API Standard 521: Pressure-relieving and Depressuring Systems, 6th Ed.," American Petroleum Institute, Washington, D.C. USA, 2016.

10. GLOSSARY OF TERMS

Please refer to the CHEF's Manual for the Glossary of Terms.

11. REVISION HISTORY

Revision	Date	Description
1.0	08-Apr-2018	Initial issue. Originally donated documentation with minor modifications.
1.1	13-Sep-2018	Minor corrections reflecting update of RAST Software. Addressed minor formatting issues.
1.2	11-Feb-2018	Updated Introduction. Updated terms to align with CCPS Process Safety Glossary. Addition of Glossary to Manual.
2.0	25-Mar-2019	Major revisions to RAST Software reflected in the CHEF Manual, the CHEF Workbook, this RAST User's Manual. Includes some technical clarification, updates and improved descriptions reflecting feedback on earlier editions.
2.1	22-Apr-2019	Addressed minor formatting issues.
3.0	12-Mar-2020	Issued with updates to the Chemical Hazards Engineering Fundamentals (CHEF) Manual. Updated literature references to be consistent with the CHEF Manual. Referred Glossary to CHEF Manual. Updates to RAST/CHEF software reflected in this version.