

Cost Analysis of the UKy-CAER Transformative CO₂ Capture System

Heather Nikolic

University of Kentucky

Center for Applied Energy Research

Lexington, KY

<http://www.caer.uky.edu/powergen/home.shtml>

Outline



- Reference Cases (RCs)
- UKy-CAER CCS Technology
- UKy-CAER TEAs and Cost Estimations
- UKy-CAER CCS Cost Estimation Compared to RC B12B

Take Away Points


1. The UKy-CAER CCS has advantages, regardless of the Reference Case used for comparison.
2. Enhanced absorber mass transfer, high absorber inlet CO₂ concentration, leaner solution feed to the absorber, split rich stripper feed and smaller columns all contribute to lower capital costs.
3. The estimated cost of CO₂ capture with the UKy-CAER CCS is \$41.40/tonne CO₂ captured (excluding T&S), compared to the RC B12B cost of \$58/tonne of CO₂.

Reference Cases

Set	Reference Case	Year Published	Steam Cycle	CCS Solvent	Used for Comparison by UKy-CAER
1	RC 9	2007	Subcritical	-	2012 TEA (Small Pilot CCS Project)
	RC 10	2007	Subcritical	MEA	
2	RC 11	2007	Supercritical	-	2016 TEA and 2017 Update (Large Pilot CCS Projects)
	RC 12	2007	Supercritical	MEA	
3	RC B12A	2015	Supercritical	-	Today
	RC B12B	2015	Supercritical	Second Generation	




RC Comparison - CCS



RC 12 is a 1st Generation Technology using MEA.

Includes:

- Flue Gas Pretreatment
- Solvent Recovery
- Amine Filtering
- Solvent Regeneration = 1530 BTU/lb CO₂ Captured (3.56 GJ/tonne)



RC B12B is an Advanced, 2nd Generation Technology.

Includes:

- Flue Gas Pretreatment
- Solvent Recovery
- Absorber Intercooler
- Amine Purification
- Pressurized Stripping
- Solvent Regeneration = 1064 BTU/lb CO₂ Captured (2.47 GJ/tonne)

RC Comparison - Configuration

Supercritical PC Plant Study Configuration Matrix				
	RC 11	RC12	RCB12A	RCB12B
Steam Cycle, MPa/°C/°C	24.1/593/593	24.1/593/593	24.1/593/593	24.1/593/593
Coal	Illinois No. 6	Illinois No. 6	Illinois No. 6	Illinois No. 6
Condenser Pressure (mm Hg)	50.8	50.8	50.8	50.8
Boiler Efficiency, HHV%	88 *	88	89 *	89
Cooling Water to Condenser, °C	16	16	16	16
Cooling Water from Condenser, °C	27	27	27	27
Stack Temperature, °C	57	32	56	42
SO ₂ Control	Wet Limestone Forced Oxidation	Wet Limestone Forced Oxidation	Wet Limestone Forced Oxidation	Wet Limestone Forced Oxidation
FGD Efficiency, %	98	98	98	98
NO _x Control	LNB with OFA and SCR *	LNB with OFA and SCR	LNB with OFA, SCR and Polishing Scrubber *	LNB with OFA, SCR and Polishing Scrubber
SCR Efficiency, %	86	86	83	85
Ammonia Slip (End of Catalyst Life), ppmv	2	2	2	2
Particulate Control	Fabric Filter	Fabric Filter	Fabric Filter	Fabric Filter
Fabric Filter Efficiency, %	99.8	99.8	99.9	99.9
Ash Distribution, Fly/Bottom	80%/20%	80%/20%	80%/20%	80%/20%
SO ₃ Control	DSI	DSI	DSI	DSI
Mercury Control	Co-benefit Capture *	Co-benefit Capture	Co-benefit Capture and ACI *	Co-benefit Capture and ACI
CO ₂ Control	NA	* Econamine	NA	* Cansolv
Overall CO ₂ Capture	NA	90.2	NA	90%
CO ₂ Sequestration	NA	Off-site Saline Formation	NA	Off-site Saline Formation

RC Comparison - Power


Plant Power Summary, kWe				
	RC 11	RC12	RCB12A	RCB12B
Coal Handling and Conveying	440	* 510	430	* 480
Pulverizer	2780	* 3850	2690	* 3370
Sorbent Handling & Reagent Preparation	890	* 1250	850	* 1070
Ash Handling	530	740	620	780
Primary Air Fans	1300	* 1800	1330	* 1670
Forced Draft Fans	1660	* 2300	1700	* 2130
Induced Draft Fans	7050	* 11120	6660	* 8350
SCR	50	70	40	60
Activated Carbon Injection	0	0	22	27
Dry Sorbent Injection	0	0	86	108
Baghouse	70	100	90	110
Wet FGD	2970	4110	2830	3550
CO ₂ Capture/Removal Auxiliaries	0	* 20600	0	* 16000
CO ₂ Compression	0	* 44890	0	* 35690
Miscellaneous BOP	2000	2000	2000	2000
Steam Turbine Auxiliaries	400	400	400	400
Condensate Pumps	800	* 560	800	* 640
Circulating Water Pumps	4730	* 10100	4520	* 7750
Ground Water Pumps	480	* 910	460	* 710
Cooling Tower Fans	2440	5230	2340	4010
Transformer Losses	1820	2290	1820	2380
TOTAL	30410	*112830	29688	* 91285

RC Comparison – Equipment Cost

Reference Case Comparison		RC 12	RC B12B	Percent Difference
Commercial Scale Plant Size (MW, net)		550	550	* 0%
Plant Efficiency, % (HHV basis)		28.4%	32.5%	* 14%
Net Plant Heat Rate, BTU/kWh HHV		12,002	10,508	-12%
Capital Costs (2011\$/KW)		\$ 3,563	\$ 3,526	-1%
Equipment Costs (\$x1000, 2011\$)				
	Item/Description			
1	COAL & SORBENT HANDLING	\$ 56,286	\$ 52,286	* -7%
2	COAL & SORBENT PREP & FEED	\$ 27,055	\$ 24,983	* -8%
3	FEEDWATER & MISC. BOP SYSTEMS	\$ 123,565	\$ 112,150	* -9%
4	PC BOILER	\$ 437,215	\$ 400,793	* -8%
5	FLUE GAS CLEANUP	\$ 196,119	\$ 197,475	* 1%
5B	CO ₂ REMOVAL & COMPRESSION	\$ 593,497	\$ 632,139	* 7%
5B.1	CO ₂ Removal System	\$ 505,963	\$ 533,757	* 5%
5B.2	CO ₂ Compression & Drying	\$ 87,534	\$ 98,381	* 12%
6	COMBUSTION TURBINE/ACCESSORIES	\$ -	\$ -	
7	HRSG, DUCTING & STACK	\$ 45,092	\$ 45,027	0%
8	STEAM TURBINE GENERATOR	\$ 166,965	\$ 178,176	* 7%
9	COOLING WATER SYSTEM	\$ 73,311	\$ 62,254	* -15%
10	ASH/SPENT SORBENT HANDLING SYSTEM	\$ 18,252	\$ 19,028	* 4%
11	ACCESSORY ELECTRIC PLANT	\$ 100,255	\$ 93,584	* -7%
12	INSTRUMENTATION & CONTROL	\$ 31,053	\$ 31,654	* 2%
13	IMPROVEMENTS TO SITE	\$ 18,332	\$ 18,063	* -1%
14	BUILDINGS & STRUCTURES	\$ 72,402	\$ 71,531	* -1%
TOTALS		\$ 1,959,399	\$ 1,939,143	* -1%




COE of RC B12B Compared to RC 12



RC B12B Advantages over RC 12:

- 1) Second Generation Solvent
- 2) Pressurized Solvent Regeneration

UKy-CAER CCS Costs Reported



Compared to RC 10
Constant Coal Feed Rate
UKy-CAER CCS Included:
Advanced Solvent
Two Stage Stripping
Heat Integration
Tall Columns

Compared to RC 12
Constant Coal Feed Rate
UKy-CAER CCS Included:
Advanced Solvent
Two Stage Stripping
Heat Integration
Tall Columns

Compared to RC 12
Constant Coal Feed Rate
UKy-CAER CCS Included:
Advanced Solvent
Two Stage Stripping
Heat Integration
Reduced Column Sizes
Split Rich Stripper Feed
Exergy Loss Minimization

Compared to RC B12B
Constant Coal Feed Rate
UKy-CAER CCS Included:
Advanced Solvent
Two Stage Stripping
Heat Integration
Reduced Column Sizes
Split Rich Stripper Feed
Exergy Loss Minimization

Compared to RC B12B
Constant Net Power Output
UKy-CAER CCS Included:
Advanced Solvent
Two Stage Stripping
Heat Integration
Reduced Column Sizes
Split Rich Stripper Feed
Exergy Loss Minimization


UKy-CAER Approach to CCS

Process
Intensification

Two-Stage
Solvent
Regeneration


System
Integration and
Heat Recovery

Advanced
Solvent



- Smaller column heights
- Discretized packing
- Absorber T profile and flooding control
- Absorber pump around
- Pressurized primary stripper
- Split rich primary stripper feed to reduce the H₂O/CO₂ ratio in the stripper outlet and supply secondary vapor source for CO₂ stripping
- Exergy loss minimization in steam extraction

UKy-CAER CCS



Includes:


- Flue Gas Pretreatment
- Solvent Recovery
- Absorber Intercooling
- Pressurized Primary Stripping
- Heat Recovery Loop, Piping and Pump

- Secondary Stripper, Overhead Condenser, Blower, Lean Amine Pump
- Secondary Stripper Gas Outlet Recycle Line Back to Boiler
- Solvent Regeneration = 900 BTU/lb CO₂ Captured (2.10 GJ/tonne)

0.7 MWe Small Pilot CCS Output: Solvent Regeneration Energy

Performance Compared to 30 wt% MEA	Advanced Solvent A	Advanced Solvent B	Advanced Solvent C
Energy Penalty	27% savings	~30% savings	20-25% savings
Solvent Circulation Rate	~35-45% reduction	~40% reduction	~30% reduction
Cyclic Capacity	~1.5X	~2X	~1.5X
Viscosity	2.5 – 3X	3 – 3.5X	~1.5X
Surface Tension	~0.6X	-1.1X	~1.0X
Degradation Products	Low	Low	Low
Solvent Regeneration Energy Measured at UKy-CAER CCS	1022 Btu/lb CO ₂ on 0.7 MWe Small Pilot, 61% of MEA on 0.1 MWth Bench	1200-1400 BTU/lb CO ₂ on 0.7 MMWe, 52% of MEA on 0.1 MWth Bench	1070-1600 BTU/lb CO ₂ on 0.7 MMWe, 68% of MEA on 0.1 MWth Bench

0.7 MWe Small Pilot CCS Output: Column Height Reduction



	2016 TEA	Updated UKy-CAER Equipment Size		
Scale	Normalized 550 MWe	Normalized 550 MWe	~170 TPD	550 MWe
Absorber	41' dia., 138' T/T, 118' pkg ht, $\Delta P = 1.79$ psi	41' dia., 80' T/T, 60' pkg ht, $\Delta P = 1.06$ psi	23' dia., 110' T/T, 60' pkg ht	48' dia., 68' T/T, 40' pkg ht
Primary Stripper	19' dia., 110' T/T, 95' pkg ht, $\Delta P = 7$ psi	19' dia., 60' T/T, 45' pkg ht, $\Delta P = 4.2$ psi	14' dia., 56' T/T, 26' pkg ht	27' dia., 38' T/T, 33' pkg ht
Secondary Stripper	21' dia., 92' T/T, 72' pkg ht, $\Delta P = 12.6$ psi	21' dia., 55' T/T, 35' pkg ht, $\Delta P = 7.5$ psi		
Direct Contact Cooler	47' dia., 110' T/T, $\Delta P = 1.7$ psi	47' dia., 65' T/T, $\Delta P = 1.0$ psi	23' dia., 49' T/T, 16.5' pkg ht, $\Delta P = 1$ psi	

Statistical analysis of small pilot CCS data show that the absorber is tall enough to approach equilibrium rich loading.

Updated Equip. Cost Estimates

	RC B12B	UKy-CAER CCS	Percent Difference
Commercial Scale Plant Size (MW, net)	550	550	0%
Plant Efficiency, % (HHV basis)	32.5%	34.0%	5%
Total Plant Costs (x 1000 2011\$)			
Item/Description			
COAL & SORBENT HANDLING	\$ * 52,286	\$ * 50,810	-3%
COAL & SORBENT PREP & FEED	\$ * 24,983	\$ * 24,242	-3%
FEEDWATER & MISC. BOP SYSTEMS	\$ * 112,150	\$ * 112,798	1%
PC BOILER	\$ * 400,793	\$ * 388,308	-3%
FLUE GAS CLEANUP	\$ * 197,475	\$ * 190,974	-3%
<i>CO₂ REMOVAL & COMPRESSION</i>	\$ * 632,139	\$ * 362,742	-43%
<i>CO₂ Removal System</i>	\$ * 533,757	\$ * 267,082	-50%
<i>CO₂ Compression & Drying</i>	\$ * 98,381	\$ * 95,659	-3%
DUCTING & STACK	\$ * 45,027	\$ * 44,664	-1%
STEAM TURBINE GENERATOR	\$ * 178,176	\$ * 173,158	-3%
COOLING WATER SYSTEM	\$ * 62,254	\$ * 61,210	-2%
ASH/SPENT SORBENT HANDLING SYSTEM	\$ * 19,028	\$ * 18,546	-3%
ACCESSORY ELECTRIC PLANT	\$ * 93,584	\$ * 90,164	-4%
INSTRUMENTATION & CONTROL	\$ * 31,654	\$ * 31,244	-1%
IMPROVEMENTS TO SITE	\$ * 18,063	\$ * 17,693	-2%
BUILDINGS & STRUCTURES	\$ * 71,531	\$ * 70,751	-1%
TOTAL	\$ 1,939,143	\$ 1,637,302	-16%

Constant Net Power Output, Higher Thermal Efficiency

Lower: Smaller power plant size

Higher: Equipment related to exergy loss minimization strategy

Lower: higher inlet CO₂ concentration, enhanced absorber mass transfer, split rich stripper feed, discretized packing, smaller columns

Lower: Takes into account the additional duct from secondary stripper back to boiler

Lower: heat integration and small cooling tower and fan

Lower: Takes into account additional CCS equipment and bigger footprint

CO₂ Removal System Equipment Cost

From TEA Performed under DE-FE0026497 Equipment List with Columns Oversized

Description	Quantity	Equipment and Materials Cost (\$)	Labor Cost (\$)	Bare Erect Cost (\$)
Pre-treatment Tower	2 op	\$ 6,073,043.85	\$ 4,858,435.08	\$ 10,931,478.93
CO ₂ Absorber	2 op	\$ 48,583,511.59	\$ 32,389,007.72	\$ 80,972,519.31
Primary Stripper	2 op	\$ 17,343,192.33	\$ 10,486,581.41	\$ 27,829,773.74
Reclaimer	1 op	\$ 1,648,333.33	\$ 1,318,666.67	\$ 2,967,000.00
Air Stripper	2 op	\$ 16,549,871.33	\$ 11,033,247.56	\$ 27,583,118.89
Reboiler	2 op	\$ 6,301,601.83	\$ 4,201,067.89	\$ 10,502,669.72
Lean/Rich Exchanger	2 op	\$ 5,509,180.47	\$ 3,505,842.11	\$ 9,015,022.58
Recycle Air Cooler #1	2 op	\$ 3,086,906.50	\$ 2,057,937.66	\$ 5,144,844.16
CO ₂ Cond #3	2 op	\$ 1,924,047.86	\$ 1,282,698.57	\$ 3,206,746.43
CO ₂ Condenser #4	2 op	\$ 202,942.55	\$ 135,295.03	\$ 338,237.58
Absorber Intercooler	2 op	\$ 2,701,219.38	\$ 1,800,812.92	\$ 4,502,032.29
Lean Cooler	2 op	\$ 1,992,470.30	\$ 1,328,313.53	\$ 3,320,783.83
Recycle Air Cooler #2	2 op	\$ 536,045.67	\$ 357,363.78	\$ 893,409.45
DCC Cooler	1 op	\$ 1,085,211.21	\$ 723,474.14	\$ 1,808,685.35
Lean Solution Pump	2 op & 2 spare	\$ 13,693,978.90	\$ 13,693,978.90	\$ 27,387,957.81
Rich Solution Pump	2 op & 2 spare	\$ 7,200,561.07	\$ 7,200,561.07	\$ 14,401,122.13
Primary Stripper Pump	2 op & 2 spare	\$ 4,436,329.41	\$ 4,436,329.41	\$ 8,872,658.83
Intercooler Pump	2 op & 1 spare	\$ 3,919,149.67	\$ 3,919,149.67	\$ 7,838,299.34
Solvent Make-up Pump	1 op & 1 spare	\$ 173,600.00	\$ 173,600.00	\$ 347,200.00
DCC Pump	1 op & 1 spare	\$ 3,292,828.47	\$ 3,292,828.47	\$ 6,585,656.95
ID Fan	2 op	\$ 6,524,033.38	\$ 3,262,016.69	\$ 9,786,050.07
Air Stripper Blower	2 op	\$ 1,069,765.75	\$ 534,882.87	\$ 1,604,648.62
Total		\$ 153,847,824.84	\$ 111,992,091.17	\$ 265,839,916.01
Allowance for Interconnections		\$ 13,122,379.48	\$ 6,674,403.11	\$ 19,796,782.59
Grand Total		\$ 166,970,204.32	\$ 118,666,494.27	\$ 285,636,698.60

Reduced Column Heights:
 Direct Contact Cooler: 110 to 65 ft.
 Absorber: 138 to 82 ft.
 Primary Stripper: 95 to 56 ft.
 Secondary Stripper: 92 to 55 ft.

The air stripper, blower, condenser and pump are only 23% of the bare erect cost which is ~\$40M.

5B. CO₂ Removal and Compression

Case 12

Item/Description	Bare Erected Cost	Eng'g CM H.O. & Fee	Process Contingencies	Project Contingencies	Total Plant Cost (\$/1000)
5B.1 CO ₂ Removal System	\$ 326,057	\$ 30,367	\$ 65,211	\$ 84,327	\$ 505,963
5B.2 CO ₂ Compression & Drying	\$ 66,717	\$ 6,228	\$ -	\$ 14,589	\$ 87,534
SUBTOTAL	\$ 392,774	\$ 36,595	\$ 65,211	\$ 98,916	\$ 593,497

UKy-CAER CCS Compared to RC 12, Constant Coal Feed Rate

Item/Description	Bare Erected Cost (\$)	Eng'g CM H.O. & Fee	Process Contingencies	Project Contingencies	Total Plant Cost (\$/1000)
5B.1 CO ₂ Removal System	\$ 201,906	\$ 17,364	\$ 34,930	\$ 45,227	\$ 299,426
5B.2 CO ₂ Compression & Drying	\$ 56,586	\$ 5,286	\$ -	\$ 12,374	\$ 74,246
SUBTOTAL	\$ 258,492	\$ 22,650	\$ 34,930	\$ 57,601	\$ 373,672

Case B12B

Item/Description	Bare Erected Cost	Eng'g CM H.O. & Fee	Process Contingencies	Project Contingencies	Total Plant Cost (\$/1000)
5B.1 CO ₂ Removal System	\$ 359,822	\$ 31,060	\$ 62,120	\$ 80,756	\$ 533,757
5B.2 CO ₂ Compression & Drying	\$ 74,531	\$ 7,453	\$ -	\$ 16,397	\$ 98,381
SUBTOTAL	\$ 434,353	\$ 38,513	\$ 62,120	\$ 97,152	\$ 632,139

UKy-CAER CCS Compared to RC B12B, Constant Net Power Output

Item/Description	Bare Erected Cost	Eng'g CM H.O. & Fee	Process Contingencies	Project Contingencies	Total Plant Cost (\$/1000)
5B.1 CO ₂ Removal System	\$ 180,048	\$ 15,542	\$ 31,084	\$ 40,709	\$ 267,082
5B.2 CO ₂ Compression and Drying	\$ 72,469	\$ 7,247	\$ -	\$ 15,943	\$ 95,659
SUBTOTAL	\$ 252,517	\$ 22,789	\$ 31,084	\$ 56,351	\$ 362,742

50% Reduction in CO₂ Removal System Cost

10% Reduction Due to Smaller Amount of CO₂ Because of the to Lower Coal Feed Rate from RC 12 to B12B and from B12B to UKy-CAER CCS

Updated Power

POWER SUMMARY	Case B12B	UKy-CAER CCS	Percent Difference
NET POWER, kWe	* 550,000	* 550,000	0%
Net Plant Efficiency (HHV)	* 32.50%	* 33.97%	5%
As-Received Coal Feed (lb/hr)	* 495,578	* 473,362	-4%
Steam Turbine Power (Gross, kWe)	* 642,000	* 632,779	-1%
AUXILIARY LOAD SUMMARY, kWe			
Coal Handling & Conveying	* 480	* 458	-4%
Pulverizers	* 3,370	* 3,219	-4%
Sorbent Handling & Reagent Preparation	* 1,070	* 1,022	-4%
Ash Handling	* 780	* 745	-4%
Primary Air Fans	* 1,670	* 1,595	-4%
Forced Draft Fans	* 2,130	* 2,035	-4%
Induced Draft Fans	* 8,350	* 7,976	-4%
SCR	* 60	* 57	-4%
Activated Carbon Injection (kW)	* 27	* 26	-4%
Dry Sorbent Injection (kW)	* 108	* 103	-4%
Baghouse	* 110	* 105	-4%
Wet FGD	* 3,550	* 3,391	-4%
CO ₂ Capture System Auxiliaries	* 16,000	* 10,867	-32%
CO ₂ Compression	* 35,690	* 34,086	-4%
Miscellaneous Balance of Plant	* 2,000	* 1,910	-4%
Steam Turbine Auxiliaries	* 400	* 394	-1%
Condensate Pumps	* 640	* 611	-4%
Circulating Water Pump	* 7750	* 7,257	-6%
Ground Water Pumps	* 710	* 674	-5%
Cooling Tower Fans	* 4010	* 3,911	-2%
Transformer Losses	* 2380	* 2,153	-10%
TOTAL AUXILIARIES, kWe	91,000	82,595	-9%

Constant Net Power Output,
Higher Thermal Efficiency

Lower: Smaller auxiliary load

Lower: Lower coal
feed rate

Lower: Smaller blowers
and pumps due to shorter
columns

Lower: Lower Steam
Turbine Power

Lower: Smaller HHV input
due to higher thermal
efficiency leads to lower
water requirement and
small cooling tower


Lower: Smaller gross
power production

Updated COE and Cost of CO₂ Captured

	RC B12B	UKy-CAER CCS	Percent Difference
Net Power, Mwe	550	550	0%
Total Plant Cost (2011 \$/kW)	3524	2977	-16%
Total Overnight Cost (2011\$/kW)	4333	3660	-16%
Total As-Spent Cost (2011\$/kW)	4940	4173	-16%
Cost of Electricity (\$/MWh, 2011\$)	133.2	116.9	-12%
CO ₂ T&S Costs	9.6	8.3	-13%
Fuel Costs	30.9	29.5	-5%
Variable Costs	12.3	12.4	1%
Fixed Costs	15.4	13.0	-16%
Capital Costs	72.2	61.9	-14%
Cost of CO ₂ Captured (\$/tonne CO ₂)	58.2	41.4	-29%

UKy-CAER Advantages:

- 1) Two Stage Solvent Regeneration
- 2) Pressurized Stripping
- 3) Split Rich Primary Stripper Feed
- 4) Advanced Solvent
- 5) CO₂ Recycle
- 6) High Solvent Cyclic Capacity, High Rich Loading and Low Lean Loading
- 7) Heat Integration
- 8) Exergy Loss Minimization



Next Steps

- CO₂ Preconcentrating Membrane
- Absorber Temperature Profile Control



Acknowledgements

Some results presented were collected under awards:

*Application of a Heat Integrated Post-combustion
CO₂ Capture System with Hitachi Advanced Solvent into
Existing Coal-Fired Power Plant, DE-FE0007395*

*Large Pilot CAER Heat Integrated Post-combustion
CO₂ Capture Technology for
Reducing the Cost of Electricity, DE-FE0026497*

*UKy-CAER Heat-integrated Transformative
CO₂ Capture Process in
Pulverized Coal Power Plants, DE-FE0031583*

U.S. DOE NETL: Andy Aurelio

EPRI: Abhoyjit Bhowan, Joseph Swisher

WP: James Simpson

UKy-CAER Team

